

SCALE: 1:250
0m 5m 10m 15m 20m 25m

LIST OF DRAWINGS

- E1 - ELECTRICAL LEGEND, LIST OF DRAWINGS, LIST OF SUBSCRIPTS, SITE PLAN AND DETAILS
E2 - LIGHTING, POWER AND MISC. SYSTEMS FLOOR PLAN, PANEL SCHEDULE, ELECTRICAL RISER DIAGRAM AND DETAILS
E3 - DETAILS

ELECTRICAL LEGEND


- A1 - FLUORESCENT LUMINAIRE. LETTER DENOTES TYPE AS SCHEDULED. CONNECTED TO PANEL A, CIRCUIT NO. 1. LINE DENOTES C/W BODINE BALLAST.
\$ - TOGGLE SWITCH, 120 VAC, 15 AMP.
⊕ - GFI DUPLEX CONVENIENCE RECEPTACLE, 120V, 15 AMP, CSA TYPE 5-15R.
H⊕ - LED, MINI-TUBE FLUORESCENT, OR HID LUMINAIRE TYPE "C". WALL MOUNTED.
□ - UNIT HEATER.
■ - SURFACE MOUNTED PANELBOARD.
TC - TIME CLOCK FOR EXTERIOR LIGHTING.
\$T - HAND WOUND TIMER FOR VENTILATION. SUPPLIED BY MECHANICAL, WIRED BY ELECTRICAL.
□ - JUNCTION BOX
⊙ - PUSHBUTTON.
DD - DAMPER MOTOR.

LIST OF SUBSCRIPTS

- WP - INDICATES WEATHER PROOF.
3 - INDICATES SWITCHING ARRANGEMENT.

NOTES


- THE COMPLETE ELECTRICAL INSTALLATION SHALL CONFORM TO THE LATEST EDITION OF THE CANADIAN ELECTRICAL CODE AND LOCAL BY LAWS CURRENTLY IN FORCE IN THE PROVINCE AND MUNICIPALITY.
- ALL WORK SHALL BE PERFORMED BY PERSONS HAVING QUALIFICATIONS AS REQUIRED BY THE AUTHORITY HAVING JURISDICTION AND WHO ARE COMPETENT IN THEIR TRADE.
- ALL WORK SHALL BE SUBJECT TO INSPECTION BY LOCAL INSPECTION AUTHORITY. THE OWNER OR HIS REPRESENTATIVE. MAKE CHANGES AND ALTERATIONS REQUIRED BY INSPECTION AUTHORITY WITHOUT CHARGE TO OWNER.
- PAYMENT FOR PERMITS AND DEPOSITS FOR THE WORK SHALL BE INCLUDED IN THE TENDER PRICE.
- BEFORE SUBMITTING A PROPOSAL FOR THE WORK COVERED BY THE SPECIFICATIONS, EACH BIDDER SHALL VISIT AND INSPECT THE SITE OF THE NEW BUILDING IN ORDER THAT HE MAY BE THOROUGHLY FAMILIAR WITH THE SITE AND LOCAL CONDITIONS, WITH THE CHARACTER AND DETAILS OF THE BUILDING CONSTRUCTION AND WITH ALL MATTERS WHICH CAN, IN ANY WAY, AFFECT THE WORK COVERED BY THE SPECIFICATIONS. NO CLAIM WILL BE ENTERTAINED OR ALLOWED FOR ANY LABOUR, MATERIALS OR OTHER EXTRAS THAT MAY BE REQUIRED FOR THE PROPER EXECUTION AND COMPLETION OF THE CONTRACT, WHICH COULD HAVE BEEN DETERMINED BY SITE EXAMINATION.
- CONTRACTOR SHALL SUPPLY AND INSTALL ALL MATERIALS EXCEPT AS OTHERWISE SPECIFIED. ALL MATERIALS AND EQUIPMENT SHALL BE NEW AND BEAR CSA APPROVAL.
- CONDUIT: THE MINIMUM SIZE OF CONDUIT SHALL BE 21mmØ UNLESS SHOWN OTHERWISE. WIRING CONCEALED ABOVE SUSPENDED CEILING OR CONCEALED WITHIN WALLS MAY BE AC-90. MAXIMUM LENGTH OF AC90 SHALL BE 3 METERS. EXPOSED WIRING SHALL BE INSTALLED IN EMT CONDUIT INSTALLED PARALLEL TO BUILDING LINES.
- WIRE: ALL WIRING SHALL BE RW90 COPPER WITH A MINIMUM SIZE OF #12 AWG. UNLESS OTHERWISE SHOWN. ALL CONDUCTORS SHALL BE PROPERLY COLOUR CODED.
- ALL WIRING DEVICES SHALL BE SPECIFICATION GRADE COMPLETE WITH STAINLESS STEEL COVERPLATES.
- CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION WITH WORK OF OTHER TRADES. ALL MECHANICAL EQUIPMENT CONTROL WIRING SHALL BE DONE BY THIS CONTRACTOR.
- GUARANTEE: THIS CONTRACTOR SHALL GUARANTEE ALL NEW MATERIALS AND WORKMANSHIP FOR A PERIOD OF ONE YEAR FROM DATE OF COMPLETION OF THE WORK AND FINAL ACCEPTANCE.



2
E1
TRENCH SECTION
N.T.S.

Public Works and
Government Services
Canada

Travaux Publics et
Services gouvernementaux
Canada



PROVINCE OF NEWFOUNDLAND AND LABRADOR
PERMIT HOLDER
This Permit Allows
STANTEC CONSULTING LTD.
To practice Professional Engineering
in Newfoundland and Labrador.
Permit No. as issued by PEG J0291
which is valid for the year 2013.

GENERAL NOTES

- ALL DIMENSIONS ARE DRAWN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
- CONTRACTOR TO VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE AND REPORT ANY DISCREPANCIES TO THE DCC REPRESENTATIVE BEFORE PROCEEDING WITH ANY PORTION OF THIS WORK.
- COORDINATE THIS DRAWING WITH ALL OTHER DRAWINGS.
- ALL WORK TO BE CARRIED OUT WITH ACCORDANCE TO THE NATIONAL BUILDING CODE.

C	ISSUED FOR TENDER	06/07 2013
B	ISSUED FOR 90% REVIEW	03/18 2013
A	ISSUED FOR 66% REVIEW	02/27 2012
revisions		date

A	A detail no. no. du detail	A
C	B location drawing no. sur dessin no.	B C
	C drawing no. dessin no.	

project project

WABUSH AIRPORT
SAND/UREA SHED

WABUSH, NL

drawing
ELECTRICAL LEGEND,
LIST OF DRAWINGS,
LIST OF SUBSCRIPTS,
SITE PLAN AND DETAIL

designed GT	concu
date 2013.03.27	
drawn KC	dessine
date 2013.03.27	
approved	approuve
date	
Tender	Soumission
PWC Project Manager	Administrateur de projets TPC
project number	no. du projet
R. 038269.001	
drawing no.	no. du dessin
E1	