

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Sewer Infrastructure Upgrade	
Solicitation No. - N° de l'invitation EW038-140126/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client CSC 20140126	Date 2013-07-08
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-9843	
File No. - N° de dossier PWU-3-36044 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-07-11	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 497-3543 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Sewage Infrastructure Upgrade

Bowden Institution

Bowden, Alberta

Project No. R.051803.001**Addendum No.3**

The following changes to the Tender Documents are effective immediately. This addendum will form part of the contract documents.

The Bid and acceptance form States 5 months for Completion.

Please reword this to say:

The Project completion must be within sixteen (16) weeks from the date of the award letter.

Specification Division 31, Section 31 22 13

3.8.1.2: change the wording in this point to:

Costs of tests will be paid by Contractor.

Specification Division 31, Section 31 23 33 .01

2.1.3.2:

Add .1: Pond sludge removed in the execution of the work, is to be sprayed off site at the contractors cost.

Add .2: Tests for sludge materials to meet the requirements of the Authority Having Jurisdiction, for agricultural spraying, are to be borne by the Contractor.

Add .3: The Contractor is responsible for sourcing and obtaining land owner permission to spray de-sludged materials

Add .4: If de-sludged materials are found to be of unsuitable quality for spraying, alternative storage arrangements will be made at the owners cost. Costs allowed for removal of sludge materials of site will be credited to the owner.