

Q&A Part 2 - : Water and Wastewater Extensions - Riding Mountain National Park

Q. Can pit run gravel be used under asphalt areas with the top 300mm C base material?

A This is acceptable.

Q Will there be trees and bush to be cleared? If so, where to dispose?

A A very minimal amount, if any at all. If disposal is required, any landfill site will accept the waste.

Q Can we get a drawing of the water main drain chambers?

A There are no asbuilts of the existing water and sewer system.

All enquiries of a technical and contractual nature are to be submitted to the Contracting Officer:

R Bedard, CFSP
Contracts, Procurement and Material Management Officer /
Manitoba Field Unit & Riding Mountain Field Unit
ron.bedard@pc.gc.ca
Telephone (204) 785-6081
Facsimile (204) 482-5887