

#### **APPENDIX 4**

#### **SITE PHOTOGRAPHS – INTERIOR**



**Photo 1: View of the Gereaux Island Light Station from Georgian Bay.**



**Photo 2: View from top of lighthouse facing south, residence building, helicopter pad, and boathouse visible.**



**Photo 3: View of lighthouse facing north.**



**Photo 4: View L.H LS-6 sample location from lighthouse third floor interior wall. Sample was found to be above criteria and is considered lead based.**



**Photo 5: View of teal paint in main floor stairwell, sample L.H LS-3 was found to be above criteria and is considered lead based.**



**Photo 6: View of residence building basement, sample R.B LS-5 (battleship grey floor paint) was found to be above criteria and is considered lead based.**





**Photo 7: View of peeling paint in bathroom in residence building, sample R.B LS-8 was found to be below criteria and is considered non-lead based.**