

PART 1 GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.2 No. 100-04, Motors and Generators.
 - .2 CSA C22.2 No. 145-M1986 (R2004), Motors and Generators for Use in Hazardous Locations.
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
 - .1 EEMAC M1-7-1992, Standard for Motors and Generators.

1.2 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings:
 - .1 Indicate dimensions, recommended installation procedure, wiring diagrams, sizes and location of mounting bolt holes and recommended support method.
- .3 Quality Assurance Submittals:
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Manufacturer's Instructions: submit manufacturer's installation instructions.
- .4 Closeout Submittals:
 - .1 Provide maintenance data for fractional horsepower motors for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Collect, package and store expired motors for either recycling or rebuilding and return to recycler or rebuilder.

PART 2 PRODUCTS

2.1 FRACTIONAL HORSEPOWER MOTOR

- .1 Non-hazardous locations: to CSA C22.2 No. 100 and EEMAC M1-7.
- .2 Hazardous locations: to CSA C22.2 No. 145.
- .3 Motor with inherent overheating protectors.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install wiring, flexible connections and grounding.
- .2 Check rotation before coupling to driven equipment.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION