

PART 1 GENERAL

1.1 REFERENCES

- .1 American National Standards Institute (ANSI).
 - .1 ANSI B31.1, Power Piping.
- .2 Canadian General Standards Board (CGSB).
 - .1 CAN/CGSB-1.40-97, Anticorrosive Structural Steel Alkyd Primer

1.2 GENERAL REQUIREMENTS

- .1 Pipe supports in accordance with requirements of ANSI B31.1.
- .2 Provide hangers and supports to secure equipment in place, prevent vibration, maintain grade, provide for expansion and contraction and to accommodate insulation; provide insulation protection saddles.
- .3 Install supports of strength and rigidity to suit loading without unduly stressing building. Locate adjacent to equipment to prevent undue stresses in equipment.
- .4 Select hangers and supports for the service and in accordance with the manufacturer's recommended maximum loading. Hangers safety factor of 5 to 1.
- .5 Fasten hangers and supports to building steel or inserts in concrete construction.
- .6 Provide and set sleeves required for equipment, including openings required for placing equipment.

1.3 APPROVALS

- .1 Obtain approval from the Departmental Representative prior to drilling for supports for piping systems.
- .2 Use of equipment for hanger supports is not permitted.
- .3 Use of perforated band iron, wire or chain as hangers is not permitted.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Supports are to be used in the meter vault.

PART 2 PRODUCTS

2.1 INSERTS

- .1 Inserts: malleable iron case or galvanized steel shell and expander plug for threaded connection with lateral adjustment, top slot for reinforcing rods, and lugs for attaching to forms.
- .2 Size inserts to suit threaded hanger rods.

2.2 PIPE HANGERS AND SUPPORTS

- .1 Hangers: Pipe sizes 15 mm to 40 mm: Adjustable wrought steel ring.
- .2 Hangers: Pipe sizes 50 mm to 100 mm and Cold Pipe Sizes 150 mm Over: Adjustable wrought steel clevis.
- .3 Design hangers so they cannot become disengaged by movements of supported pipe.

2.3 HANGER RODS

- .1 Provide steel hanger rods, threaded both ends, threaded one end, or continuous threaded.

2.4 FLASHING

- .1 Steel Flashing: 0.55 mm galvanized steel.

2.5 SLEEVES

- .1 Round Ducts: Form sleeves with galvanized steel.

2.6 FINISHES ON HANGER RODS, HANGERS, AND SUPPORTS

- .1 All steel hanger rods, hangers and supports to be galvanized or factory primed with alkyd red oxide primer to CAN/CGSB-1.40-97.

PART 3 EXECUTION

3.1 INSERTS

- .1 Use inserts for suspending hangers from reinforced concrete.
- .2 Set inserts in position in advance of concrete work. Provide reinforcement rod in concrete as required.
- .3 Where concrete slabs form finished ceiling, finish inserts flush with slab surface.

3.2 PIPE HANGERS AND SUPPORTS

- .1 Support horizontal steel and copper piping as follows:

Nominal Pipe Size	Distance Between Supports	Hanger Rod Diameter
15 mm	1.8 m	10 mm
20 mm to 40 mm	1.8 m	10 mm
50 mm & 65 mm	3.0 m	10 mm
80 mm & 100 mm	3.6 m	16 mm
150 mm to 300 mm	4.3 m	22 mm
350 mm to 450 mm	6.1 m	25 mm

- .2 Install hangers to provide minimum 12 mm clear space between finished covering and adjacent work.
- .3 Place a hanger within 300 mm of each horizontal elbow.
- .4 Use hangers that are vertically adjustable 40 mm minimum after piping is erected.
- .5 Where practical, support riser piping independently of connected horizontal piping.

3.3 SLEEVES

- .1 Set sleeves in position in advance of concrete work. Provide suitable reinforcing around sleeves.

END OF SECTION