

**Part 1 General**

**1.1 RELATED REQUIREMENTS**

- .1 Mechanical Spare Parts and Maintenance Materials Section 23 05 02
- .2 Common Motor Requirements for HVAC Equipment Section 23 05 13

**1.2 PRODUCT OPTIONS AND SUBSTITUTIONS**

- .1 Refer to Division 1 for requirements pertaining to product options and substitutions.

**1.3 QUALITY ASSURANCE**

- .1 Constructed the unit in accordance with CSA C22.2 and UL 1812.
- .2 Shop manufacture and test all units.
- .3 Insulation shall comply with NFPA 90A and Alberta Building Code.
- .4 Air handling units are to be shipped to the job site in one piece, factory assembled. All equipment shall be factory tested prior to shipment.
- .5 Unit shall have 5 year warranty. Heat recovery core for lifetime warranty.

**1.4 SUBMITTALS**

- .1 Submit shop drawings as per Section 01 33 10.
- .2 Submit operating and maintenance data as per Section 23 05 02.
- .3 Submit fan curves and operating characteristics.

**Part 2 Products**

**2.1 ACCEPTABLE MANUFACTURERS AND PRODUCTS**

- .1 Venmar, Van-ee, Semco, Carrier, Engineered Air

**2.2 UNIT CONSTRUCTION**

- .1 Unit casing shall be of minimum 20 gauge galvanized sheet metal with 12 or 16 gauge galvanized frame.
- .2 Units shall be provided with hinged access panels to the following components:

- .1 Supply/exhaust fans and motors
  - .2 Filters
  - .3 Controls
  - .4 Heat recovery core
- .3 Internally insulate units with 25 mm thick, 1-1/2 lb/cu.ft. density, neoprene coated fibreglass thermal insulation. Line interior of unit with 26 gauge galvanized wall for easy cleaning.

## **2.3 FANS**

- .1 Centrifugal fans shall be rated in accordance with AMCA Standard Test Code, Bulletin 210. Fan manufacturer shall be a member of AMCA. All fans and fan assemblies shall be dynamically balanced during factory test run. Fan shafts shall be selected for stable operation at least 20% below the first critical RPM. Fan shafts shall be provided with a rust inhibiting coating.
- .2 Equip fans with sealed ball bearings.
- .3 Provide fan-motor assemblies with vibration isolators. Secure isolators to welded steel channel and connected to the structural frame of the unit. The isolators shall be neoprene-in-shear type. Hard mounted fan assemblies are not acceptable.
- .4 Motors shall be continuous duty, permanently lubricated and match to fan loads.

## **2.4 HEAT RECOVERY CORE**

- .1 Arrange the heat recovery core to allow self cleaning by two counter flow air streams.
- .2 Install the core removable cassette to allow for inspection, removal and cleaning.
- .3 Test the energy recovery effectiveness values in accordance with ASHRAE 84 and ARI standard 1060.
- .4 The core must comply with NFPA-90A and Alberta Building Code for frame spread and smoke generation.

## **2.5 FILTERS**

- .1 Provide filters on both air streams as part of unit of medium efficiency design (30% DSE).

## **Part 3 Execution**

### **3.1 AIR HANDLING SCHEDULE**

- .1 Refer to Schedule on drawing.

**END OF SECTION**