

**Part 1 General**

**1.1 SUMMARY**

- .1 Section Includes.
  - .1 Requirements and procedures for identification of devices, sensors, wiring tubing, conduit and equipment, for building Energy Monitoring and Control System (EMCS) Work and nameplates materials, colours and lettering sizes.
- .2 Related Sections.
  - .1 Section 25 05 01 - EMCS: General Requirements.

**1.2 REFERENCES**

- .1 Canadian Standards Association (CSA International).
  - .1 CSA C22.1-02, The Canadian Electrical Code, Part I (19th Edition), Safety Standard for Electrical Installations.

**1.3 DEFINITIONS**

- .1 For acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

**1.4 SYSTEM DESCRIPTION**

- .1 Language Operating Requirements: provide identification for control items in English.

**1.5 SUBMITTALS**

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures supplemented and modified by requirements of this Section.
- .2 Submit to Departmental Representative for approval samples of nameplates, identification tags and list of proposed wording.

**Part 2 Products**

**2.1 NAMEPLATES FOR PANELS**

- .1 Identify by Plastic laminate, 3 mm thick, matt white finish, core, square corners, lettering accurately aligned and engraved into core.
- .2 Sizes: 25 x 67 mm minimum.
- .3 Lettering: minimum 7 mm high, black.
- .4 Inscriptions: machine engraved to identify function.

**2.2 NAMEPLATES FOR FIELD DEVICES**

- .1 Identify by plastic encased cards attached by plastic tie.
- .2 Sizes: 50 x 100 mm minimum.
- .3 Lettering: minimum 5 mm high produced from laser printer in black.
- .4 Data to include: point name and point address.

- .5 Companion cabinet: identify interior components using plastic enclosed cards with point name and point address.

## **2.3 NAMEPLATES FOR ROOM SENSORS**

- .1 Identify by stick-on labels using point identifier.
- .2 Location: as directed by Departmental Representative.
- .3 Letter size: to suit, clearly legible.

## **2.4 WARNING SIGNS**

- .1 Equipment including motors, starters under remote automatic control: supply and install red coloured signs warning of automatic starting under control of EMCS.
- .2 Sign to read: "Caution: This equipment is under automatic remote control of EMCS" as reviewed by Departmental Representative's.

## **2.5 WIRING**

- .1 Supply and install numbered tape markings on wiring at panels, junction boxes, splitters, cabinets and outlet boxes.
- .2 Colour coding: to CSA C22.1. Use colour coded wiring in communications cables, matched throughout system.
- .3 Power wiring: identify circuit breaker panel/circuit breaker number inside each EMCS panel.

## **2.6 PNEUMATIC TUBING**

- .1 Numbered tape markings on tubing to provide uninterrupted tracing capability.

## **2.7 CONDUIT**

- .1 Colour code EMCS conduit.
- .2 Pre-paint box covers and conduit fittings.
- .3 Coding: use fluorescent orange paint and confirm colour with Departmental Representative during "Preliminary Design Review".

## **Part 3 Execution**

### **3.1 NAMEPLATES AND LABELS**

- .1 Ensure that manufacturer's nameplates, CSA labels and identification nameplates are visible and legible at all times.

### **3.2 EXISTING PANELS**

- .1 Correct existing nameplates and legends to reflect changes made during Work.

**END OF SECTION**