

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Emergency System Upgrades	
Solicitation No. - N° de l'invitation E0209-140260/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client PWGSC	Date 2013-07-16
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-9858	
File No. - N° de dossier PWU-3-36057 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-07-31	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 497-3543 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Emergency System Upgrades

JD Higinbotham
Lethbridge, Alberta

Addendum No.1

Project No. R.057698.003

The following changes to the Tender Documents are effective immediately. This addendum will form part of the contract documents.

The following questions were received during the site walk through of July 10, 2013.

Q1. Can the Generator be located closer to the point of entry? (Possibly in front of stairs)

Answer: No. Install as per Site Plan E-1

Q2. Will it be enclosed? (weather enclosure around generator)

Answer: Provide skin tight environmental enclosure as per specifications.

Q3. Include relocating of park bench and rotating the steps to scope of work.

Answer: Tender to include removal and reinstallation of park bench to within 3m of existing location. Stairs to be rotated to face west. Installation of these items to match existing quality.

Q4. Review of 55Db sound level. Seems excessively low if it causes significant increase of cost. Street level sound quite high already(70-75ish?).

Answer: Sound level not to exceed City of Lethbridge sound ordinances and in any case not louder than 75db at 1m from enclosure.

Q5. Site access restrictions

Answer: Provide 48 hours notice when needing to use Canada Post large Freight elevator. Certain times of the day are unavailable. Coordinate with local representative.

Q6. Is a copy of the Asbestos Survey available?

Answer: A copy of the Asbestos Survey is available upon request.

Q7. Who deems if the By-pass valves are usable?

Answer: Replace existing bypass assembly with new. Installation to account for new fire pump physical space requirements.

Q8. While Fire Pump is removed, what is the backup provision?

Answer: Use the new by-pass valve assembly during site removal of the old fire pump and preparation of base for the new fire pump. During switchovers provide a firewatch for the building.