

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
 Bid Receiving Public Works and Government
 Services Canada/Réception des soumissions/Travaux
 publics et Services gouvernementaux Canada
 The Cambridge Building
 3 Queen Street/3, rue Queen
 Charlottetown
 Prince Edward Island
 C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:
 darlene.reay@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
 The Cambridge Building
 3 Queen Street/3 rue, Queen
 PO Box 1268/CP 1268
 Charlottetown
 Prince Ed
 C1A 4A2

Title - Sujet Réparation de palplanches	
Solicitation No. - N° de l'invitation E0226-140713/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.061358.001	Date 2013-07-30
GETS Reference No. - N° de référence de SEAG PW-\$PWC-008-3278	
File No. - N° de dossier PWC-3-36028 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-08-07	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Reay, D (PWC)	Buyer Id - Id de l'acheteur pwc008
Telephone No. - N° de téléphone (902) 566-7518 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Le présent addenda vise à présenter les réponses suivantes aux questions posées par les soumissionnaires.

Les changements suivants aux documents d'appel d'offres entrent en vigueur immédiatement. Cet addenda fera partie des documents contractuels.

RÉPONSES AUX QUESTIONS

1. **QUESTION**

What is the name or type of SSP that is present?

RÉPONSE

Do not have any information on the existing SSP.

2. **QUESTION**

Re: Specification, Section 03 30 00, Pg. 3, Item 2.2 Mixes

Ready mix supplier advising new requirement to meet spec as opposed to mix used on all marine DPW projects to date, advise which product required?

RÉPONSE

Since the mix will be placed behind steel plate for the full height of the work, PWGSC would be willing to waive the chloride penetrability requirement of C1 exposure.

3. **QUESTION**

What is the width of the wharf before the ramp?

RÉPONSE

The wharf is 10m wide.

4. **QUESTION**

Is the wharf strong enough to support the weight of a 45 ton crane?

RÉPONSE

No.

5. **QUESTION**

If you want the outside steel plating to be continuous, where do the ladders go?
They can't lay flat against the steel plating.

RÉPONSE

The ladders are installed as per Detail 4/ m3/m3 on the outside of the new steel plate.

6. **QUESTION**

Since the ramp is closed in, seeing what condition the underneath is in, is impossible. So should our bid include enough materials to replace the whole ramp structure?

RÉPONSE

No, your bid should only include items for the headblock repairs.