



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS Á:**

**Parks Canada Agency/WNSC
Contracts/ Procurement Services
Suite 1300 – 635 8 Ave SW
Calgary, AB T2P 3M3**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same

Ce document est par la présente revise; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

**Parks Canada Agency
Western and Northern Service Centre
Suite 1300 – 635 8 Ave SW
Calgary, AB T2P 3M3**

Title-Sujet Retaining Wall Repair Km 19 TCH Banff National Park		Date 1 Aug 2013
Solicitation No. - No. de l'invitation 5P420-13-5063/B	Amendment No. – No modif. 003	
GETS Reference No. – No de reference de SEAG PW-13-00357295		
Solicitation Closes L'invitation prend fin – at – á 02:00 PM on – le 2013-08-07	Time Zone Fuseau horaire - Mountain Daylight Saving Time (MDT) / Heure avancée des Rocheuses (HAR)	
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à : E. Ryan Baker		
Telephone No. - No de téléphone (902) 426-3420	Fax No. – No de FAX: (902) 426-7012	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Telephone No. - No de telephone: Facsimile No. - N° de télécopieur:		
Name and title of person authorized to sign on behalf of the Vendor/Firm (type or print) Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)		
_____		_____
Name / Nom		Title / Titre
_____		_____
Signature		Date

This solicitation amendment number three (003) is issued to provide answers to questions from potential Bidders as follows:

Q1. Will the Owner/departamental representative be designing the temporary supports as described on the drawings?

A1. Design and construction of the temporary support (shoring) will be the responsibility of the contractor.

Q2. May the contractor choose a different method of executing the work that does not require temporary supports?

A2. The contractor may submit alternate construction method for review and approval.

Q3. Will this project require full time monitoring by the Contractor's Environmental Monitor?

A3. A full time environmental monitor is not required.

Q4. Does the Contractor's Environmental Monitor need to be a Registered Professional Biologist?

A4. There is no requirement for a registered professional biologist.

Q5. Will the sediment pond required to be constructed next to the lower access road?

A5. The ditch along the north side of Vermillion Lakes Road can be modified for use as a sediment pond.

Q6. What is the location of the water supply for the Jet Rod Equipment required to clean the existing culverts?

A6. Water is available from the PCA works yard in Banff.

Q7. Do the existing culverts that require cleaning, contain Hydro Carbons or contaminated debris in any manner that will require the debris to be removed from the Park?

A7. The material removed from the culvert can be placed in km 69 pit.

Q8. Will all lane closures with excavations within close vicinity of open lanes of traffic require a separation by CRB

A8. It is the responsibility of the contractor to develop and implement a traffic control and detour plan. Due to the high volume of traffic it is anticipated that barrier will be required for the protection of the contractor and the public when the shoulder is excavated.

All other Terms and Conditions remain unchanged