



Addendum 2

Date: August 7, 2013

Project: Building 15 Roof Replacement at the Nappan Research Farm

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Les soumissionnaires doivent s'assurer que leurs propositions soient basées sur la version la plus récente des documents de soumission publiés et prennent en considération les informations ci-dessous, incluant toute information déjà publiée lors d'amendements ou Q&Rs antérieurs.

Les propositions ne respectant pas cette exigence seront rejetées.

1-Q&A's #1, question 2, answer 2 is modified as follow:

REPLACE: (SEE ADDENDUM 1)

2- Question: Can a detail be provided for showing how the flashing is to cover the facial board?

Answer: After review and discussions with the steel roofing manufacturer, it was determined that sufficient details are provided on detail 5 of drawing A-1. A new drawing showing additional detail is not necessary and will not be provided.

BY:

2- Question: Can a detail be provided for showing how the flashing is to cover the facial board?

Answer: After review and discussions with the steel roofing manufacturer, it was determined that sufficient details are provided on detail 5 of drawing A-1. The detail can be constructed as shown on the drawing. The metal ribs would simply be cut before folding the panel over the fascia, then metal trim would be added to cover the gap. A new drawing showing additional detail is not necessary and will not be provided.

2- Q &A's #1, question 3, answer 3 is modified as follow:

REPLACE:

3- Question: Is the new steel roof to be a specific color?

Answer: Yes. AAFC is to provide as an addendum.

BY:

3- Question: Is the new steel roof to be a specific color?

Answer: The steel roofing that is to be supplied and installed a part of the project is Tradition 100 by Vicwest or approved equivalent. The AAFC colour selection is Stone Grey (QC 16071).

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED
TOUS LES TERMES ET CONDITIONS DEMEURENT INCHANGÉS**
