



Mark VanDeRee 2013-07-08



07	FOR TENDER 2	2013-06-30
06	FOR TENDER	2013-06-04
05	FINAL DESIGN COMPLETION	2013-05-31
04	99% DESIGN COMPLETION	2013-05-31
03	90% DESIGN SUBMITTAL	2013-03-31
02	66% DESIGN SUBMITTAL	2013-02-14
01	33% DESIGN SUBMITTAL	2012-12-10

revision	date
Do not scale drawings. Verify all dimensions and conditions on site and immediately notify the Departmental Representative of all discrepancies.	

	A Detail No. No. du détail
	B drawing no. - where detail required dessin no. - où detail exigé
	C drawing no. - where detailed dessin no. - où détaillé

project title
titre du projet
**HAMILTON ONTARIO
BURLINGTON CANAL
VERTICAL LIFT BRIDGE
REPLACEMENT OF CONTROLS,
DRIVES AND OVERHEAD CABLES**

drawing title
titre du dessin
**ELECTRICAL DEMOLITION PLAN
NORTH MACHINERY ROOM**

drawn by
dessiné par
J. Perez

designed by
conc par
G. Patino/B. Crouthamel

approved by
approuvé par
M. Vanderee


bid
soumission
A. Ghubril

project manager
administrateur
de projets

project date
date du projet
2013-05-31

project no.
no. du projet
R.012641.001

drawing no.
dessiné no.
E-08



- NOTES:
1. REFER TO ELECTRICAL EQUIPMENT LAYOUT PLAN SHEET E-13 FOR NEW AND TEMPORARY LOCATION.
 2. REFER TO DESIGNATED SUBSTANCE REPORT FOR HAZARDOUS MATERIAL SURVEY REPORT.
 3. ALL CONDUIT AND WIRING ASSOCIATED WITH ELECTRICAL EQUIPMENT TO BE REMOVED SHALL ALSO BE REMOVED.
 4. CONTRACTOR TO VERIFY EXISTING CABLE TRAY CONDITION THROUGHOUT FACILITY OF VARIOUS SIZES AND LENGTHS, REMOVAL OF EXISTING CABLES. CONTRACTOR TO RESTORE TO USABLE CONDITION AS NEEDED, FOLLOWING REMOVAL OF EXISTING CABLES.

DEMOLITION PLAN-NORTH MACHINERY ROOM

SCALE 1/4"=1'-0"