

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Forrest Park Thermal Upgrades	
Solicitation No. - N° de l'invitation E0209-140717/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PWGSC	Date 2013-08-12
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-9903	
File No. - N° de dossier PWU-3-36120 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-08-22	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pww201
Telephone No. - N° de téléphone (780) 497-3543 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

**Forrest Park Crown Housing Complex
Crawlspace Renovations - Phase 2
Project No. R.015993.346**

Addendum No. 1

This Addendum is raised to provide the following clarifications:

Q1: What is the project location?

A1: Forrest Park Crown Housing Complex
Lanky Court, Yellowknife, Northwest Territories

Q2: Will the dwelling units remain occupied during the Work?

A2: In accordance with specification Section 01 11 00 Summary of Work, the dwelling units will remain occupied during the entire construction period.

Q3: Clause 1.2.4 of Section 01 14 00 Work Restrictions states that the Departmental Representative will assign sanitary facilities for use by Contractor's personnel. What is the location of the sanitary facilities?

A3: Delete clause 1.2.4 of Section 01 14 00 Work Restrictions. Contractor to provide and maintain their own sanitary facilities.

Q4: Is there an electrical conduit from the crawlspace to the electrical panel in the laundry room of each dwelling unit with sufficient capacity to accommodate wiring for the new crawlspace ventilation system?

A4: The capacity of any existing electrical conduit is unknown. Bidders are to assume that the wall assembly below the electrical panel will need to be opened up to facilitate installation of the new wiring and then patched to match existing. The wall assembly is painted gypsum board attached to wood studs.

Q5: With respect to re-routing and extending roof drain leaders and drainage pipes, would it be acceptable to install nominally horizontal pipes under the cantilevered portion of the dwelling units or along the front of the buildings to ensure positive drainage away from the foundation walls?

A5: The Contractor is required to re-route and extend roof drain leaders and drainage pipes to ensure positive drainage away from the foundation walls in all locations. Installing nominally horizontal pipes under the cantilevered portion of the dwelling units or along the front of the buildings to achieve this requirement could form part of the solution.

-
- Q6: Can the existing polyethylene ground cover remain in place?
- A6: No. The existing polyethylene ground cover material and sheathing tape is to be removed. It was installed to facilitate the work of a previous phase that is now complete. Each of the crawlspaces was cleared for re-occupancy at the completion of this previous work.
- Q7: Should the horizontal fuel oil service pipes that penetrate the right foundation wall in the crawlspace of dwelling unit 1006 be extended to avoid encapsulating or otherwise contacting with spray foam the vertical fuel oil supply tubing?
- A7: Yes. Extend each of the eight horizontal fuel oil service pipes that penetrate the right foundation wall in the crawlspace of dwelling unit 1006 approximately 150 mm to accommodate the application of spray-applied polyurethane foam insulation.
- Q8: What means or methods of ventilating the crawlspaces during construction are acceptable?
- A8: Specification Section 01 51 00 Temporary Utilities and specification Section 07 21 29.03 Sprayed Insulation - Polyurethane Foam, for example, require that ventilation be established and maintained to meet specified requirements. The Contractor is required to establish and maintain ventilation systems that meet the specified requirements and that do not negatively impact the integrity of the Work.
- Q9: Could another tender phase site visit be arranged?
- A9: An additional site visit is arranged for August 16, 2013 at 1:00 pm. Interested bidders are to meet at the Forest Park Crown Housing Complex located in Lanky Court off Forrest Drive, Yellowknife, NT.

END OF ADDENDUM