

1 General

1.1 REFERENCES

- .1 American National Standards Institute/National Fire Prevention Association (ANSI/NFPA)
 - .1 ANSI/NFPA 13 , Installation of Sprinkler Systems.
 - .2 Underwriters Laboratories of Canada (ULC)

1.2 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit product data shop drawings in accordance with Submittal Procedures and in accordance with ANSI/NFPA 13, working plans and design requirements.
- .2 Submit a complete set of shop drawings and hydraulic calculations are to the Fire Protection Engineer of HRSDC for approval.

1.3 ENGINEERING DESIGN CRITERIA

- .1 Design system in accordance with ANSI/NFPA 13, using following parameters:
 - .1 Hazard:
 - .1 To suit occupancy.
 - .2 Pipe size and layout:
 - .1 Hydraulic design .
 - .2 Sprinkler head layout: to ANSI/NFPA 13 or as directed by authorities having jurisdiction .
 - .3 Revise head locations to suit new ceiling grid.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Closeout Submittals.
- .2 provide hard copy as-built drawings for each manual and one copy of AutoCad plans in version 2007 or newer.

1.5 EXTRA MATERIALS

- .1 Provide maintenance materials in accordance with Closeout Submittals.
- .2 Provide spare sprinklers and tools as required by ANSI/NFPA 13 and as specified elsewhere.

2 Products

2.1 PIPE, FITTINGS AND VALVES

- .1 Pipe:
 - .1 Ferrous: to ANSI/NFPA 13.
 - .2 Copper tube: to ANSI/NFPA 13.
 - .3 Flexible, braided, stainless steel hose: to ANSI/NFPA 13 and ULC listed for fire protection service.
- .2 Fittings and joints to ANSI/NFPA 13:
 - .1 Ferrous: screwed, welded, flanged or roll grooved.
 - .2 Copper tube: screwed, soldered, brazed.
- .3 Valves:
 - .1 ULC listed for fire protection service.
 - .2 Up to NPS 2: bronze, screwed ends, OS & Y; gate.
 - .3 NPS 2 1/2 and over: cast iron, flanged or roll grooved ends, indicating butterfly valve.
 - .4 Swing check valves.
 - .5 Ball drip.
- .4 Pipe hangers:
 - .1 ULC listed for fire protection services.
- .5 Produce pipe and fittings from minimum 50% recycled materials.

2.2 SPRINKLER HEADS

- .1 General: to ANSI/NFPA 13 and ULC listed for fire services.
- .2 Refer to schedule on drawings for sprinkler head types.

2.3 SUPERVISORY SWITCHES

- .1 General: to ANSI/NFPA 13 and ULC listed for fire service.
- .2 Valves:
 - .1 Mechanically attached to valve body, with normally open and normally closed contacts and supervisory capability.
- .3 Flow switch type:
 - .1 With normally open and normally closed contacts and supervisory capability.
- .4 Pressure alarm switch:
 - .1 With normally open and normally closed contacts and supervisory capability.

2.4 FIRE DEPARTMENT CONNECTION

- .1 To ANSI/NFPA 13 and ULC S543 listed, siamese type, location as indicated. Thread specifications to be compatible with local fire department.
- .2 Polished bronze. Threaded metal caps and chains.

2.5 SIGNS

- .1 Signs for control drain and test valves: to ANSI/NFPA 13.

3 Execution

3.1 INSTALLATION

- .1 Install, inspect and test to acceptance in accordance with ANSI/NFPA 13 and the approval of the Authority Having Jurisdiction.
- .2 Relocate heads / provide new where required to suit architectural, mechanical and electrical revisions. Offset piping where required to provide room for new ductwork. Coordinate exact requirements on site.
- .3 Adjust pipe routing to suit structure, ceilings & partitions. Coordinate sprinkler head locations with final partition layouts, ceiling arrangement and diffuser & light locations.
- .4 Provide and install all main drains, auxiliary drains for test connections, flow stations etc., and carry to sanitary system, suitable floor drain or building exterior.
- .5 Protect sprinkler heads against mechanical injury with chrome metal guards where necessary.
- .6 Provide chrome plated escutcheons to all piping through walls, floors, ceilings in finished areas.
- .7 Revise head locations to suit new ceiling grid. Align heads in rows, and center within each tile.

3.2 ELECTRICAL GENERAL

- .1 Do complete installation in accordance with requirements of:
 - .1 Electrical Specifications and this specification.
 - .2 CSA 22.1 Canadian Electrical Code.
 - .3 ANSI/NFPA 70.
 - .4 ANSI C2.
- .2 Provide 120V power wiring for components and accessories from spare breakers in 120V emergency power panels.
- .3 Fully enclose or properly guard electrical wiring, terminal blocks, high voltage above 70 V contacts and mark to prevent accidental injury.
- .4 Do underground installation to CAN/CSA C22.3No.7, except where otherwise specified.
- .5 Conform to manufacturer's recommendations for storage, handling and installation.
- .6 Check factory connections and joints. Tighten where necessary to ensure continuity.
- .7 Install electrical equipment between 1000 and 2000 mm above finished floor wherever possible and adjacent to related equipment.
- .8 Protect exposed live equipment such as panel, mains, outlet wiring during construction for personnel safety.
- .9 Shield and mark live parts "LIVE 120 VOLTS" or other appropriate voltage.
- .10 Install conduits, and sleeves prior to pouring of concrete.

- .11 Holes through exterior wall and roofs: flash and make weatherproof.
- .12 Make necessary arrangements for cutting of chases, drilling holes and other structural work required to install electrical conduit, cable, pull boxes, outlet boxes.
- .13 Install cables, conduits and fittings which are to be embedded or plastered over, neatly and closely to building structure to minimize furring.

End of Section