

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

[illegible]

1	ISSUED FOR TENDER	30-07-13
ions	description	date

A detail no.
n° du détail

B location drawing no.
sur dessin n°

C drawing no.
dessin n°

ect	projet
-----	--------

ESPLANADE LAURIER COOLING TOWER REPLACEMENT

40 O'CONNOR ST., OTTAWA (ONTARIO)

ving dessin


STRUCTURE NORTH COOLING TOWER DEMOLITION, PLANS AND DETAILS

Conçu par	P.-L. SÉGUIN	2012/01/23	(yyyy/mm/dd)
Dessiné par	F. DUBOIS	2012/01/23	(yyyy/mm/dd)
Examiné par	F. LANDRY	2012/01/23	(yyyy/mm/dd)
Approuvé par	F. LANDRY	2012/01/23	(yyyy/mm/dd)
Soumission	DAVID RUETER		


Project Manager	Administrateur de projets
Project no.	No. du projet

R.049987.003


ving no. No. du dessin
S01




1
S01 PARTIAL PLAN LEVEL 22ND - NORTH - NEW
SCALE 1:100



2 PARTIAL ROOF PLAN - NORTH - DEMOLITION
S01 SCALE 1:100



3 PARTIAL PLAN LEVEL 22ND - NORTH - DEMOLITION
S01 SCALE 1:100



4 DETAIL - CONCRETE PIER
S01 SCALE 1:20

DESIGN LOADS

LIVE LOAD: 9.6 kPa

DEAD LOAD: 5.7 kPa + CONCRETE BEAMS

NOTE : SEISMIC RESTRAINT FOR ALL MECHANICAL EQUIPMENT NOT NOTED IS THE RESPONSABILITY OF THE CONTRACTORS ENGINEER TO PROVIDE

