

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

.1 Section Includes:  
1. Contactors.

1.3 RELATED DOCUMENTS

.1 Submit product data in accordance with Section 26 05 01 - Common Work Results - Electrical.

PART 2 - PRODUCTS

2.1 CONTACTORS

- .1 Contactors: to EEMAC No.1CS-1970.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .3 Fused switch combination contactor as indicated.
- .4 Complete with 2 normally open and 2 normally closed auxiliary contacts unless indicated otherwise.
- .5 Mount in CSA Enclosure 1 unless otherwise indicated.
- .6 Include following options in cover:  
1. Red indicating lamp.  
2. Hand-Off-Auto selector switch.
- .7 Control transformer.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Size 4 nameplate indicating name of load controlled as indicated.

---

Project Number 720198  
Wharf Electrical Upgrades  
Greenspond, NL

---

CONTACTORS

Section 26 29 01  
Page 2

2013-07-25

---

PART 3 - EXECUTION

3.1 INSTALLATION

.1 Install contactors and connect auxiliary control devices as indicated.