

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property  
Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Regional Manager/Real Property Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

<b>Title - Sujet</b> DFO fit-up construction	
<b>Solicitation No. - N° de l'invitation</b> EQ754-140500/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> R.03337.001	<b>Date</b> 2013-08-19
<b>GETS Reference No. - N° de référence de SEAG</b>	
<b>File No. - N° de dossier</b> PWL-3-36024 (039)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-08-22</b>	
<b>Time Zone</b> Fuseau horaire Eastern Daylight Saving Time EDT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Hassell, Bob	<b>Buyer Id - Id de l'acheteur</b> pwl039
<b>Telephone No. - N° de téléphone</b> (416) 590-8270 ( )	<b>FAX No. - N° de FAX</b> (416) 512-5862
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO Lakeshore Rd Burlington, ON X1X 1X1	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> (type or print) <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

## QUESTIONS AND ANSWERS

**Question 15**

The ceiling heights on the left of the drawings do not match to the ones on top of the drawings

**Answer 15**

See Drawing - Attachment 017

**Answer 16**

Detailed drawings provided.

**Question 24**

There is also New VCT: "Vinyl Plank" around room R231A (Drawing A-04), do we have to install it on top of the existing VCT?

**Answer 24**

Yes, we want to leave VCT undisturbed. the Base Building Carpet is specified on the Floor Finishes Plan and that the Base Building Partitioning is specified on the Partition Plan. The specification is very generic and does not reflect the Environment Canada Building Standards.

**Question 25**

Who's the manufacturer for existing demountable portions?

**Answer 25**

Existing demountable partitions are by PC350. They do not make them anymore but are still in business. CCIW uses prefinished vinyl board made by Envirowall. It is noted on the partition plan legend.

**Question 26**

I got requests from the trades saying that the drawings are letter size, can't be scaled, if there another set could be posted?

**Answer 26**

This has been corrected – last email

**Question 27**

Is there any work shall be done after hours?

**Answer 27**

schedule is to be maintained. Any work that will disrupt adjacent employees may be subject to after hours work, or minimize noise pollution if possible.