

**PART 1                      GENERAL**

**1.1                      RELATED SECTIONS**

- .1                      Section 01 33 00 - Submittal Procedures.
- .2                      Section 26 05 00 – Common Work Results - Electrical.

**PART 2                      PRODUCTS**

**2.1                      DISCONNECT SWITCHES**

- .1                      Fusible and non-fusible, disconnect switch in CSA Enclosure type 1, size as indicated.
- .2                      Provision for padlocking in on-off switch position by three locks.
- .3                      Mechanically interlocked door to prevent opening when handle in ON position.
- .4                      Fuses: size as indicated, to Section 26 28 13.01 - Fuses - Low Voltage.
- .5                      Fuseholders: suitable without adaptors, for type and size of fuse indicated.
- .6                      Quick-make, quick-break action.
- .7                      ON-OFF switch position indication on switch enclosure cover.

**2.2                      EQUIPMENT IDENTIFICATION**

- .1                      Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2                      Indicate name of load controlled on size 4 nameplate.

**PART 3                      EXECUTION**

**3.1                      INSTALLATION**

- .1                      Install disconnect switches complete with fuses as indicated.

**END OF SECTION**