

**PART 1                      GENERAL**

**1.1                      GENERAL**

- .1                      This section describes the extent of services to be provided for wiring of equipment supplied by others.
- .2                      Within the context of this section, Others means:
  - .1                      Other divisions of this specification (i.e.: Division 25 – Integrated Automation).
  - .2                      The Departmental Representative, as defined in the Contract.
  - .3                      Other contractors supplying and installing equipment to the contract.

**1.2                      EXTENT OF SERVICES PROVIDED**

- .1                      The work of this contract is to include all power and control wiring of equipment which is provided by Division 26.
- .2                      All power and control wiring above 50 V for equipment will be the responsibility of this contractor.
- .3                      All control wiring 50 V and less for will be the responsibility of this contractor.
- .4                      All power and control wiring associated with equipment supplied by Division 01 will be the responsibility of this contractor. Coordinate with general contractor for exact requirements.
- .5                      Final connection of all wiring to equipment provided by others will be by division 26. Coordinate with the provider for connection instructions.

**1.3                      RESPONSIBILITY OF DIVISION 26**

- .1                      It is the responsibility of the Division 26 subcontractor to verify final requirements for wiring of all equipment noted. Verification of wiring requirements to include:
  - .1                      Confirmation of electrical characteristics.
  - .2                      Location of connection point.
  - .3                      Method of connection (i.e. direct or plug-in etc.)
- .2                      Obtain and become familiar with shop drawings for all relevant equipment.
- .3                      No claim for extra will be entertained for wiring equipment which has been indicated, or changes to installed wiring where installation proceeded prior to verification of electrical requirements.

**PART 2                    PRODUCTS (NOT APPLICABLE)**

**PART 3                    EXECUTION (NOT APPLICABLE)**

**END OF SECTION**