


APPROX. NORTH









NOTES:

1. ALL EXISTING SPRINKLER HEADS SHALL BE REPLACED WITH NEW QUICK RESPONSE SPRINKLER HEADS AND BE CONNECTED TO EXISTING SPRINKLER PIPING. REFER TO THE FOLLOWING NOTES REGARDING HEADS WHOSE EXISTING LOCATION INTERFERES WITH THE NEW STRUCTURAL OR MECHANICAL EQUIPMENT.
2. EXISTING SPRINKLER HEAD TO BE REMOVED, CUT/CAP SPRINKLER PIPING AS REQUIRED.
3. NEW SPRINKLER HEAD LOCATION C/N NEW SPRINKLER PIPING AS REQUIRED. ENSURE ALL PIPE SIZES CONFORM TO NFPA-13 STANDARD.

GENERAL NOTES

- EXISTING SPRINKLER HEADS ARE SHOWN AS CLOSE TO EXISTING LOCATION IN NEW CEILING GRID AS POSSIBLE. THE CONTRACTOR TO COORDINATE ON SITE WITH CEILING INSTALLER AND RELOCATE HEADS IN THE EVENT THAT HEADS CONFLICT WITH CEILING T-BAR GRID OR BUILDING EQUIPMENT. ENSURE SPRINKLER HEAD LOCATIONS CONFORM TO NFPA-13.
- COORDINATE ON SITE EXACT LOCATION OF NEW DUCT WORK MAINS. RELOCATE SPRINKLER HEADS OR RELOCATE SPRINKLER PIPING AS REQUIRED TO ACCOMMODATE DUCTWORK (TYPICAL).
- UNLESS OTHERWISE NOTED, ALL PIPE SIZES SHALL BE NFPA.

SYMBOL LEGEND	
MARK	DESCRIPTION
—EXP—	EXISTING FIRE PROTECTION LINE
⊕	EXISTING SPRINKLER HEAD
▽	EXISTING SIDEWALL SPRINKLER HEAD
○	NEW UPRIGHT SPRINKLER HEAD
⊙	NEW SEMI RECESS SPRINKLER HEAD
—FB—	NEW FIRE PROTECTION PIPING
—CA—	NEW CLEAN AGENT PIPING
-----RMFP-----	EXISTING FIRE PIPING TO BE REMOVED
	PULL STATION
	ABORT BUTTON (20 SECOND DELAY)
	2A – 5kg ABC EXTINGUISHER IN CABINET
	2A – 5kg ABC EXTINGUISHER ON BRACKET
	2B – 5kg CO <sub>2</sub> EXTINGUISHER ON BRACKET



PREACTION/CLEAN AGENT SYSTEM CONTROL	N.T.S.
--------------------------------------	--------