



NOTES:

1. ALL UNITS TO HAVE DISCONNECT AT UNIT. OUTDOOR UNITS TO HAVE WEATHERPROOF ENCLOSURE
2. ALL FEEDERS TO HAVE GROUND CONDUCTORS
3. MCC MODULE
4. DISCONNECT EXISTING BOILER & RECONNECT NEW BOILER USING EXISTING FEED.
5. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH MECHANICAL CONTRACTOR TO INTERCONNECT ALL INTERNAL MOTORS FOR UNIT
6. COMBINATION MAGNETIC STARTERS
7. WIRE THROUGH MECHANICAL CONTROLS

**** REUSE EXISTING CIRCUITS, REPLACE FEEDS AND BREAKERS**

</