



- NOTES:**
- CONTRACTOR TO COORDINATE WITH ARCHITECTURAL DWGS AND VERIFY THE ACCURACY OF DIFFUSER SCHEDULE TO ENSURE ALL FIRE RATED WALL PENETRATIONS ARE ACCOUNTED FOR BY COMBINATION VOLUME CONTROLLER / FIRE DAMPER TYPE DIFFUSERS, GRILLES, AND REGISTERS. EXAMPLE, EH PRICE "VCS4" MODEL VOLUME CONTROLLER / FIRE DAMPERS. SEE PENETRATION DETAIL - DWG M5.

| revisions | date |
|--|---------------------------------|
| Client | Client |
| CORRECTIONAL SERVICE CANADA | |
| project title | titre du projet |
| COMMUNITY CORRECTIONAL CENTRE | |
| 1045 MAIN STREET WINNIPEG, MANITOBA | |
| approved by | approuve par |
| designed by | concu par |
| drawn by | dessine par |
| reviewed by | |
| PWC Project Manager | Administrateur de Projets TPC |
| PWC A&E Resources | Gestionnaire Ressources A&G TPC |
| Client | Client |
| drawing title | titre du dessin |
| MECHANICAL | |
| BASEMENT FLOOR PLAN, MAIN FLOOR PLAN, SECOND FLOOR PLAN, HVAC | |
| scale | project no. |
| AS NOTED | 781438 |
| date | CAD no. |
| JUNE, 1993 | A097 |
| sheet | feuille |
| M3 | of 6 |

