

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving - PWGSC / Réception des soumissions -**  
**TPSGC**  
**11 Laurier St./11 rue Laurier**  
**Place du Portage, Phase III**  
**Core 0A1 / Noyau 0A1**  
**Gatineau, Québec K1A 0S5**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**  
This document contains a security requirement.

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Construction Services Division/Division des services de  
construction  
11 Laurier St./11 Rue Laurier  
3C2, Place du Portage  
Phase III  
Gatineau, Québec K1A 0S5

<b>Title - Sujet</b> COOLING TOWERS REPLACEMENT/ REMPLAC		
<b>Solicitation No. - N° de l'invitation</b> EP119-132998/A		<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> 20132998		<b>Date</b> 2013-08-28
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-349-63295		
<b>File No. - N° de dossier</b> fg349.EP119-132998	<b>CCC No./N° CCC - FMS No./N° VME</b>	
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-09-05</b>		<b>Time Zone</b> <b>Fuseau horaire</b> Eastern Standard Time EST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Enquiries to: - Adresser toutes questions à:</b> D'aoust, Jacques		<b>Buyer Id - Id de l'acheteur</b> fg349
<b>Telephone No. - N° de téléphone</b> (819) 956-0616 ( )		<b>FAX No. - N° de FAX</b> (819) 956-8335
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Esplanade Laurier Building 300 Laurier Street Ottawa, Ontario		

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EP119-132998/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fg349

Client Ref. No. - N° de réf. du client

20132998

File No. - N° du dossier

fg349EP119-132998

CCC No./N° CCC - FMS No/ N° VME

---

This amendment is raised to incorporate the attached Addendum 1 to the solicitation document. This Addendum will form part of the resulting contract.

All other terms and conditions remain unchanged.

**ADDENDUM No. 01**

**Project Number: R.049987.003**

**The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents**

**SPECIFICATIONS**

**1 Section 02 41 13 – Selective Site Demolition**

.1 Add new item 6 to article 3.5.2 - Removals from Site as follows:

3.5 - Sequence of Operations:

.2 Removals from Site:

.6 Waste bin (2 maximum) are allowed to be placed on the roof. The bins would have to be located in specific areas (over columns and beams) and load limitation depending on the bin model and location would have to be considered. It will be the contractor's responsibility to have the roof structure analyzed to be able to use containers.

**2 Section 23 05 05 – Installation of Pipework**

.1 Add new article 3.11 as follows:

3.11 New Pipes Treatment:

.1 After manufacturing of individual steel fittings and pipe lengths, they shall be pickled by immersion in a tank containing an ambient nitric hydrofluoric acid solution made up from 'Oakite' Deoxidizer, or equal, and monitored to generally maintain a concentration of 25% or higher solution by volume of water. The duration of immersion shall be 15 to 20 minutes and supplemented by manually scrubbing or brushing with non-metallic pads or stainless steel wire brushes. The acid treatment shall be followed by immersion in a rinse water tank, followed by a spray rinse. The steel products shall then be allowed to air dry to achieve passivity.

.2 All fabricated piping shall have openings plugged and flanges secured for storage and/or transport after fabrication. All fabricated piping shall be piece marked with identifying numbers or codes, which correspond to the contractor's layout and installation drawings. The marks will be located on the spools at opposite ends and 180 degrees apart.

**3 Section 23 65 10 – Condensers Coolers and Cooling Towers**

.1 Delete article 2.1 entirely.

.2 Add article 2.1 as follows:

2.1 General Requirements:

- .1 Install as shown on the plans modular Cooling Tower. Preliminary equipment information shall be obtained by Contractor by research of industry data for Modular Cooling Tower by Tower Tech model TTXL 061950.
- .2 Cooling Tower is pre-purchased and paid by the Departmental Representative.