

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 56 19 - Roadway Lighting.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA C22.1-12, Canadian Electrical Code, Part 1 (22nd Edition), Safety Standard for Electrical Installations.
 - .2 CAN/CSA C22.3 No. 7-10, Underground Systems.
 - .3 CAN/CSA-C22.3 No. 1-10, Overhead Systems.
 - .4 CAN3-C235-83 (R2010), Preferred Voltage Levels for AC Systems, 0 to 50 000 V
- .2 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
 - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

1.3 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

1.4 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Use label for both languages.

1.5 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS in accordance with Section 01 35 29.06 - Health and Safety Requirements.
- .3 Submit for review single line electrical diagrams and locate as indicated.
- .4 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Ontario, Canada.
 - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.

- .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
- .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
- .5 Submit 5 copies of 600 x 600 mm minimum size drawings and product data to authority having jurisdiction.
- .6 If changes are required, notify Departmental Representative of these changes before they are made.
- .5 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Provide CSA certified material.
 - .2 Where CSA certified material is not available, submit such material to inspection authorities for approval before delivery to site.
 - .3 Submit test results of installed electrical systems and instrumentation.
 - .4 Permits and fees: in accordance with General Conditions of contract.
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - EXECUTION.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.

1.6 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians.
- .3 Site Meetings:
 - .1 In accordance with Section 01 32 16.07 - Construction Progress Schedule - Bar (GANTT) Chart.
- .4 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.7 DELIVERY, STORAGE AND HANDLING

- .1 Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.
- .2 Construction/Demolition Waste Management and Disposal: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.8 SYSTEM STARTUP

- .1 Instruct Departmental Representative in operation, care and maintenance of systems, system equipment and components.

1.9 OPERATING INSTRUCTIONS

- .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
- .2 Operating instructions to include following:

- .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
- .2 Safety precautions.
- .3 Procedures to be followed in event of equipment failure.
- .4 Other items of instruction as recommended by manufacturer of each system or item of equipment.
- .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
- .4 Post instructions where directed.
- .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
- .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

Part 2 Products

2.1 MATERIALS AND EQUIPMENT

- .1 Provide material in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material to be CSA certified. Where CSA certified material is not available, obtain special approval from inspection authorities before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.

2.2 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of authority having jurisdiction and Departmental Representative.

2.3 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

2.4 EQUIPMENT IDENTIFICATION

- .1 Labels: embossed plastic labels with 6 mm high letters unless specified otherwise.
- .2 Wording on labels to be approved by Departmental Representative prior to manufacture.
- .3 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .4 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .5 Terminal cabinets and pull boxes: indicate system and voltage.

2.5 WIRING IDENTIFICATION

- .1 Identify wiring with permanent indelible identifying markings, numbered, on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.

- .3 Colour coding: to CAN/CSA C22.1.
- .4 Use colour coded wires in communication cables, matched throughout system.

2.6 CONDUIT AND CABLE IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other Communication Systems	Green	Blue
Fire Alarm	Red	
Emergency Voice	Red	Blue
Other Security Systems	Red	Yellow

Part 3 Execution

3.1 INSTALLATION

- .1 Do complete installation in accordance with CAN/CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CAN/CSA C22.3 except where specified otherwise.

3.2 NAMEPLATES AND LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.3 CONDUIT AND CABLE INSTALLATION

- .1 Install conduit and sleeves prior to pouring of concrete.
 - .1 Sleeves through concrete: plastic, sized for free passage of conduit, and protruding 50 mm.

3.4 CO-ORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

3.5 FIELD QUALITY CONTROL

- .1 Load Balance:

- .1 Measure phase current to panel boards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
- .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
- .3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panel boards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests in accordance with Section 01 45 00 - Quality Control.
 - .1 Power distribution system including phasing, voltage, grounding and load balancing.
 - .2 Circuits originating from branch distribution panels.
 - .3 Lighting and its control.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

3.6 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 03 10 00 - Concrete Forming and Accessories.
- .2 Section 03 20 00 - Concrete Reinforcing.
- .3 Section 03 30 00 - Cast-in-Place Concrete.
- .4 Section 26 05 00 - Common Work Results - Electrical.
- .5 Section 31 23 33.01 - Excavating, Trenching and Backfilling.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA A14-07 (R2012), Concrete Poles.
 - .2 CAN/CSA C22.2 No.206-13, Lighting Poles.
 - .3 CAN/CSA C22.2 No.211.1-06 (R2011), Rigid Types EB1 and DB2/ES2 PVC Conduit.
 - .4 CAN/CSA-O15-05 (R2009), Wood Utility Poles and Reinforcing Stubs.
 - .5 CAN/CSA O80 Series-08, Wood Preservation.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit written request to access electrical box to Departmental Representative at least 1 week before start of electrical work.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.
- .6 Do not dispose of preservative treated wood through incineration.
- .7 Do not dispose of preservative treated wood with other materials destined for recycling or reuse.
- .8 Dispose of treated wood, end pieces, wood scraps and sawdust at sanitary landfill approved by Departmental Representative.
- .9 Dispose of unused wood preservative material at official hazardous material collections site approved by Departmental Representative.

- .10 Do not dispose of unused preservative material into sewer system, into streams, lakes, onto ground or in any other location where they will pose health or environmental hazard.
- .11 Divert unused concrete materials from landfill to local facility approved by Departmental Representative.

Part 2 Products

2.1 STEEL POLES

- .1 Remove existing steel poles and fixtures before demolition of barriers and store in secure location. Reuse after construction of new barriers.

2.2 CONDUIT

- .1 Conduit: and fittings. to CAN/CSA C22.1 No.211.1.
- .2 Colour: grey.
- .3 Use PVC with ultraviolet inhibitors or shielding for conduit exposed to sun for 150 mm length or greater.
- .4 Terminators: bell end.

2.3 CONCRETE-ENCASED DUCTS

- .1 Concrete: 20 MPa mix in accordance with Section 03 30 00 - Cast-in-Place Concrete.
- .2 Duct spacers: approved by Energy Ottawa.
- .3 Base spacers: concrete, minimum 50 mm thick.

Part 3 Execution

3.1 LIGHTING DEACTIVATION

- .1 Lighting circuits are controlled by electrical box on Middle Street. Use electrical box to deactivate circuit before work.
- .2 At least one sidewalk will be open to public during the Work. Maintain lighting during night hours for sidewalk open to public.

3.2 INSTALLATION OF POLES

- .1 Install poles true and plumb, fixed to anchor bolts cast in barriers.
- .2 Check lamppost orientation, level and tilt.
- .3 Connect lamppost to lighting circuit.
- .4 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.

3.3 INSTALLATION OF CONDUIT

- .1 Install new conduit between light poles and electrical box, including buried ducts between electrical box and Middle Street, buried concrete-encased ducts below sidewalks and road, and conduit embedded in barriers along roadway.

- .2 Splices to existing conduit are only permitted at interface between new and existing barrier.
- .3 Install new conduit across Booth Street between electrical box and light pole opposite Middle Street. Conduit to cross under lanes below approach slab South of OHEPC Bridge.
- .4 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.

3.4 TRENCHING AND BACKFILLING

- .1 Excavate trenches in accordance with Section 31 23 33.01 - Excavating, Trenching and Backfilling.
- .2 Excavate trench to minimum width to allow for duct installation.
- .3 Grade trench to give duct run rise of fall of at least 2.5 mm/m toward next connection point. Do not create sags or depressions in ducts where water may accumulate.
- .4 Encase duct in concrete below road or sidewalk. Bury duct
- .5 Backfill trenches in accordance with Section 31 23 33.01 - Excavating, Trenching and Backfilling.
- .6 Backfill material: in accordance with Section 31 23 33.01 - Excavating, Trenching and Backfilling..
- .7 Compact backfill to 95% standard proctor density.

3.5 CONCRETE-ENCASED DUCTS IN TRENCHES

- .1 Minimum separation between ducts: 25 mm.
- .2 Minimum concrete cover for ducts: 76 mm on top, bottom, and sides.
- .3 Form both sides of concrete in accordance with Section 03 10 00 - Concrete Forming and Accessories.
- .4 Space duct spacers at maximum 2 500 mm and within 150 mm of couplings.
- .5 Tie together ducts at maximum 1 500 mm with No. 18 AWG steel wire.
- .6 Overlap ends of reinforcing by minimum 150 mm on base spacers and tie both ends.
- .7 Clean ducts of all extraneous matter.
- .8 Test ducts by passing through mandrel and brush of suitable diameter.
- .9 Clean and rod all ducts. Leave 8 mm polypropylene rope in each duct.
- .10 Cap ends with bell end terminators.
- .11 Provide drainage sump at low end of duct runs.

3.6 CONDUIT IN BARRIERS

- .1 Install expansion joints in conduit where conduit crosses bridge expansion joint. Provide slack in wires to accommodate movement of bridge.

END OF SECTION