

AMENDMENT # 1

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE
IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT
DOCUMENTS.

SPECIFICATIONS

GENERAL QUESTIONS

Item 1 **Q:** In the General Instructions, page 1 of 9, Item 1.2.1.3, reference is made to extending the top of the two ss beams by one metre as shown on the drawing. My drawing S1, Issued for Tender dated July 18, 2013 doesn't seem to show this detail. Please Advise.

A: Beams already extended therefore not required.

Item 2 **Q:** In the General Instructions, page 8 of 9, Item 1.24.1, reference is made to the length of all Owner supplied SS Beams as being approximately 5.5 metres long each, which would equal approx. 11,000 total length per guide location. Drawing S1 indicates a lower beam of approx. 15'-0" long spliced to an upper beam of about 23'-0" long, a total length overall of 11,516. Does this situation relate to Item 1. Above? Please clarify.

A: Bottom beams are 5.5 and top are 6.7 with extension in place.

Item 3 **Q:** In the General Instructions, page 8 of 9, Item 1.24.2, reference is made to 10 single wall mounting brackets pre-purchased by the Owner. Drawing S1 indicates that 12 brackets are required. Please advise whether 2 additional brackets will be supplied by Owner, or required to be provided by Bidder.

A: There are 12 brackets per beam all supplied, contractor does not have to supply any.

Item 4 **Q:** Under Spec section SS Beams Installation, Section 05 53 00, Item 2.1.4, steel nuts and washers are spec'ed to ASTM A563. On Drwg S1, Note Item 3.D indicates that they conform to ASTM A325.

A: All washers and nuts are to be 316 stainless steel.

Item 5

Q: The Pump Collar Detail #3 on Dwg. S1 indicates a Neoprene Liner. Is there a Spec. for this Item?

A: Just a compressable neoprene strip between the steel and the pump

Item 6

Q: Under Spec. Item Metal Fabrication, Section 05 50 00, Page 1 of 2, Item 1.5.1.1: ? all costs associated with the supply and installation of Collars, Pumps, and Canada supplied hoses,? Should the Pumps be noted as Canada supplied?

A: Pumps are supplied by canada

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
