

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Building Mechanical Systems	
Solicitation No. - N° de l'invitation W0105-13E064/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2013-09-05
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3295	
File No. - N° de dossier PWB-3-36040 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-09-12	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Two (2) is raised to include the following Addendum No. Two (2).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

1. SPECIFICATION

In Annex "B" - Major Operational Inspection in the Specification (English version),
ADD the attached two pages (Page 1 and Page 2) which were left out in error.

Major Operational Inspections

- 1 Report in with appropriate personnel as designated by the Engineer.
- 2 All items covered in the minor inspection to be included in the major inspection.
- 3 **VCI VEC Controls Programable Control Unit, Honeywell Controls (Csoft-500 E/ES) and Automatic Logic, Web Control, 4.1**
 - .1 Inspecting the PCU;
 - .2 Checking the FID enclosure, FID circuit board, and input / output points;
 - .3 Checking and calibrating all external sensing devices and verify operation of all controlled outputs;
Note: point schedules for all systems will be available from the Engineer. (see 01005, Art .5)
 - .4 Checking the modems;
 - .5 Software maintenance;
 - .6 Answering user questions, and providing any additional instruction deemed necessary by the service technician or operations personnel or system manager, as required; and
 - .7 Reviewing auto schedules, setpoints, CDM's disabled or user controlled points.
- 4 **Air Handling Units:**
 - .1 Report in with appropriate personnel; and
 - .2 Review operation for problems and trends.
 - .3 **Fan and Motor:**
 - .1 Inspect fan wheel for free rotation, cracks and alignment;
 - .2 Inspect motor windings for cleanliness; and
 - .3 Check all major valves for operation or leaks.

.4 **Starters:**

- .1 Inspect wiring for secureness and damage;
 - .2 Megger motor at starter and record readings;
 - .3 Inspect switch gear, starters and contactor points;
 - .4 Inspect electrical connections for tightness and absence of moisture;
 - .5 Inspect starters for signs of wear, arcing, overheating and burns;
 - .6 Measure and record operating voltages; and
 - .7 Measure and record operating amperage.
- .5 Inspect coils for leaks - clean or dirty.
- .6 Inspect condition of dampers.
- .7 Test secureness of guards, doors, and panels.
- .8 Inspect humidifier parts.
- .9 Inspect casing for corrosion and damage.
- .10 Inspect flexible connections and ductwork for damage or leaks.
- .11 Dependent on type, clean or replace filters.

5 **Automatic temperature control systems:**

.1 **Air compressors:**

- .1 Drain tank and check traps;
- .2 Change oil and check oil pressure;
- .3 Check belt and sheaves - change as required;
- .4 Change suction filters;
- .5 Inspect unloader and check valves;
- .6 Inspect high pressure safety valves;
- .7 Analyse motor operating conditions and lubricate;
- .8 Check PE switch, starter and alternator;
- .9 Record compressor run time; and
- .10 Record oil carryover rate where applicable.

.2 **Refrigerated air dryer:**