

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 – Submittal Procedures.
- .2 Section 01 78 00 – Closeout Submittals

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)
 - .1 ANSI/NFPA 10-2002, Portable Fire Extinguishers.
- .2 Underwriters' Laboratories of Canada (ULC)
CAN/ULC-S508-M90(R1995), Rating and Fire Testing of Fire Extinguishers and Class "D" Extinguishing Media.

1.3 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 – Submittal Procedures.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 – Closeout Submittals.

PART 2 - PRODUCTS

2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labeled for 6A, 80B and C class protection. Size 4.5 kg.

2.2 EXTINGUISHER BRACKETS

- .1 Type recommended by extinguisher manufacturer.

2.3 IDENTIFICATION

- .1 Identify extinguishers in accordance with recommendations of ANSI/NFPA 10.
- .2 Attach tag or label to extinguishers, indicating month and year of installation. Provide space for service dates.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install or mount extinguishers on brackets as indicated.

End of Section