

## ADDENDUM #1

---

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE  
IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT  
DOCUMENTS.  
\*\*\*\*\*

**QUESTION:** For the concrete removal on the Rocky Barachois Bridge, would hydrodemolition be permitted to be used for the removal of the concrete deck providing all environmental requirements are met or exceeded? Hydrodemolition uses high pressure water to break down the deteriorated concrete and does not cause micro-fractures in the remaining concrete as happens with jackhammers. Additionally, the reinforcing steel is cleaned without any impact or damage.

**ANSWER:**

Hydrodemolition is an acceptable method for concrete removal providing all contract conditions are met.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.

**All other terms & conditions remain unchanged.**

\*\*\*\*\*