



## **QUESTIONS & ANSWERS #3**

**THE FOLLOWING QUESTIONS HAVE BEEN ASKED BY POTENTIAL BIDDERS. FOR YOUR INFORMATION, BELOW ARE THE QUESTIONS AND ANSWERS:**

**Q #1)** On page 20 of 32 of the Technical Specification document, you mentioned some specific part numbers for the underground piping. We want to know if those are the correct ones?

- Double-walled piping ø 40 mm (1 1/2 "): the manufacturer has C15 but you indicated C30?
- Single-walled tertiary piping ø 80 mm (3 "): you indicated AXP40?

**A # 1)** *For the double-walled piping ø 40 mm (1 1/2 "), we want you to use the OPW model # C15A (see technical data sheet attached).*

*For single-walled tertiary piping ø 80 mm (3 "), we want you to use the OPW model # AXP40 (see technical data sheet attached).*

**Q # 2)** Where should we install the new inventory management and product detection system?

**A # 2)** *In the Coquelin building, next to the existing electrical panels.*

**Q # 3)** Should we remove and temporarily store petroleum products from the existing tanks?

**A # 3)** *The fuel stored in tanks is owned by ARP GAS and they're located at 1039 Titane Street in Havre-Saint-Pierre. Therefore, ARP GAS will remove their fuel before the tanks are dismantled.  
The dismantling of all three fuel tanks at the marina should be done in accordance with paragraphs 44 and 45 of the federal regulations (SOR/2008-197).*

**Q # 4)** Do we need to provide the rigid pipe network for new probes for product detection or is it already in place?

**A # 4)** *The rigid pipe network for the new probes for product detection shall be supplied and installed.*