

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, 2nd floor  
800, rue Burrard, 2e étage  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Potable Well Water System Upgrades	
<b>Solicitation No. - N° de l'invitation</b> EZ899-140825/B	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2013-09-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-020-7086	
<b>File No. - N° de dossier</b> PWY-3-36090 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-09-23</b>	<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ly, Ronny(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy020
<b>Telephone No. - N° de téléphone</b> (604) 666-0043 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CBSA - Multiple Locations - Various, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-140825/B

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-3-36090

Buyer ID - Id de l'acheteur

pw020

CCC No./N° CCC - FMS No/ N° VME

---

Please find Addendum #1 herein.

All other terms and conditions remain unchanged.

ADDENDUM No. 1

This addendum will form part of the contract documents.

---

Question: 1

Water Softener:

- Twin tank softeners 48'000 grain capacity per tank or total for both ?
- Twin high flow is 15 gpm minimum flow with both 48,000 tanks online  
7.5 gpm minimum flow when one tank is regenerating.

Answer: 1

48'000 total for both.

---

Question: 2

- Can the control valve be constructed of "NORYL fibreglass reinforced composite?

Brass is rarely used in the industry any more for this size of unit. We have used the "Pentair Autotrol" valve for over 25yrs. It is very reliable and well constructed. Pressure tested to 300psi in the factory. It uses a camshaft to activate flapper valves. No o-rings to be damaged by abrasives.

Answer: 2

Yes

---

Question: 3

Ultra Violet Sterilizer:

- Certification Standard NSF55B is an older standard and has been replaced by NSF55A

We can not supply a 55B unit to supply 15 gpm

55B specs 40mj/cm2 lamp intensity and can be achieved by non NSF certified units

-NSF55A includes a light intensity monitor and optional solenoid shutdown of water supply.

- Can we supply a non certified unit that achieves 55B specs?

Answer: 3

No, supply to the latest standard.

Question: 4

Non disruption of water supply to replace lamps is specified. Can we install a Bypass valve to service the Lamps ?

Answer: 4

Yes

---

Question: 5

Regarding potable well water upgrades at the border crossings file # PWY-3-36090 (020) EZ899-140825/A : Your request for quotes indicate you require a new seismic floor mount stand for twin softener units. No make or model number has been supplied, or... can this be a stand with vibration mounts underneath? Also, as these units are being installed in a non earthquake zone are they really required ?

Answer: 5

The tanks are to be securely fastened to prevent tip over.

---

Question: 6

*SECURITY - At Nelway & Waneta - where commissionaire escort is required inside the building.. does the government provide the commissionaire or do we hire and pay for this service ?*

Answer: 6

The contractor hires and pays for this service.

---

Question: 7

Section 015100 #4 Contractor to supply bottled water for CBSA Staff \* the borders already have bottled water on site \* Do we need to supply additional water ?

Answer: 7

Additional bottled water not required.

---

Question: 8

*WATER SUPPLY TO BUILDING ; We plan on having a Water Tank on site complete with a jet pump to supply water when working on site, then the shut down would be kept to a minimum.*

Answer: 8

Ok.

---

Question: 9

019100 COMMISSIONING- Contractor to engage and pay for the service of a COMMISSIONING AGENT. We can do this but it is very expensive for such a small job. Suggest we have ROD ROBINSON from the KINGSGATE BORDER come to each site and check our work .. as he will have to come anyway so we can explain the operation system of the UV's and WATER SOFTENERS to him ?

Answer: 9

Contractor to engage and pay for the services of a Commissioning Agent.

---

End of Addendum No. 1