

**Part 1 General**

**1.1 RELATED SECTIONS**

- .1 Section 01 00 10 – General Instructions.
- .2 Section 25 05 01 - EMCS: General Requirements.

**1.2 DEFINITIONS**

- .1 For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

**1.3 DESIGN REQUIREMENTS**

- .1 Confirm with Departmental Representative that Design Criteria and Design Intent are still applicable.
- .2 Commissioning personnel to be fully aware of and qualified to interpret Design Criteria and Design Intent.

**1.4 SUBMITTALS**

- .1 Submittals in accordance with Section 01 00 10 – General Instructions.
- .2 Final Report: submit report to Departmental Representative.
  - .1 Include measurements, final settings and certified test results.
  - .2 Bear signature of commissioning technician and supervisor.
  - .3 Report format to be approved by Departmental Representative before commissioning is started.
  - .4 Revise "as-built" documentation, commissioning reports to reflect changes, adjustments and modifications to EMCS as set during commissioning and submit to Departmental Representative in accordance with Section 01 00 10 – General Instructions.
  - .5 Recommend additional changes and/or modifications deemed advisable in order to improve performance, environmental conditions or energy consumption.

**1.5 CLOSEOUT SUBMITTALS**

- .1 Provide documentation, O&M Manuals, and training of O&M personnel for review of Departmental Representative before interim acceptance in accordance with Section 01 00 10 – General Instructions.

**1.6 COMMISSIONING**

- .1 Do commissioning in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements.
- .2 Carry out commissioning under direction of Departmental Representative and in presence of Departmental Representative.

- .3 Inform, and obtain approval from, Departmental Representative in writing at least 14 days prior to commissioning or each test. Indicate:
  - .1 Location and part of system to be tested or commissioned.
  - .2 Testing/commissioning procedures, anticipated results.
  - .3 Names of testing/commissioning personnel.
- .4 Correct deficiencies, re-test in presence of Departmental Representative until satisfactory performance is obtained.
- .5 Acceptance of tests will not relieve Contractor from responsibility for ensuring that complete systems meet every requirement of Contract.
- .6 Load system with project software.
- .7 Perform tests as required.

#### **1.7 COMPLETION OF COMMISSIONING**

- .1 Commissioning to be considered as satisfactorily completed when objectives of commissioning have been achieved and reviewed by Departmental Representative.

#### **1.8 ISSUANCE OF FINAL CERTIFICATE OF COMPLETION**

- .1 Final Certificate of Completion will not be issued until receipt of written approval indicating successful completion of specified commissioning activities including receipt of commissioning documentation.

### **Part 2 Products**

#### **2.1 EQUIPMENT**

- .1 Provide sufficient instrumentation to verify and commission the installed system. Provide two-way radios.
- .2 Instrumentation accuracy tolerances: higher order of magnitude than equipment or system being tested.
- .3 Application: to conform to normal industry standards.

### **Part 3 Execution**

#### **3.1 PROCEDURES**

- .1 Test each system independently and then in unison with other related systems.
- .2 Commission each system using procedures prescribed by the Departmental Representative.
- .3 Commission integrated systems using procedures prescribed by Departmental Representative.
- .4 Debug system software.

- .5 Optimize operation and performance of systems by fine-tuning PID values and modifying CDLs as required.

### 3.2 FIELD QUALITY CONTROL

- .1 Pre-Installation Testing.
  - .1 General: consists of field tests of equipment just prior to installation.
  - .2 Testing may be on site or at Contractor's premises as approved by Departmental Representative.
  - .3 Configure major components to be tested in same architecture as designed system.
- .2 Completion Testing.
  - .1 General: test after installation of each part of system and after completion of mechanical and electrical hook-ups, to verify correct installation and functioning.
  - .2 Include following activities:
    - .1 Test and calibrate field hardware including stand-alone capability of each controller.
    - .2 Verify each A-to-D convertor.
    - .3 Test and calibrate each AI using calibrated digital instruments.
    - .4 Test each DI to ensure proper settings and switching contacts.
    - .5 Test each DO to ensure proper operation and lag time.
    - .6 Test each AO to ensure proper operation of controlled devices. Verify tight closure and signals.
    - .7 Test operating software.
    - .8 Debug software.
    - .9 Provide point verification list in table format including point identifier, point identifier expansion, point type and address, low and high limits and engineering units. Include space on commissioning technician and Departmental Representative. This document will be used in final start-up testing.
  - .3 Final Start-up Testing: Upon satisfactory completion of tests, perform point-by-point test of renovated system under direction of Departmental Representative and provide:
    - .1 Technical personnel capable of re-calibrating field hardware and modifying software.
    - .2 Departmental Representative's acceptance signature to be on executive and applications programs.
    - .3 Commissioning to commence during final start-up testing.
    - .4 O&M personnel may assist in commissioning procedures as part of training.
    - .5 Commissioning to be supervised by qualified supervisory personnel and Departmental Representative.
    - .6 Operate systems as long as necessary to commission entire project.
    - .7 Monitor progress and keep detailed records of activities and results.

### 3.3 ADJUSTING

- .1 Final adjusting: upon completion of commissioning as reviewed by Departmental Representative set and lock devices in final position and permanently mark settings.

**3.4**

**DEMONSTRATION**

- .1 Demonstrate to Departmental Representative operation of systems including sequence of operations in regular and emergency modes, under normal and emergency conditions, start-up, shut-down interlocks and lock-outs in accordance with Section 01 79 00 - Demonstration and Training.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED SECTIONS**

- .1      Section 01 00 10 – General Instructions.
- .2      Section 25 05 54 - EMCS: Identification.
- .3      Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation.

**1.2            ACRONYMS AND ABBREVIATIONS**

- .1      Acronyms used in EMCS:
  - .1      AI - Analog Input.
  - .2      AO - Analog Output.
  - .3      BACnet - Building Automation and Control Network.
  - .4      BC(s) - Building Controller(s).
  - .5      CDL - Control Description Logic.
  - .6      CDS - Control Design Schematic.
  - .7      COSV - Change of State or Value.
  - .8      CPU - Central Processing Unit.
  - .9      DI - Digital Input.
  - .10     DO - Digital Output.
  - .11     ECU - Equipment Control Unit.
  - .12     EMCS - Energy Monitoring and Control System.
  - .13     HVAC - Heating, Ventilation, Air Conditioning.
  - .14     IDE - Interface Device Equipment.
  - .15     I/O - Input/Output.
  - .16     LAN - Local Area Network.
  - .17     LCU - Local Control Unit.
  - .18     MCU - Master Control Unit.
  - .19     NC - Normally Closed.
  - .20     NO - Normally Open.
  - .21     OS - Operating System.
  - .22     O&M - Operation and Maintenance.
  - .23     OWS - Operator Work Station.
  - .24     PC - Personal Computer.
  - .25     PCI - Peripheral Control Interface.
  - .26     PID - Proportional, Integral and Derivative.
  - .27     RAM - Random Access Memory.
  - .28     SP - Static Pressure.
  - .29     ROM - Read Only Memory.
  - .30     TCU - Terminal Control Unit.
  - .31     USB - Universal Serial Bus.
  - .32     UPS - Uninterruptible Power Supply.

### 1.3 DEFINITIONS

- .1 Point: may be logical or physical.
  - .1 Logical points: values calculated by system such as set points, totals, counts, derived corrections and may include, but not limited to result of and statements in CDL's.
  - .2 Physical points: inputs or outputs which have hardware wired to controllers which are measuring physical properties, or providing status conditions of contacts or relays which provide interaction with related equipment (stop, start) and valve or damper actuators.
- .2 Point Name: follow the existing naming convention used at this site.
- .3 Point Object Type: points fall into following object types:
  - .1 AI (analog input).
  - .2 AO (analog output).
  - .3 DI (digital input).
  - .4 DO (digital output).
  - .5 Pulse inputs.
- .4 Symbols and engineering unit abbreviations utilized in displays: to ANSI/ISA S5.5.
  - .1 Printouts: to ANSI/IEEE 260.1.
  - .2 Refer also to Section 25 05 54- EMCS: Identification.

### 1.4 SYSTEM DESCRIPTION

- .1 Existing Siemens Apogee system.
- .2 Work covered by sections referred to above consists of expanding the existing system to include systems installed as part of this project including the following:
  - .1 Control devices as required to modify the existing system
  - .2 Add new graphics at the OWS as required for new systems.
  - .3 Field control devices for new systems.
  - .4 Software/Hardware complete with full documentation for new systems.
  - .5 Update the existing operating and maintenance manuals for new systems.
  - .6 Training of personnel as required.
  - .7 Acceptance tests, technical support during commissioning, full documentation.
  - .8 Miscellaneous work as specified in these sections and as indicated.
- .3 Design Requirements:
  - .1 Design and provide conduit and wiring linking elements for new systems.
  - .2 Supply sufficient programmable controllers of types to meet project requirements. Quantity and points contents as reviewed by Departmental Representative prior to installation.
  - .3 Location of controllers as reviewed by Departmental Representative prior to installation.
  - .4 Provide utility power to EMCS as required.
  - .5 Metric references: in accordance with CAN/CSA Z234.1.

- .4 Language Operating Requirements:
  - .1 Match existing system requirements.

## **1.5 SUBMITTALS**

- .1 Make submittals in accordance with Section 01 00 10 – General Instructions.
- .2 Quality Control:
  - .1 Provide equipment and material from manufacturer's regular production, CSA certified, manufactured to standard quoted plus additional specified requirements.
  - .2 Where CSA certified equipment is not available submit such equipment to inspection authorities for special inspection and approval before delivery to site.
  - .3 For materials whose compliance with organizational standards/codes/specifications is not regulated by organization using its own listing or label as proof of compliance, furnish certificate stating that material complies with applicable referenced standard or specification.
  - .4 Permits and fees: in accordance with general conditions of contract.

## **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.
- .2 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 00 10 – General Instructions.
  - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
  - .3 Handle and dispose of hazardous materials in accordance with all regulations.
  - .4 Label location of salvaged material's storage areas and provide barriers and security devices.
  - .5 Ensure emptied containers are sealed and stored safely.

## **Part 2 Products**

### **2.1 EQUIPMENT**

- .1 Provide new equipment and controllers as required.

## **Part 3 Execution**

### **3.1 MANUFACTURER'S RECOMMENDATIONS**

- .1 Installation: to manufacturer's recommendations.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED SECTIONS**

- .1    Section 01 00 10 – General Instructions.
- .2    Section 25 05 01 - EMCS: General Requirements.
- .3    Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.

**1.2            DEFINITIONS**

- .1    OWS - Operator Work Station.
- .2    For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

**1.3            SUBMITTALS**

- .1    Submittals in accordance with Section 01 00 10 – General Instructions, supplemented and modified by requirements of this Section.
- .2    Update existing Operations and Maintenance manuals to reflect the work of this project.

**1.4            AS-BUILTS**

- .1    Provide 1 copy of detailed shop drawings generated in Section 25 05 02 - EMCS: Submittals and Review Process and include:
  - .1    Changes to contract documents as well as addenda and contract extras.
  - .2    Changes to interface wiring.
  - .3    Listing of alarm messages.
  - .4    Panel/circuit breaker number for sources of normal power.
  - .5    Test procedures and reports: provide records of start-up procedures, test procedures, checkout tests and final commissioning reports as specified in Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.
  - .6    Basic system design and full documentation on system configuration.
- .2    Submit for final review by Departmental Representative.

**Part 2           Products**

**2.1           NOT USED**

- .1    Not Used.



**Part 3            Execution**

**3.1                NOT USED**

.1            Not Used.

**END OF SECTION**

**Part 1            General**

**1.1            RELATED SECTIONS**

- .1        Section 01 00 10 – General Instructions.
- .2        Section 25 05 01 - EMCS: General Requirements.

**1.2            REFERENCES**

- .1        Canadian Standards Association (CSA International).
  - .1        CSA C22.1-02, The Canadian Electrical Code, Part I (19th Edition), Safety Standard for Electrical Installations.

**1.3            DEFINITIONS**

- .1        For acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

**1.4            SYSTEM DESCRIPTION**

- .1        Language Operating Requirements: match existing.

**1.5            SUBMITTALS**

- .1        Submittals in accordance with Section 01 00 10 – General Instructions supplemented and modified by requirements of this Section.
- .2        Submit to Departmental Representative for review samples of nameplates, identification tags and list of proposed wording.

**Part 2           Products**

**2.1            NAMEPLATES FOR PANELS**

- .1        Match existing name plate protocol.

**2.2            NAMEPLATES FOR FIELD DEVICES**

- .1        Match existing name plate protocol.

**2.3            NAMEPLATES FOR ROOM SENSORS**

- .1        Match existing name plate protocol.

## **2.4 WARNING SIGNS**

- .1 Equipment including motors, starters under remote automatic control: supply and install orange coloured signs warning of automatic starting under control of EMCS.
- .2 Sign to read: "Caution: This equipment is under automatic remote control of EMCS" as reviewed by Departmental Representative's.

## **2.5 WIRING**

- .1 Supply and install numbered tape markings on wiring at panels, junction boxes, splitters, cabinets and outlet boxes.
- .2 Colour coding: to CSA C22.1. Use colour coded wiring in communications cables, matched throughout system.
- .3 Power wiring: identify circuit breaker panel/circuit breaker number inside each EMCS panel.

## **2.6 CONDUIT**

- .1 Colour code EMCS conduit.
- .2 Pre-paint box covers and conduit fittings.
- .3 Coding: use fluorescent orange paint and confirm colour with Departmental Representative during "Preliminary Design Review".

## **Part 3 Execution**

### **3.1 NAMEPLATES AND LABELS**

- .1 Ensure that manufacturer's nameplates, CSA labels and identification nameplates are visible and legible at all times.

**END OF SECTION**

**Part 1 General**

**1.1 RELATED SECTIONS**

- .1 Section 25 05 01 - EMCS: General Requirements.
- .2 Section 25 05 03 - EMCS: Project Record Documents.
- .3 Section 25 30 02 - EMCS: Field Control Devices.
- .4 Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation.

**1.2 REFERENCES**

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers, Inc. (ASHRAE).
  - .1 ASHRAE 2003, Applications Handbook, SI Edition.
- .2 Canadian Standards Association (CSA International).
  - .1 C22.2 No.205-M1983 (R1999), Signal Equipment.
- .3 Institute of Electrical and Electronics Engineers (IEEE).
  - .1 IEEE C37.90.1-02, Surge Withstand Capabilities (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus.
- .4 Public Works and Government Services Canada (PWGSC)/Real Property Branch/Architectural and Engineering Services.
  - .1 MD13800-September 2000, Energy Management and Control Systems (EMCS) Design Manual. English: <ftp://ftp.pwgsc.gc.ca/rps/docentre/mechanical/me214-e.pdf>

**1.3 DEFINITIONS**

- .1 Acronyms and definitions: refer to Section 25 05 01 - EMCS: General Requirements.

**1.4 SYSTEM DESCRIPTION**

- .1 Existing system. Provide additional controllers as required.
  - .1 Provide sufficient controllers to meet intents and requirements of this section.
  - .2 Controller quantity, and point contents to be approved by Departmental Representative at time of preliminary design review.
- .2 Controllers: stand-alone intelligent Control Units.
  - .1 Incorporate programmable microprocessor, non-volatile program memory, RAM, power supplies, as required to perform specified functions.
  - .2 Incorporate communication interface ports for communication to LANs to exchange information with other Controllers.
  - .3 Capable of interfacing with operator interface device.

- .4 Execute its logic and control using primary inputs and outputs connected directly to its onboard input/output field terminations or slave devices, and without need to interact with other controller. Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).
  - .1 Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).

## 1.5 DESIGN REQUIREMENTS

- .1 To include:
  - .1 Scanning of AI and DI connected inputs for detection of change of value and processing detection of alarm conditions.
  - .2 Perform On-Off digital control of connected points, including resulting required states generated through programmable logic output.
  - .3 Perform Analog control using programmable logic, (including PID) with adjustable dead bands and deviation alarms.
  - .4 Control of systems as described in sequence of operations.
- .2 Field Termination and Interface Devices:
  - .1 To: CSA C22.2 No.205.
  - .2 Electronically interface sensors and control devices to processor unit.
  - .3 Include, but not be limited to, following:
    - .1 Programmed firmware or logic circuits to meet functional and technical requirements.
    - .2 Power supplies for operation of logics devices and associated field equipment.
    - .3 Required communications equipment and wiring (if remote units).
    - .4 Leave controlled system in "fail-safe" mode in event of loss of communication with, or failure of, processor unit.
    - .5 Input Output interface to accept as minimum AI, AO, DI, DO functions as specified.
    - .6 Wiring terminations: use conveniently located screw type or spade lug terminals.
  - .4 AI interface equipment to:
    - .1 Provide for following input signal types and ranges:
      - .1 4 - 20 mA;
      - .2 0 - 10 V DC;
      - .3 100/1000 ohm RTD input;
    - .2 Meet IEEE C37.90.1 surge withstand capability.
    - .3 Have common mode signal rejection greater than 60 dB to 60 Hz.
    - .4 Where required, dropping resistors to be certified precision devices which complement accuracy of sensor and transmitter range specified.

- .5 AO interface equipment:
  - .1 Convert digital data from controller processor to acceptable analog output signals using 8 bit digital-to-analog resolution.
  - .2 Provide for following output signal types and ranges:
    - .1 4 - 20 mA.
    - .2 0 - 10 V DC.
  - .3 Meet IEEE C37.90.1 surge withstand capability.
- .6 DI interface equipment:
  - .1 Able to reliably detect contact change of sensed field contact and transmit condition to controller.
  - .2 Meet IEEE C37.90.1 surge withstand capability.
  - .3 Accept pulsed inputs up to 2 kHz.
- .7 DO interface equipment:
  - .1 Respond to controller processor output, switch respective outputs. Each DO hardware to be capable of switching up to 0.5 amps at 24 V AC.
  - .2 Switch up to 5 amps at 220 V AC using optional interface relay.
- .3 Controllers and associated hardware and software: operate in conditions of 0 degrees C to 44 degrees C and 20 % to 90 % non-condensing RH.
- .4 Provide surge and low voltage protection for interconnecting wiring connections.

## 1.6 SUBMITTALS

- .1 Make submittals in accordance with Section 01 00 10 – General Instructions and Section 25 05 02 - EMCS: Shop Drawings, Product Data and Review Process.
  - .1 Submit product data sheets for each product item proposed for this project.

## 1.7 MAINTENANCE PROCEDURES

- .1 Provide manufacturers recommended maintenance procedures for insertion in Section 25 05 03 - EMCS: Project Record Documents.

## Part 2 Products

### 2.1 TERMINAL/EQUIPMENT CONTROL UNIT (TCU/ECU)

- .1 Microprocessor capable of supporting necessary software and hardware to meet TCU/ECU functional specifications.
  - .1 TCU/ECU definition to be consistent with those defined in ASHRAE HVAC Applications Handbook section 45.

- .2 Controller to communicate directly with EMCS through EMCS LAN and provide access from EMCS OWS for setting occupied and unoccupied space temperature setpoints, flow setpoints, and associated alarm values, permit reading of sensor values, field control values (% open) and transmit alarm conditions to EMCS OWS.

## **2.2 SOFTWARE**

- .1 General.
  - .1 Existing – modify as required for this project.

## **Part 3 Execution**

### **3.1 LOCATION**

- .1 Location of Controllers to be approved by Departmental Representative.

### **3.2 INSTALLATION**

- .1 Provide necessary power from local 120 V branch circuit panel for equipment.
- .2 Install tamper locks on breakers of circuit breaker panel.

**END OF SECTION**

**Part 1 General**

**1.1 RELATED SECTIONS**

- .1 Section 07 84 00 - Firestopping.
- .2 Section 25 01 11 - EMCS: Start-Up, Verification and Commissioning.
- .3 Section 25 05 01 - EMCS: General Requirements.
- .4 Section 25 05 54 - EMCS: Identification.
- .5 Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation.
- .6 Section 26 05 00 - Common Work Results for Electrical.
- .7 Section 26 27 10 - Modular Wiring System.
- .8 Section 26 27 26 - Wiring Devices.

**1.2 REFERENCES**

- .1 American National Standards Institute (ANSI).
  - .1 ANSI C12.7-1993 (R1999), Requirements for Watthour Meter Sockets.
  - .2 ANSI/IEEE C57.13-1993, Standard Requirements for Instrument Transformers.
- .2 American Society for Testing and Materials International, (ASTM).
  - .1 ASTM B148-97(03), Standard Specification for Aluminum-Bronze Sand Castings.
- .3 National Electrical Manufacturer's Association (NEMA).
  - .1 NEMA 250-03, Enclosures for Electrical Equipment (1000 Volts Maximum).
- .4 Air Movement and Control Association, Inc. (AMCA).
  - .1 AMCA Standard 500-D-98, Laboratory Method of Testing Dampers For Rating.
- .5 Canadian Standards Association (CSA International).
  - .1 CSA-C22.1-02, Canadian Electrical Code, Part 1 (19th Edition), Safety Standard for Electrical Installations.

**1.3 DEFINITIONS**

- .1 Acronyms and Definitions: refer to Section 25 05 01 - EMCS: General Requirements.

**1.4 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submit shop drawings and manufacturer's installation instructions in accordance with Section 25 05 02 - EMCS: Submittals and Review Process.



- .2 Manufacturer's Instructions:
  - .1 Submit manufacturer's installation instructions for specified equipment and devices.

## **Part 2 Products**

### **2.1 GENERAL**

- .1 Control devices of each category to be of same type and manufacturer.
- .2 Operating conditions: 0 - 32 degrees C with 10 - 90% RH (non-condensing) unless otherwise specified.
- .3 Terminations: use standard conduit box with slot screwdriver compression connector block unless otherwise specified.
- .4 Transmitters and sensors to be unaffected by external transmitters including walkie talkies.
- .5 Account for hysteresis, relaxation time, maximum and minimum limits in applications of sensors and controls.
- .6 Devices installed in user occupied space not exceed Noise Criteria (NC) of 35. Noise generated by any device must not be detectable above space ambient conditions.

### **2.2 TEMPERATURE SENSORS**

- .1 General: except for room sensors, to be resistance or thermocouple type to following requirements:
  - .1 Thermocouples: limit to temperature range of 200 degrees C and over.
  - .2 RTD's: 100 or 1000 ohm at 0 degrees C (plus or minus 0.2 ohms) platinum element with strain minimizing construction, 3 integral anchored lead wires. Coefficient of resistivity: 0.00385 ohms/ohm degrees C.
  - .3 Sensing element: hermetically sealed.
  - .4 Stem and tip construction: copper or type 304 stainless steel.
  - .5 Time constant response: less than 3 seconds to temperature change of 10 degrees C.
  - .6 Immersion wells: NPS 3/4, stainless steel spring loaded construction, with heat transfer compound compatible with sensor.
- .2 Room temperature sensors and display wall modules.
  - .1 Temperature sensing and display wall module.
    - .1 LCD display to show space temperature and temperature setpoint.
    - .2 Buttons for occupant selection of temperature setpoint and occupied/unoccupied mode.
    - .3 Jack connection for plugging in laptop personal computer for access to zone bus.
    - .4 Integral thermistor sensing element 10,000 ohm at 24 degrees C.
    - .5 Accuracy 0.2 degrees C over range of 0 to 70 degrees.
    - .6 Stability 0.02 degrees C drift per year.
    - .7 Separate mounting base for ease of installation.

- .2 Room temperature sensors.
  - .1 Wall mounting, in slotted type covers having brushed aluminum finish, with guard.
  - .2 Element 10-50mm long RTD with ceramic tube or equivalent protection or thermistor, 10,000 ohm, accuracy of plus or minus 0.2 degrees C.
- .3 Duct temperature sensors:
  - .1 General purpose duct type: suitable for insertion into ducts at various orientations, insertion length 460 mm or as indicated.
  - .2 Averaging duct type: incorporates numerous sensors inside assembly which are averaged to provide one reading. Minimum insertion length 6000 mm. Bend probe at field installation time to 100 mm radius at point along probe without degradation of performance.
- .4 Outdoor air temperature sensors:
  - .1 Outside air type: complete with probe length 100 - 150 mm long, non-corroding shield to minimize solar and wind effects, threaded fitting for mating to 13 mm conduit, weatherproof construction in NEMA 4 enclosure.

## **2.3 TEMPERATURE TRANSMITTERS**

- .1 Requirements:
  - .1 Input circuit: to accept 3-lead, 100 or 1000 ohm at 0 degrees C, platinum resistance detector type sensors.
  - .2 Power supply: 24 V DC into load of 575 ohms. Power supply effect less than 0.01 degrees C per volt change.
  - .3 Output signal: 4 - 20 mA into 500 ohm maximum load.
  - .4 Input and output short circuit and open circuit protection.
  - .5 Output variation: less than 0.2 % of full scale for supply voltage variation of plus or minus 10 %.
  - .6 Combined non-linearity, repeatability, hysteresis effects: not to exceed plus or minus 0.5 % of full scale output.
  - .7 Maximum current to 100 or 1000 ohm RTD sensor: not to exceed 25 mA.
  - .8 Integral zero and span adjustments.
  - .9 Temperature effects: not to exceed plus or minus 1.0 % of full scale/ 50 degrees C.
  - .10 Long term output drift: not to exceed 0.25 % of full scale/ 6 months.
  - .11 Transmitter ranges: select narrowest range to suit application from following:
    - .1 Minus 50 degrees C to plus 50 degrees C, plus or minus 0.5 degrees C.
    - .2 0 to 100 degrees C, plus or minus 0.5 degrees C.
    - .3 0 to 50 degrees C, plus or minus 0.25 degrees C.
    - .4 0 to 25 degrees C, plus or minus 0.1 degrees C.
    - .5 10 to 35 degrees C, plus or minus 0.25 degrees C.

## **2.4 CONTROL DAMPERS**

- .1 Construction: blades, 152 mm wide, 1219 mm long, maximum. Modular maximum size, 1219 mm wide x 1219 mm high. Three or more sections to be operated by jack shafts.
- .2 Materials:
  - .1 Frame: 2.03 mm minimum thickness extruded aluminum. For outdoor air and exhaust air applications, frames to be insulated.

- .2 Blades: extruded aluminum. For outdoor air/exhaust air applications, blades to be internally insulated.
- .3 Bearings: maintenance free, synthetic type of material.
- .4 Linkage and shafts: aluminum, zinc and nickel plated steel.
- .5 Seals: synthetic type mechanically locked into blade edges.
  - .1 Frame seals: synthetic type, mechanically locked into frame sides.
- .3 Performance: minimum damper leakage meet or exceed AMCA Standard 500-D ratings.
  - .1 25 L/s/m<sup>2</sup> maximum allowable leakage against 1000 Pa static pressure for outdoor air and exhaust air applications.
  - .2 Temperature range: minus 40 degrees C to plus 100 degrees C.
- .4 Arrangements: dampers mixing warm and cold air to be parallel blade, mounted at right angles to each other, with blades opening to mix air stream.
- .5 Jack shafts: 25 mm diameter solid shaft, constructed of corrosion resistant metal complete with required number of pillow block bearings to support jack shaft and operate dampers throughout their range.
  - .1 Include corrosion resistant connecting hardware to accommodate connection to damper actuating device.
  - .2 Install using manufacturer's installation guidelines.
  - .3 Use same manufacturer as damper sections.

## **2.5 ELECTRONIC CONTROL DAMPER ACTUATORS**

- .1 Requirements:
  - .1 Direct mount proportional type as indicated.
  - .2 Spring return for "fail-safe" in Normally Open or Normally Closed position as indicated.
  - .3 Operator: size to control dampers against maximum pressure and dynamic closing/opening pressure, whichever is greater.
  - .4 Power requirements: 5VA maximum at 24 V AC.
  - .5 Operating range: 0 - 10 V DC or 4 - 20 mA DC.

## **2.6 CURRENT SENSING RELAYS**

- .1 Requirements:
  - .1 Suitable to detect belt loss or motor failure.
  - .2 Trip point adjustment, output status LED.
  - .3 Split core for easy mounting.
  - .4 Induced sensor power.
  - .5 Relay contacts: capable of handling 0.5 amps at 30 VAC / DC. Output to be NO solid state.
  - .6 Suitable for single or 3 phase monitoring. For 3-Phase applications: provide for discrimination between phases.
  - .7 Adjustable latch level.

## **2.7 WIRING**

- .1 In accordance with Section 26 27 10 - Modular Wiring System, 26 27 26 - Wiring Devices.

- .2 For wiring under 70 volts use FT6 rated wiring where wiring is not run in conduit. Other cases use FT4 wiring.
- .3 Wiring must be continuous without joints.
- .4 Sizes:
  - .1 Field wiring to digital device: 20AWG stranded twisted pair.
  - .2 Analog input and output: shielded #20 minimum stranded twisted pair.

### **Part 3 Execution**

#### **3.1 INSTALLATION**

- .1 Install equipment, components so that manufacturer's and CSA labels are visible and legible after commissioning is complete.
- .2 Install field control devices in accordance with manufacturers recommended methods, procedures and instructions.
- .3 Temperature transmitters, humidity transmitters, current-to-pneumatic transducers, solenoid air valves, controllers, relays: install in NEMA 1 enclosure or as required for specific applications. Provide for electrolytic isolation in cases when dissimilar metals make contact.
- .4 Support field-mounted panels, transmitters and sensors on pipe stands or channel brackets.
- .5 Fire stopping: provide space for fire stopping in accordance with Section 07 84 00 - Firestopping. Maintain fire rating integrity.
- .6 Electrical:
  - .1 Complete installation in accordance with Section 26 05 00 - Common Work Results for Electrical.
  - .2 Terminate wires with screw terminal type connectors suitable for wire size, and number of terminations.
  - .3 Install communication wiring in conduit.
    - .1 Conduit sizes to suit wiring requirements and to allow for future expansion capabilities specified for systems.
    - .2 Maximum conduits fill not to exceed 40%.
    - .3 Design drawings do not show conduit layout.
  - .4 Do not run exposed conduits in normally occupied spaces unless otherwise indicated or unless impossible to do otherwise. Departmental Representative to review before starting Work. Wiring in mechanical rooms, wiring in service rooms and exposed wiring must be in conduit.

#### **3.2 TEMPERATURE SENSORS**

- .1 Stabilize to ensure minimum field adjustments or calibrations.
- .2 Readily accessible and adaptable to each type of application to allow for quick easy replacement and servicing without special tools or skills.
- .3 Outdoor installation:
  - .1 Protect from solar radiation and wind effects by non-corroding shields.
  - .2 Install in NEMA 4 enclosures.

- .4 Duct installations:
  - .1 Do not mount in dead air space.
  - .2 Locate within sensor vibration and velocity limits. Securely mount extended surface sensor used to sense average temperature.
  - .3 Thermally isolate elements from brackets and supports to respond to air temperature only.
  - .4 Support sensor element separately from coils, filter racks.

### **3.3 IDENTIFICATION**

- .1 Identify field devices in accordance with Section 25 05 54 - EMCS: Identification.

### **3.4 TESTING AND COMMISSIONING**

- .1 Calibrate and test field devices for accuracy and performance in accordance with Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.

**END OF SECTION**

**Part 1            General**

**1.1            REFERENCES**

- .1    Public Works and Government Services Canada (PWGSC) / Real Property Branch / Architectural and Engineering Services.
- .1    MD13800-September 2000, Energy Management and Control Systems (EMCS) Design Manual. English: <ftp://ftp.pwgsc.gc.ca/rps/docentre/mechanical/me214-e.pdf>

**1.2            SEQUENCING**

- .1    Present sequencing of operations for system[s], in accordance with MD13800 - Energy Management and Control Systems (EMCS) Design Manual.
- .2    Sequencing of operations for systems as detailed below.

**1.3            ELEVATOR ROOM COOLING**

- .1    A wall mounted temperature sensor shall send a signal to start the fan coil unit in cooling mode. Report status of the room temperature and fan coil status (enabled/disabled) at the OWS.
- .2    Should the room temperature be greater than 2°C above set point and the fan coils has been commanded on, the DDC system shall disable the fan coil and send an alarm to the OWS. The DDC system shall then open the transfer duct motorised damper and start the room exhaust fan. The fan shall continue to operate until the space temperature reaches set point. Fan status to be reported at the OWS. Should the fan stop or fail to start, an alarm shall be sent to the OWS.

**Part 2            Products**

**2.1            NOT USED**

- .1    Not Used.

**Part 3            Execution**

**3.1            NOT USED**

- .1    Not Used.

**END OF SECTION**