

Canada

Robertson Martin  
Architects


216 Perth Ave.  
Ottawa, ON K1S1X2  
Phone: 613-567-1381  
Fax: 613-567-9482  
Email: mail@robertsonmartin.com

RMA



Smith + Andersen

1600 Carling Avenue, Suite 530 Ottawa Ontario K1Z 1G3  
613 230 1186 / 613 230 2598 smithandanderson.com



KEY PLAN  
PLAN-REPÈRE

Contractor to verify all dimensions  
& conditions on site and immediately  
notify the engineer of all discrepancies.

revisions	description	date
5	ISSUED FOR TENDER	APR. 04 2013
4	ISSUED FOR 100% SUBMISSION	MAR. 01 2013
3	ISSUED FOR 99% SUBMISSION	JAN. 31 2013
2	ISSUED FOR 66% SUBMISSION	OCT. 02 2012
1	ISSUED FOR 33% SUBMISSION	AUG. 27 2012

revisions	description	date
A	A detail no. no. du detail	A
B	B location drawing no. sur dessin no.	B
C	C drawing no. dessin no.	C

project

**PUBLIC ARCHIVES  
NATIONAL LIBRARY  
ELEVATOR MODERNIZATION**

395 WELLINGTON STREET

drawing

**GROUND FLOOR  
ELECTRICAL LAYOUT**

Designed By	T.HUGHES	Conçu par
Date	AUGUST 2012	(yyyy/mm/dd)
Drawn By	T.HUGHES	Dessiné par
Date	AUGUST 2012	(yyyy/mm/dd)
Reviewed By	A.DROUIN	Examiné par
Date	AUGUST 2012	(yyyy/mm/dd)
Approved By	A.DROUIN	Approuvé par
Date	AUGUST 2012	(yyyy/mm/dd)
Tender		Soumission


MARC SAUCIER  
Project Manager  
Administrateur de projets

Project no.

R042454.002

Drawing no.

E100



1 GROUND FLOOR PLAN  
1:200

DRAWING NOTES:

- (N-1) PROVIDE ELEVATOR COMMUNICATIONS INFRASTRUCTURE FROM SECURITY OFFICE ON GROUND FLOOR TO EACH NEW ELEVATOR CONTROLLER IN EACH OF FOUR ELEVATOR MACHINE ROOMS. PROVIDE 1 DEDICATED 53mm CONDUIT TO EACH OF THE FOUR ELEVATOR MACHINE ROOMS.
- (N-2) PROVIDE SECURITY COMMUNICATIONS INFRASTRUCTURE FROM SECURITY OFFICE ON GROUND FLOOR TO ELEVATOR #2 MACHINE ROOM ON THE NINTH FLOOR MEZZANINE LEVEL AND ELEVATOR #4&5 MACHINE ROOM ON THE EIGHTH FLOOR. PROVIDE 1 DEDICATED 53mm CONDUIT TO EACH OF THE TWO ELEVATOR MACHINE ROOMS.

