

PART 1 - GENERAL

1.1 REFERENCES

- .1 CSA International
 - .1 CSA B111-1974(R2003), Wire Nails, Spikes and Staples.
 - .2 CSA O121-08, Douglas Fir Plywood.
 - .3 CSA O141-05(R2009), Softwood Lumber.
 - .4 CSA O151-09, Canadian Softwood Plywood.
 - .5 CAN/CSA O80 -08, Wood Preservation
 - .6 CAN/CSA-O325.0-07, Construction Sheathing.
 - .7 CAN/CSA-Z809-08, Sustainable Forest Management.
- .2 Green Seal Environmental Standards (GS)
 - .1 GS-11-11, Paints and Coatings.
- .3 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2010.

1.2 QUALITY ASSURANCE

- .1 Lumber identification: by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood identification: by grade mark in accordance with applicable CSA standards.
- .3 Plywood, OSB and wood based composite panel construction sheathing identification: by grademark in accordance with applicable CSA standards.
- .4 Sustainable Standards Certification:

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labeled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect wood from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Packaging Waste Management: remove for reuse and return pallets, crates, padding, banding, and packaging materials as specified in Construction Waste Management Plan Waste Reduction Workplan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Lumber: unless specified otherwise, softwood, S4S, moisture content 19% or less in accordance with following standards:
 - .1 CAN/CSA-O141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
 - .3 CAN/CSA-Z809 or FSC or SFI certified.
- .2 Furring, blocking, nailing strips, grounds, rough bucks, cants, curbs, fascia backing and sleepers:
 - .1 S2S is acceptable for interior carpentry.
 - .2 Board sizes: "Standard" or better grade.
 - .3 Dimension sizes: "Standard" light framing or better grade.
 - .4 Post and timbers sizes: "Standard" or better grade.
- .3 Panel Materials:
 - .1 Douglas fir plywood (DFP): to CSA 0121, standard construction.
 - .1 Urea-formaldehyde free.
 - .2 Canadian softwood plywood (CSP): to CSA 0151, standard construction.
 - .1 Urea-formaldehyde free.
- .4 Primers Paints Coatings: in accordance with manufacturer's recommendations for surface conditions:

2.2 ACCESSORIES

- .1 Fasteners: to CAN/CSA-G164, for exterior work treated lumber.
- .2 Nails, spikes and staples: to CSA B111.
- .3 Bolts: 12.5 mm diameter unless indicated otherwise, complete with nuts and washers.
- .4 Proprietary fasteners: toggle bolts, expansion shields and lag bolts, screws and lead or inorganic fibre plugs, recommended for purpose by manufacturer.
 - .1 Explosive actuated fastening devices required Departmental Representative security approval.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for rough carpentry installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of

Departmental Representative.

.2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.

.3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 PREPARATION

.1 Treat surfaces of material exposed to the elements or exposed to water condensation with wood preservative, before installation.

.2 Apply preservative by dipping, or by brush to completely saturate and maintain wet film on surface for minimum 3 minute soak on lumber and 1 minute soak on plywood.

.3 Re-treat surfaces exposed by cutting, trimming or boring with liberal brush application of preservative before installation.

3.3 INSTALLATION

.1 Comply with requirements of NBC, supplemented by the following paragraphs.

.2 Install furring and blocking spaced out as required to support roofing equipment, material and other work.

.3 Align and plumb faces of furring and blocking to tolerance of 1:600.

.4 Install rough bucks, nailers and linings to rough openings as required to provide backing for frames and other work.

.5 Install wood cants, fascia backing, nailers, curbs and other wood supports as required and secure using galvanized steel fasteners.

.6 Install wood backing, dressed, tapered and recessed slightly below top surface of roof insulation for roof hopper.

.7 Install sleepers as required.

.8 Frame, anchor, fasten, tie and brace members to provide necessary strength and rigidity.

.9 Countersink bolts where necessary to provide clearance for other work.

.10 Securely fasten materials to structure in accordance with engineering direction as required to achieve resistance wind uplift.

3.4 CLEANING

.1 Progress Cleaning: clean in accordance with Section

01 74 11 - Cleaning.

.1 Leave Work area clean at end of each day.

.2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

.3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal

.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.