

---

**Question:****DWG 105 - PART PLAN REMOVALS & DEMOLITION II**

Details advise the Contractor to “DISCONNECT AND SALVAGE ALL HYDRAULIC AND ELECTRICAL LINES. DISCONNECT AND SALVAGE HYDRAULIC CYLINDERS IF REQUIRED.”

**DWG 106 - PLAN NEW CONSTRUCTION**

Details advise the Contractor to “ REINSTALL HYDRAULIC SYSTEM – 2 Locations”.

The contract drawings advise the Contractor to remove, salvage and reinstall the hydraulic systems. The contract drawings advise

The Contractor to simply remove and salvage the electrical lines. Electrical system is not to be reinstalled / reinstated. Please confirm.

**Answer:**

The note on drawing 106 should read 'Reinstall Hydraulic lines and Electrical conduit'.