



## Addendum 2

**Project Title:** Roof Replacement  
Building 76  
Central Experimental Farm (CEF), Ottawa (Ontario)

**Solicitation No:** 13-1191

September 25, 2013

**The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents**

---

### Q&A

**Q1:** There is information that lead coated copper flashing is no longer available because of the lead and that lead welding is not done anymore. Can you confirm and, if affirmative, specify options?

**A1:** We were able to determine that lead coated copper is available and that lead soldering is still practiced.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**