

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Building Modernization - Phase 2	
Solicitation No. - N° de l'invitation EC015-140977/A	Amendment No. - N° modif. 012
Client Reference No. - N° de référence du client R.039554.001	Date 2013-09-26
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3297	
File No. - N° de dossier PWB-3-36036 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-10-01	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro douze (12) est soumise et comprend la modification numéro douze (12) suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 12

1. CLARIFICATION

Elevators

In order to provide a fully non proprietary system, that can be readily maintained by contractors other than the original equipment manufacturer, the following is required for all equipment originating from companies owned by or affiliated with the bidder. This includes control equipment, fixtures, buttons and door operators.

Provide fully non-proprietary versions of all equipment including:

- a. All required diagnostics are "on board".
- b. All programming and diagrams required for long-term maintenance are provided and remain property of the equipment owner.
- c. The controller will not shut down or alter its functionality in any way after a pre-determined increment of time or use.
- d. Any elevator contractor is allowed to purchase parts, supplies, diagrams, support, or training directly from the factory at the same cost level as the original installer. A published price list shall be supplied. In the case of any control equipment not recognized as third-party non-proprietary, the parts list should be submitted in advance of, or conjunction with, the bid. The only control equipment recognized as third-party non proprietary presently is JRT (Quebec), MCE (California) and GAL (New York).
- e. Parts including circuit boards should be available for direct purchase from the factory in numbers and not on an one-for-one "exchange only" basis.

2. QUESTIONS ET RÉPONSES - ARCHITECTURAL

Q1: In Specification Section 01 91 13, item 1.3.2 states "For Cx responsibilities refer to Section 01 91 31 - Commissioning (Cs) Plan". This referred to section is not included in

this specification, nor is it referenced in the Index. Please provide this section.

R1: Contractor is to meet the requirements set in sections 01 91 13, 01 91 33, and 01 91 41. The owner is responsible for overall commissioning.

Q2: Amendment No. 4 - Section 09 68 00 Carpeting: Acceptable Product, Does the carpet tile have to match the specification exactly or is this a guide line, We distribute a Canadian made Carpet tile by Belletile in Belleville Ontario I am attaching we meet all spec except our Nylon is a nylon 6 not 6,6 and the Yarn weight is 20 oz not 22, or Gage is 1/12 which is tighter than the 1/10 Gage specified."

R2: Not an acceptable product.

Q3: " Re: Specification section 09 65 19 Part 2 - Products, 2.1 Material .2 Resilient Tile. Does the tile have to be 305 x 610 cm , or can we submit a 305 x 305 x 2mm thickness or 457 x 457 x 2mm with the current specification you are limiting to one company?"

R3: Tile to be 305 x 610 mm, all others not acceptable

3. DEVIS

Specification Section 01 91 51 - Building Management Manual (BMM) Delete Reference to "Commissioning Plan".

4. DESSINS

Item 4 Drawings (Clarification)

L-101 - Site Plan / Roof Plan and Details

All roof damages resulting from removals or installation of mechanical units / supporting structure / steel stairs, to be repaired to match existing.