

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
**800 Burrard Street, 2nd floor**  
**800,rue Burrard, 2e étage**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Building Envelope Remediation	
<b>Solicitation No. - N° de l'invitation</b> EZ899-141064/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2013-10-01
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-026-7089	
<b>File No. - N° de dossier</b> PWY-3-36120 (026)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-10-02</b>	<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Liu (PWY), Patty	<b>Buyer Id - Id de l'acheteur</b> pwy026
<b>Telephone No. - N° de téléphone</b> (604) 775-6227 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada - Gulf Georgia Cannery - Steveston, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-141064/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-3-36120

Buyer ID - Id de l'acheteur

pw026

CCC No./N° CCC - FMS No/ N° VME

---

## **Amendment 002**

Amendment 002 has been raised to incorporate Addendum No. 2.

- Please view attached.

All other terms and conditions remain unchanged.

## ADDENDUM No. 2

BUILDING ENVELOPE REMEDIATION  
Project No. R.060702.001

---

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

### 1.0 CHANGES AND CLARIFICATIONS

#### SPECIFICATIONS

1.1 Not applicable.

#### DRAWINGS

1.2 Not applicable.

### 2.0 RESPONSE TO CONTRACTOR QUERIES:

Q #1: We request a 16 week completion period for the work.

**A #1: Refer to Addendum #1, Item 1.2.**

Q #2: we also request a two week extension to the closing given the delays.

**A #2: Refer to Addendum #1 for closing date extension.**

Q #3: We request that the specification be confirmed that you do indeed require a full enclosure to abate the lead paint from all surfaces.

**A #3: Refer to Addendum #1, Item 2.A#4.**

Q #4: As you are requesting complete paint removal from all surfaces we need to know the coating thickness of each substrate as this will affect the speed of removal. In some cases it may be extremely difficult to remove 100% of all coating, please allow for a realistic spec in this regard.

**A #4: Refer to 2.A#1 above. Contractor to bid as specified. Refer to Addendum 1, Item 1.3.**

Q #5: We request an alternate specification be approved for walnut shell blasting as a means to remove existing lead paint.

**A #5: Contractor to determine method of lead paint removal in accordance with specified work schedule, applicable Provincial and Municipal environmental regulations and Occupational Safety and Health Regulations.**

Q #6: We request a unit price for wall and wood repairs along with glazing repairs as it is currently impossible to determine what requires repair.

**A #6: The work in question is not quantified and the contractor is not to provide for any cost in their bid for this work. Should any repair work subsequently be decided to be completed, it will be facilitated by Change Order.**

**END OF ADDENDUM No. 2**