

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada-
Bid Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

INVITATION TO TENDER
APPEL D'OFFRES

**Tender To: Public Works and Government Services
Canada**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: Travaux Publics et Services
Gouvernementaux Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet CFB & Mctn, Transformer Maintenance	
Solicitation No. - N° de l'invitation W0105-14E004/A	Date 2013-10-03
Client Reference No. - N° de référence du client	GETS Ref. No. - N° de réf. de SEAG PW-\$PWB-004-3309
File No. - N° de dossier PWB-3-36066 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-10-29	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CFB & Mctn Maintenance & Testing CFB Gagetown & Detachment Mctn Moncton New Brunswick Canada	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée See Herein	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

**TRANSFORMER MAINTENANCE AND TESTING
CFB GAGETOWN, OROMOCTO, NEW BRUNSWICK
AND DETACHMENT MONCTON, MONCTON, NEW BRUNSWICK**

TABLE OF CONTENTS

PART 1 - GENERAL INFORMATION

1. Requirement
2. Debriefings

PART 2 - BIDDER INSTRUCTIONS

1. Standard Instructions, Clauses and Conditions
2. Submission of Bids
3. Enquiries - Bid Solicitation
4. Applicable Laws
5. Insurance Requirements
6. Workers Compensation Certification - Letter of Good Standing

PART 3 - BID PREPARATION INSTRUCTIONS

1. Bid Preparation Instructions

PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION

1. Evaluation Procedures and Basis of Selection

PART 5 - CERTIFICATIONS

1. Mandatory Certifications Required Precedent to Contract Award
2. Additional Certifications Precedent to Contract Award

PART 6 - RESULTING CONTRACT CLAUSES

1. Requirement
2. Standard Clauses and Conditions
3. Term of Contract
4. Authorities
5. Payment
6. Invoicing Instructions
7. Certifications
8. Applicable Laws
- 9.. Priority of Documents
10. SACC Manual Clauses
11. Insurance Requirements

List of Annexes:

- Annex A: Evaluation Criteria and Basis of Selection
Annex B: Basis of Payment
Annex C: Insurance Requirements
Annex D: Complete List of Each Individual Who is Currently on the Bidder's Board of Directors

Solicitation No. - N° de l'invitation

W0105-14E004/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

Annex E: Specification

PART 1 - GENERAL INFORMATION

1. Requirement

The Department of National Defence (DND) has a requirement for the furnishing of all labour, material, tools and equipment required to conduct annual preventative maintenance testing for specified transformers, and providing written reports of the testing as required for the transformers located at CFB Gagetown, Oromocto, New Brunswick and Detachment Moncton, Moncton, New Brunswick. The Service Contract is required for the period from April 1, 2014 to March 31, 2015 with an option to extend for two additional one year periods. The services must be provided in accordance with the Specification attached at Annex "E".

This agreement is subject to the provisions of the Agreement on Internal Trade (AIT).

2. Debriefings

After contract award, bidders may request a debriefing on the results of the bid solicitation process. Bidders should make the request to the Contracting Authority within 15 working days of receipt of the results of the bid solicitation process. The debriefing may be in writing, by telephone or in person.

PART 2 - BIDDER INSTRUCTIONS

1. Standard Instructions, Clauses and Conditions

All instructions, clauses and conditions identified in the bid solicitation by number, date and title are set out in the *Standard Acquisition Clauses and Conditions*

(<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>)
Manual issued by Public Works and Government Services Canada.

Bidders who submit a bid agree to be bound by the instructions, clauses and conditions of the bid solicitation and accept the clauses and conditions of the resulting contract.

The 2003 (2013-06-01) Standard Instructions - Goods or Services - Competitive Requirements, are incorporated by reference into and form part of the bid solicitation.

1.1 SACC Manual Clauses (by reference)

A0220T - Evaluation of Price (2013-04-25)

2. Submission of Bids

Tenders shall be received at the office designated for the receipt of tenders, on or before the date and time set for tender closing. Late tenders will be returned unopened.

- (a) Bids must be complete and submitted on prescribed tender form;
- (b) Include the tender call number/project number and description of proposed work;
- (c) Include the closing date and time;
- (d) Must be received prior to bid closing time and at the designated place and facsimile number - FACSIMILE NUMBER IS (506-636-4376).

NOTE: FACSIMILE BIDS

Only incorrect handling by the Department of Public Works and Government Services will excuse the delay of responses transmitted by facsimile. Misrouting, traffic volume, weather disturbances, or any cause for the late receipt of such responses are not acceptable.

Bid Receiving
Public Works and Government Services Canada
Room 421
189 Prince William Street
Saint John, New Brunswick
E2L 2B9

NOTE: THIS IS NOT A PUBLIC OPENING

3. Enquiries - Bid Solicitation

All enquiries must be submitted in writing to the Contracting Authority no later than 5 (five) calendar days before the bid closing date. Enquiries received after that time may not be answered.

Bidders should reference as accurately as possible the numbered item of the bid solicitation to which the enquiry relates. Care should be taken by bidders to explain each question in sufficient detail in order to enable Canada to provide an accurate answer. Technical enquiries that are of a proprietary nature must be clearly marked "proprietary" at each relevant item. Items identified as "proprietary" will be treated as such except where Canada determines that the enquiry is not of a proprietary nature. Canada may edit the questions or may request that the Bidder do so, so that the proprietary nature of the question is eliminated, and the enquiry can be answered with copies to all bidders. Enquiries not submitted in a form that can be distributed to all bidders may not be answered by Canada.

4. Applicable Laws

Any resulting contract must be interpreted and governed, and the relations between the parties determined, by the laws in force in New Brunswick.

Bidders may, at their discretion, substitute the applicable laws of a Canadian province or territory of their choice without affecting the validity of their bid, by deleting the name of the Canadian province or territory specified and inserting the name of the Canadian province or territory of their choice. If no change is made, it acknowledges that the applicable laws specified are acceptable to the bidders.

5. Insurance Requirements

The Bidder must provide a letter from an insurance broker or an insurance company licensed to operate in Canada stating that the Bidder, if awarded a contract as a result of the bid solicitation, can be insured in accordance with the Insurance Requirements specified in Annex "C".

If the information is not provided in the bid, the Contracting Authority will so inform the Bidder and provide the Bidder with a time frame within which to meet the requirement. Failure to comply with the request of the Contracting Authority and meet the requirement within that time period will render the bid non-responsive.

6. Workers Compensation Certification - Letter of Good Standing

The Bidder must have an account in good standing with the applicable provincial or territorial Workers' Compensation Board.

The Bidder must provide, within seven (7) days following a request from the Contracting Authority, a certificate or letter from the applicable Workers' Compensation Board confirming the Bidder's good standing account. Failure to comply with the request may result in the bid being declared non-responsive.

PART 3 - BID PREPARATION INSTRUCTIONS

1. Bid Preparation Instructions

Price must not appear in any other area of the bid except in the **Financial Bid**.

It is required that the bids follow the response format/instructions as detailed below:

Section I: Technical Bid

No Technical Bid required as part of this requirement.

Section II: Financial Bid

Bidders must submit their financial bid in accordance with Annex "B" Basis of Payment. The total amount of Goods and Services Tax (GST) or Harmonized Sales Tax (HST) must be shown separately, if applicable

Section III: Certifications

Bidders must submit the certification required under Part 5.

Solicitation No. - N° de l'invitation

W0105-14E004/A

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION

1. Evaluation Procedures and Basis of Selection

Bids will be evaluated in accordance with the **Evaluation Criteria and Basis of Selection** specified in **Annex "A"** and **Basis of Payment** specified in **Annex "B"**. Bids will be assessed in accordance with the entire requirement of the bid solicitation including the technical and financial evaluation criteria.

PART 5 - CERTIFICATIONS

Bidders must provide the required certifications to be awarded a contract. Canada will declare a bid non-responsive if the required certifications are not completed and submitted as requested.

Compliance with the certifications bidders provide to Canada is subject to verification by Canada during the bid evaluation period (before award of a contract) and after award of a contract. The Contracting Authority will have the right to ask for additional information to verify bidders' compliance with the certifications before award of a contract. The bid will be declared non-responsive if any certification made by the Bidder is untrue, whether made knowingly or unknowingly. Failure to comply with the certifications or to comply with the request of the Contracting Authority for additional information will also render the bid non-responsive.

1. Mandatory Certifications Required Precedent to Contract Award

1.1 Code of Conduct and Certifications - Related documentation

By submitting a bid, the Bidder certifies, for himself and his affiliates, to be in compliance with the Code of

Conduct and Certifications clause of the Standard instructions. The related documentation hereinafter mentioned will help Canada in confirming that the certifications are true. By submitting a bid, the Bidder certifies that it is aware, and that its affiliates are aware, that Canada may request additional information, certifications, consent forms and other evidentiary elements proving identity or eligibility. Canada may also verify the information provided by the Bidder, including the information relating to the acts or convictions specified herein, through independent research, use of any government resources or by contacting third parties. Canada will declare non-responsive any bid in respect of which the information requested is missing or inaccurate, or in respect of which the information contained in the certifications is found to be untrue, in any respect, by Canada. The Bidder and any of the Bidder's affiliates, will also be required to remain free and clear of any acts or convictions specified herein during the period of any contract arising from this bid solicitation.

Bidders who are incorporated, including those bidding as a joint venture, must provide with their bid or promptly thereafter a complete list of names of all individuals who are currently directors of the Bidder. Bidders bidding as sole proprietorship, including those bidding as a joint venture, must provide the name of the owner with their bid or promptly thereafter. Bidders bidding as societies, firms, partnerships or associations of persons do not need to provide lists of names. If the required names have not been received by the time the evaluation of bids is completed, Canada will inform the Bidder of a time frame within which to provide the information. Failure to comply will render the bid non-responsive. Providing the required names is a mandatory requirement for contract award.

Canada may, at any time, request that a Bidder provide properly completed and Signed Consent Forms (Consent to a Criminal Record Verification form- PWGSC-TPSGC 229)

(<http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/formulaires-forms-eng.html>) for any or all individuals aforementioned within the time specified. Failure to provide such Consent Forms within the time period provided will result in the bid being declared non-responsive.

2. Additional Certifications Precedent to Contract Award

The certifications listed below should be completed and submitted with the bid, but may be submitted afterwards. If any of these required certifications is not completed and submitted as requested, the Contracting Authority will so inform the Bidder and provide the Bidder with a time frame within which to

meet the requirement. Failure to comply with the request of the Contracting Authority and meet the requirement within that time period will render the bid non-responsive.

2.1 Former Public Servant Certification

Contracts awarded to former public servants (FPS) in receipt of a pension or of a lump sum payment must bear the closest public scrutiny, and reflect fairness in the spending of public funds. In order to comply with Treasury Board policies and directives on contracts with FPS, bidders must provide the information required below before contract award.

Definitions

For the purposes of this clause, "*former public servant*" is any former member of a department as defined in the *Financial Administration Act*, R.S., 1985, c. F-11, a former member of the Canadian Armed Forces or a former member of the Royal Canadian Mounted Police. A former public servant may be:

an individual;

an individual who has incorporated;

a partnership made of former public servants; or

a sole proprietorship or entity where the affected individual has a controlling or major interest in the entity.

"lump sum payment period" means the period measured in weeks of salary, for which payment has been made to facilitate the transition to retirement or to other employment as a result of the implementation of various programs to reduce the size of the Public Service. The lump sum payment period does not include the period of severance pay, which is measured in a like manner.

"pension" means a pension or annual allowance paid under the *Public Service Superannuation Act* (PSSA), R.S., 1985, c.P-36, and any increases paid pursuant to the *Supplementary Retirement Benefits Act*, R.S., 1985, c.S-24 as it affects the PSSA. It does not include pensions payable pursuant to the *Canadian Forces Superannuation Act*, R.S., 1985, c.C-17, the *Defence Services Pension Continuation Act*, 1970, c.D-3, the *Royal Canadian Mounted Police Pension Continuation Act*, 1970, c.R-10, and the *Royal Canadian Mounted Police Superannuation Act*, R.S., 1985, c.R-11, the *Members of Parliament Retiring Allowances Act*, R.S., 1985, c.M-5, and that portion of pension payable to the *Canada Pension Plan Act*, R.S., 1985, c.C-8.

Former Public Servant in Receipt of a Pension

As per the above definitions, is the Bidder a FPS in receipt of a pension? **Yes () No ()**

If so, the Bidder must provide the following information, for all FPS in receipt of a pension, as applicable:

name of former public servant;

date of termination of employment or retirement from the Public Service.

Solicitation No. - N° de l'invitation

W0105-14E004/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

By providing this information, Bidders agree that the successful Bidder's status, with respect to being a former public servant in receipt of a pension, will be reported on departmental websites as part of the published proactive disclosure reports in accordance with [Contracting Policy Notice: 2012-2](#) and the [Guidelines on the Proactive Disclosure of Contracts](#).

Work Force Adjustment Directive

Is the Bidder a FPS who received a lump sum payment pursuant to the terms of the Work Force Adjustment Directive? **Yes () No ()**

If so, the Bidder must provide the following information:

name of former public servant;

conditions of the lump sum payment incentive;

date of termination of employment;

amount of lump sum payment;

rate of pay on which lump sum payment is based;

period of lump sum payment including start date, end date and number of weeks;

number and amount (professional fees) of other contracts subject to the restrictions of a work force adjustment program.

For all contracts awarded during the lump sum payment period, the total amount of fees that may be paid to a FPS who received a lump sum payment is \$5,000, including Applicable Taxes.

PART 6 - RESULTING CONTRACT CLAUSES

1. Requirement

The Department of National Defence (DND) has a requirement for the furnishing of all labour, material, tools and equipment required to conduct annual preventative maintenance testing for specified transformers, and providing written reports of the testing as required for the transformers located at CFB Gagetown, Oromocto, New Brunswick and Detachment Moncton, Moncton, New Brunswick. The Service Contract is required for the period from April 1, 2014 to March 31, 2015 with an option to extend for two additional one year periods. The services must be provided in accordance with the Specification attached at Annex "E".

2. Standard Clauses and Conditions

All clauses and conditions identified in the Contract by number, date and title are set out in the *Standard Acquisition Clauses and Conditions*

(<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>)

Manual issued by Public Works and Government Services Canada.

2.1 General Conditions

2010C (2013-06-27), General Conditions - Services (Medium Complexity) apply to and form part of the Contract.

3. Term of Contract

3.1 Period of the Contract

The work is to be performed from April 1, 2014 to March 31, 2015.

3.2 Option to Extend the Contract

The Contractor grants to Canada the irrevocable option to extend the term of the Contract by up to two (2) additional one (1) year period(s) under the same conditions. The Contractor agrees that, during the extended period of the Contract, it will be paid in accordance with the applicable provisions as set out in the Basis of Payment.

Canada may exercise this option at any time by sending a written notice to the Contractor at least thirty (30) calendar days before the expiry date of the Contract. The option may only be exercised by the Contracting Authority, and will be evidenced for administrative purposes only, through a contract amendment.

4. Authorities

4.1 Contracting Authority

The Contracting Authority for the Contract is:

Name: Gisèle Doucet
Title: Supply Specialist
Organization: Public Works and Government Services Canada
Acquisitions Branch
Directorate: Real Property Contracting
Address: 189 Prince William Street
Saint John, New Brunswick
E2L 2B9
Telephone: (506) 636-4541
Facsimile: (506) 636-4376
E-mail address: gisele.doucet@pwgsc.gc.ca

The Contracting Authority is responsible for the management of the Contract and any changes to the Contract must be authorized in writing by the Contracting Authority. The Contractor must not perform work in excess of or outside the scope of the Contract based on verbal or written requests or instructions from anybody other than the Contracting Authority.

4.2 Project Authority - Will be made available at time of award

The Project Authority for the Contract is:

Name:
Title:
Organization:
Address:
Telephone :
Facsimile:
E-mail address:

The Project Authority is the representative of the department or agency for whom the Work is being carried out under the Contract and is responsible for all matters concerning the technical content of the Work under the Contract. Technical matters may be discussed with the Project Authority, however the Project Authority has no authority to authorize changes to the scope of the Work. Changes to the scope of the Work can only be made through a contract amendment issued by the Contracting Authority.

4.3 Contractor's Representative

Name:
Title:
Organization:
Address:
Telephone:
Fax:
E-mail:

5. Payment

Basis of payment is in accordance with Annex "B" and section 12, Payment Period, of the 2010C (2013-06-27), General Conditions - Services (Medium Complexity).

5.1 Monthly Payment

SACC Manual clause H1008C (2008-05-12) Monthly Payment

6. Invoicing Instructions

The Contractor must submit invoices in accordance with the information required in section 10, Invoice Submission, of the 2010C (2013-06-27), General Conditions - Services (Medium Complexity).

7. Certifications

7.1 Compliance with the certifications provided by the Contractor in its bid is a condition of the Contract and subject to verification by Canada during the term of the Contract. If the Contractor does not comply with any certification or it is determined that any certification made by the Contractor in its bid is untrue, whether made knowingly or unknowingly, Canada has the right, pursuant to the default provision of the Contract, to terminate the Contract for default.

8. Applicable Laws

The Contract must be interpreted and governed, and the relations between the parties determined, by the laws in force in New Brunswick.

9. Priority of Documents

If there is a discrepancy between the wording of any documents that appear on the list, the wording of the document that first appears on the list has priority over the wording of any document that subsequently appears on the list.

- (a) the Articles of Agreement;
- (b) 2010C (2013-06-27);
- (c) Specification (Annex "E") and annexes;
- (d) Any Amendment issued or any allowable bid revision received before the date and time set for solicitation closing;
- (e) the Contractor's bid dated _____

10. SACC Manual Clauses

SACC Manual Clause A0285C (2007-05-25) Worker's Compensation
SACC Manual Clause A2000C (2006-06-16) Foreign Nationals (Canadian Contractor)
SACC Manual Clause A2001C (2006-06-16) Foreign Nationals (Foreign Contractor)

11. Insurance Requirements

The Contractor must comply with the insurance requirements specified in Annex "C". The Contractor must maintain the required insurance coverage for the duration of the Contract. Compliance with the insurance requirements does not release the Contractor from or reduce its liability under the Contract.

The Contractor is responsible for deciding if additional insurance coverage is necessary to fulfill its obligation under the Contract and to ensure compliance with any applicable law. Any additional insurance coverage is at the Contractor's expense, and for its own benefit and protection.

The Contractor must forward to the Contracting Authority within seven (7) days after request from the Contracting Authority and prior to award of Service Contract, a Certificate of Insurance evidencing the insurance coverage and confirming that the insurance policy complying with the requirements is in force. Coverage must be placed with an Insurer licensed to carry out business in Canada. The Contractor must, if requested by the Contracting Authority, forward to Canada a certified true copy of all applicable insurance policies.

Solicitation No. - N° de l'invitation

W0105-14E004/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

ANNEX "A"

EVALUATION CRITERIA AND BASIS OF SELECTION

ANNEX "A"

EVALUATION CRITERIA AND BASIS OF SELECTION

Bids received will be assessed in accordance with the entire requirement of the bid solicitation.

1. Mandatory Criteria

1. Submission of firm prices/rates for one (1) year including two (2) option years in accordance with Invitation to Tender.
2. A duly completed and signed Invitation to Tender including all Addenda.
3. Within seven (7) days of request from contracting authority and prior to award of Service Contract, provide proof that Bidder has an account in good standing with the Provincial Workers Compensation Board/Commission.
4. Within seven (7) days of request from contracting authority and prior to award of Service Contract, the bidder shall be required to provide proof of Commercial General Liability Insurance in the amount of \$2,000,000.00 in accordance with Section 00 21 13, Paragraph 1.5 of the Specification located at Annex "E"
5. Within seven (7) days of request from contracting authority and prior to award of Service Contract, the bidder shall be required to provide copies of licenses as proof of High Voltage Electrical Mechanic and/or a Linesman License, specializing in High Voltage Installations, as issued by the Province of New Brunswick Department of Training and Employment Development Apprenticeship and Certification, and have a minimum of two (2) years High Voltage Electrical contracting experience.
6. Within seven (7) days of request from contracting authority and prior to award of Service Contract, the bidder must provide proof of level one thermography to perform infra red inspections.

2. 2007/05/07 A0069T Basis of Selection - Mandatory Requirements Only

A bid must comply with all requirements of the bid solicitation to be declared responsive. The responsive bid with the lowest evaluated price will be recommended for award of a contract.

Solicitation No. - N° de l'invitation

W0105-14E004/A

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

ANNEX "B"

BASIS OF PAYMENT

Solicitation No. - N° de l'invitation

W0105-14E004/A

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-3-36066

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No/ N° VME

ANNEX "B"

BASIS OF PAYMENT

The following requirement must be strictly adhered to: **Failure to do so shall render the bidder's proposal as non-responsive.**

It is mandatory that the bidders submit firm rates for the Period of the Service Contract for all items listed hereafter. Unit Price Tables, will be considered as the bidder's Financial Proposal.

Each item specified in the Unit Price Tables, includes wages, traveling time and costs, allowances, supervision, liabilities as employer, insurance, and the use of all tools, tackle, etc., overhead, profit, and all other liabilities whatsoever.

The prices inserted in the Unit Price Tables, includes all applicable federal, provincial and municipal taxes. However, they do not include any amount for the Goods and Services Tax (GST)/Harmonized Sales Tax (HST). The appropriate GST/HST amounts will be paid by Her Majesty to the Offeror in addition to the amount paid against the amount of the contract.

Solicitation No. - N° de l'invitation
W0105-14E004/A
 Client Ref. No. - N° de réf. du client
 W0105-14E004

Amd. No. - N° de la modif.
 File No. - N° du dossier
 PWB-3-36053

Buyer ID - Id de l'acheteur
 pwb004
 CCC No./N° CCC - FMS No/N° VME

W0105-14E004

The estimated quantity entered in column four for each item is an estimate only for service as and when required and does not infer all the quantities for that item will be utilized or that the quantities may not be exceeded.
NOTE: TENDERS WILL BE EVALUATED ON THE TOTAL BID FOR THE FIRST TERM OF THE CONTRACT PLUS THE OPTION YEARS. HOWEVER, ANY CONTRACT AWARD WILL BE FOR THE PERIOD FROM APRIL 1, 2014 TO MARCH 31, 2015.

Item	Class of Service	Unit of Measure	Estimated Quantity	A		B		C	
				Term	Option Year	Term	Option Year	Term	Option Year
				Price per Unit	Total	Price per Unit	Total	Price per Unit	Total
1.	Rate per hour for service calls at CFB Gagetown	Per Hour	80						
2.	Rate per hour for service calls at Detachment Moncton	Per Hour	20						
3.	Rate for two (2) transformer inspections per year at CFB Gagetown as outlined in Section 26 05 01, Part 2 - Testing	Per Inspection	2						
4.	Rate for two (2) transformer inspections per year at Detachment Moncton as outlined in Section 26 05 01, Part 2 - Testing	Per Inspection	2						
5.	Rate for one (1) infra-red transformer inspection at CFB Gagetown as outlined								

Solicitation No. - N° de l'invitation
W0105-14E004/A
 Client Ref. No. - N° de réf. du client
 W0105-14E004

Amd. No. - N° de la modif.
 File No. - N° du dossier
 PWB-3-36053

Buyer ID - Id de l'acheteur
 pw/b004
 CCC No./N° CCC - FMS No/N° VME

in Section 26 05 01, Part 2 -
 Testing. **This inspection
 is required in the first year
 of the contract only.**

Per Inspection 1 _____ N/A _____ N/A _____ N/A _____ N/A

6. Rate for one (1) infra-red
 transformer inspection at detach-
 ment Moncton as outlined
 in Section 26 05 01, Part 2 -
 Testing. **This inspection
 is required in the first year
 of the contract only.**

Per Inspection 1 _____ N/A _____ N/A _____ N/A _____ N/A

7. All materials will be invoiced
 at the Contractor's wholesale cost
 plus a percentage for mark-up,
 estimated at \$7,500.00. The
 Contractor is to submit a percent
 of mark-up for tendering purposes.

Allowance \$7,500.00 Mark-up _____% Mark-up _____%
 _____% _____%

TOTAL FOR FIRST TERM AND OPTION YEARS

\$ _____ A \$ _____ B \$ _____ C

GRAND TOTAL FOR FIRST TERM AND OPTION YEARS

\$ _____
A, B AND C

Solicitation No. - N° de l'invitation

W0105-13E050/A

Client Ref. No. - N° de réf. du client

W0105-13E050

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-2-35142

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

ANNEX "C"

INSURANCE REQUIREMENTS

ANNEX "C" INSURANCE REQUIREMENTS

1. Commercial General Liability Insurance

1. The Contractor must obtain Commercial General Liability Insurance, and maintain it in force throughout the duration of the Contract, in an amount usual for a contract of this nature, **but for not less than \$2,000,000 per accident or occurrence and in the annual aggregate.**
2. The Commercial General Liability policy must include the following:
 - (a) Additional Insured: Canada is added as an additional insured, but only with respect to liability arising out of the Contractor's performance of the Contract. The interest of Canada should read as follows: Canada, as represented by Public Works and Government Services Canada.
 - (b) Bodily Injury and Property Damage to third parties arising out of the operations of the Contractor.
 - (c) Products and Completed Operations: Coverage for bodily injury or property damage arising out of goods or products manufactured, sold, handled, or distributed by the Contractor and/or arising out of operations that have been completed by the Contractor.
 - (d) Personal Injury: While not limited to, the coverage must include Violation of Privacy, Libel and Slander, False Arrest, Detention or Imprisonment and Defamation of Character.
 - (e) Cross Liability/Separation of Insureds: Without increasing the limit of liability, the policy must protect all insured parties to the full extent of coverage provided. Further, the policy must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.
 - (f) Blanket Contractual Liability: The policy must, on a blanket basis or by specific reference to the Contract, extend to assumed liabilities with respect to contractual provisions.
 - (g) Employees and, if applicable, Volunteers must be included as Additional Insured.
 - (h) Employers' Liability (or confirmation that all employees are covered by Worker's compensation (WSIB) or similar program)

-
- (i) **Broad Form Property Damage including Completed Operations:** Expands the Property Damage coverage to include certain losses that would otherwise be excluded by the standard care, custody or control exclusion found in a standard policy.
 - (j) **Notice of Cancellation:** The Insurer will endeavour to provide the Contracting Authority thirty (30) days written notice of policy cancellation.
 - (k) **If the policy is written on a claims-made basis, coverage must be in place for a period of at least 12 months after the completion or termination of the Contract.**
 - (l) **Owners' or Contractors' Protective Liability:** Covers the damages that the Contractor becomes legally obligated to pay arising out of the operations of a subcontractor.
 - (m) **Non-Owned Automobile Liability - Coverage for suits against the Contractor resulting from the use of hired or non-owned vehicles.**
 - (n) **Sudden and Accidental Pollution Liability (minimum 120 hours):** To protect the Contractor for liabilities arising from damages caused by accidental pollution incidents.

Solicitation No. - N° de l'invitation

W0105-13E050/A

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-2-35142

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

W0105-13E050

ANNEX "D" Complete List of Each Individual Who is Currently on the Board of Directors

NOTE TO BIDDERS

WRITE DIRECTORS SURNAMES AND GIVEN NAMES IN BLOCK LETTERS

Solicitation No. - N° de l'invitation

W0105-13E050/A

Client Ref. No. - N° de réf. du client

W0105-13E050

Amd. No. - N° de la modif.

File No. - N° du dossier

PWB-2-35142

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

ANNEX "E"

SPECIFICATION



**DEPARTMENT OF NATIONAL DEFENCE
5 ENGINEERING SERVICES SQUADRON
5 ENGINEER SERVICES UNIT
CFB GAGETOWN**

SPECIFICATION

SERVICE CONTRACT
TRANSFORMER MAINTENANCE AND TESTING
CFB GAGETOWN AND DETACHMENT MONCTON
APRIL 01, 2014 TO MARCH 31, 2015
WITH TWO (2) ONE (1) YEAR OPTION PERIODS


Designed by


Fire Inspector


Project O


Engineering O

PF No:
Job No: L-G2-9900 / 1611

Date: 14 May 2013

<u>Section</u>	<u>Title</u>	<u>Pages</u>
<u>Division 00 - Procurement and Contracting Requirements</u>		
00 21 13	Instructions to Bidders	8
<u>Division 01 - General Requirements</u>		
01 35 30	Health and Safety Requirements	2
01 35 35	DND Fire Safety Requirements	3
01 35 43	Environmental Procedures	1
<u>Division 26 - Electrical</u>		
26 05 01	Transformer Testing Criteria	3

List of Attachments

Annex A - CFB Gagetown Transformer Inventory	5
Annex B - Detachment Moncton Transformer Inventory	1

PART 1 - GENERAL

- 1.1 Description of Work .1 The work covered under this Service Contract comprises the furnishing of all labour, material, tools and equipment required to conduct annual preventative maintenance testing for specified transformers, and providing written reports of the testing as required for the transformers located at CFB Gagetown and Detachment Moncton, as specified herein.
- 1.2 Duration of Contract .1 This Service Contract will extend from April 01, 2014 to March 31, 2015, with two (2) one (1) year option periods.
- 1.3 Qualifications .1 The Contractor must possess a current High Voltage Electrical Mechanic and/or a Linesman License, specializing in High Voltage installations, as issued by the Province of New Brunswick Department of Training and Employment Development Apprenticeship and Certification, and have a minimum of two (2) years High Voltage Electrical contracting experience.
- .2 All high voltage work is to be performed by tradesman and registered apprentices licensed by the Province where the work is being conducted.
- .3 Proof of level one thermography to perform infra red inspections.
- 1.4 Engineer .1 The Engineer, as defined and stated in this Specification, will be the Commanding Officer of 5 Engineer Services Unit or a designated representative. The address of the Engineer is:
- Contracts Office
5 Engineer Services Unit
Building B18
CFB/ASU Gagetown
PO Box 17000 Station Forces
Oromocto, NB
E2V 4J5
-

- 1.4 Engineer .1 (Cont'd)
Telephone: (506) 422-2000 Extension 2677.
Fax: (506) 422-1248.
- 1.5 Liability Insurance .1 The Contractor shall provide proof of Liability Insurance in the amount of Two Million Dollars (2,000,000.00) to PWGSC before the award of this Service Contract.
- 1.6 Documents Required .1 Maintain at the job site one (1) copy of each of the following:
.1 Specifications; and
.2 Addenda.
- 1.7 Contractor's Use of Site .1 Work site access will be as directed by the Engineer.
.2 Movement around the site is subject to restrictions laid down by the Engineer.
.3 Do not unreasonably encumber the site with materials or equipment.
- 1.8 Temporary Services .1 DND will not provide temporary electric power and water for the purposes of this agreement.
- 1.9 Acceptability of Material .1 Material and parts used will be those specified by the manufacturer of the equipment, and any other material will require the approval of the Engineer.
.2 Provide material and equipment of specified design and quality, performing to published ratings and for which replacement parts are readily available.
.3 The Contractor will not make any change in the design and installation of equipment and materials without prior written approval of the Engineer.
.4 If, in an emergency, the Contractor installs parts other than those specified, they will be replaced with specified parts before claiming
-

-
- 1.9 Acceptability of Material (Cont'd)
- .4 (Cont'd)
payment, but no claim for other than specified parts will be made.
 - .5 All replaced parts and materials not under warranty, whether serviceable or unserviceable will be left on site for inspection on completion of the work.
 - .6 All manufactured articles, materials, and equipment will be applied, installed, connected and used as specified by the manufacturer and the Engineer.
 - .7 Requests for acceptance of materials other than those specified will be submitted in writing to the Engineer. The request must be supported with sufficient product information to enable the Engineer to make an assessment.
- 1.10 Guarantee
- .1 The Contractor will guarantee all materials installed and workmanship for a period of one (1) year or the manufacturer's guarantee, whichever is longer, after acceptance by the Engineer. Any defects which may develop during this period will be rectified and made good to the satisfaction of the Engineer, by the Contractor at their own expense.
- 1.11 Codes and Standards
- .1 Perform work and enforce safety measures in accordance with the latest editions of the National Building Code of Canada; Canadian Labour Code, Part 2; the Canadian Electrical Code, Part III, Electricity Distribution and Transmission Systems; 3 ASG Engineer Branch SOP 8.2, Confined Spaces; 3 ASG Engineer Branch SOP 2.3, Electrical Equipment and Facilities, Annex B, Isolation and Lockout Procedures; and WorkSafe NB, unless otherwise specified.
 - .2 The Contractor must be registered with WorkSafe NB.
 - .3 Comply with the requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage and disposal of hazardous materials; and labelling and provision of Materials Safety Data Sheets acceptable to Human Resources and Skills Development Canada and Health Canada.
-

-
- 1.11 Codes and Standards (Cont'd) .4 Work is to meet or exceed the requirements of specified standards, codes and referenced documents. In the event of conflict between any provisions of the above authorities, the most stringent provision shall apply.
- 1.12 Overloading .1 Ensure no part of work is subject to a load which will endanger its safety or will cause permanent deformation.
- 1.13 Temporary Structures .1 The Contractor will furnish and maintain all equipment such as temporary ramps, ladders, scaffolds, hoists, chutes, etc, as may be required for the proper execution of the work.
- .2 Temporary structures erected by the Contractor will remain their property and will be removed from the site on completion of the work.
- 1.14 Clean Up .1 On completion of all work, the Contractor will remove all surplus material, tools, equipment and debris. The building and site must be left in a clean and tidy condition which meets the satisfaction of the Engineer. The Contractor will not remove any salvageable material or equipment from the job site without permission from the Engineer.
- 1.15 Maintenance Inspections .1 Visual inspections shall be scheduled during the months of May and November. Infra-red scans shall be scheduled during the month of July and be completed only on the first year of the contract.
- .2 Inspections requiring power shut-downs shall be scheduled for evening and weekend hours, so as to minimize the impact on building's functions and military training operations.
- .3 Emergency power shut-downs shall be coordinated through the Engineer.
- .4 The Contractor shall provide a complete and concise report on all inspection findings
-

1.16 Quantities and .1
Basis of Payment

The Contractor will submit prices for the following in accordance with the specification. Such prices will include transportation (travel time to and from the contractors base of operation will be included in the rates provided), supervision, expenses and profit:

.1 Rate per hour for service calls at CFB Gagetown. **(Estimated 80 hours)**

.2 Rate per hour for service calls at Detachment Moncton. **(Estimated 20 hours)**

.3 Rate for two (2) transformer inspections per year at CFB Gagetown as outlined in section 26 05 01, Part 2- Testing.

(Quantity 2 inspections)

.4 Rate for two (2) transformer inspections per year at Detachment Moncton as outlined in section 26 05 01, Part 2-Testing.

(Quantity 2 inspections)

.5 Rate for one (1) infra-red transformer inspection at CFB Gagetown as outlined in 26 05 01, Part 2 -Testing. **This inspection is required in the first year of the contract only.** No bid required for first and second option years.

(Quantity 1 inspection)

.6 Rate for one infra-red transformer inspection at Detachment Moncton as outlined in 26 05 01, Part 2-Testing. **This inspection is required in the first year of the contract only.** No bid is required for the first and second option years.

(Quantity 1 inspection)

.7 All materials will be invoiced at the Contractor's wholesale cost plus a percentage for mark-up. **(Estimated at \$7,500.00)** The Contractor will submit a percentage of mark-up for tendering purposes. Copies of the Contractor's invoices from any and all suppliers must accompany the Contractor's invoice for all materials used in the completion of the work for all service calls.

.2 Time charged, materials used and supporting documentation submitted may be verified by Government Audit before or after payment.

.3 The above estimated quantities may increase or decrease and are to only to be used as a guide. The quantities are nor guaranteed and the Contractor will have no claim for loss of anticipated profits as a result of these estimated quantities.

1.16 Quantities and .4
Basis of Payment
(Cont'd)

- One invoice covering all charges for each Service Request or Inspection will be submitted to the Engineer with a copy of the faxed Service Request within 10 working days of completion of work. The invoice must indicate Contract, Work Order and Requisition numbers issued on the Work Request. The invoice must itemize technicians' names, dates and hours worked, materials used complete with copies of the Contractor's invoices verifying correct mark-up on materials.
- .5 The Contractor will provide service during normal working hours on an eight (8) hour per day, five (5) days per week basis, 0730 to 1600 hours, Monday to Friday inclusive and emergency service after normal working hours.
- .6 The Contractor will advise the Engineer of the telephone number or location at which they or their representative may be contacted at all times.
- .7 The Contractor, upon receipt of an Acceptance of Tender, will be advised by the Engineer in writing of the names of persons authorized to request service. Work undertaken at the request of others, such as building occupants, will be entirely at the Contractor's risk with regard to payment.
- .8 The Contractor will not refuse any call for service by the Engineer and will respond within twenty-four (24) hours on normal service calls and within four (4) hours on emergency service calls.
- .9 When service is required, the Engineer will notify the Contractor and detail the job. When requested by the Engineer, a written estimate shall be provided by the Contractor indicating estimated labour and material costs in accordance with the Service Contract.
- .10 The Contractor will report to the Engineer prior to starting work and upon completion of work on a daily basis to sign in and out. If work started or completed outside normal working hours and the Engineer's office is closed, the Base Fire Department has a sign in/sign out sheet available for the Contractor.
- .11 After reporting, the Contractor will proceed to the job and carry out the work. The

1.16 Quantities and .11 (Cont'd)
Basis of Payment
(Cont'd)

Contractor will provide daily work reports to the Engineer detailing the work performed, Contractor's employees assigned to work, location or building number of the work site, hours worked for each employee, trade of each employee, the materials used in the completion of the work and any recommendations for further work that may be required. This work report must indicate the work order number and the requisition number on which the work was requested from the Engineer. The Contractor is to have the Engineer sign the work report either at the end of the work day or at the beginning of the next work day while signing in. The Standard Operating Procedure (SOP) for work reports will be provided to the successful bidder after award of Contract.

1.17 Contractor .1
Passes

- .1 All Contractor employees will have in their possession at all times while on the Base an authorized Contractor Pass while employed on DND property. Such passes will be produced on demand to the Military Police, Commissionaires, Security Guards and persons in authority.
- .2 The Contractor will complete an application form for the Contractor Passes for each individual. The Contractor will accompany the employee to the Military Police Identification Section, Building F-19, for the issuance of a pass.
- .3 Photocopies of passes are to be provided to the Engineer.
- .4 The Contractor will ensure Contractor Passes are recovered from employees who cease to be employed on DND property. Such passes shall be returned to the Military police Identification Section by the Contractor.

1.18 Security .1
Clearance

- .1 The Contractor shall maintain an up-to-date roster of all employees involved in this contract including managers, supervisors, tradespersons, drivers and labourers. This roster must be made available to the Engineer upon request.

1.18 Security Clearance (Cont'd) .2

The Contractor shall provide proof of the information contained within the roster to the Engineer upon request. The Engineer reserves the right to have removed from the site those personnel who do not meet the security requirements as laid down by the Military Police Identification Section.

1.19 Documentation .1

The successful bidder when requested shall supply PWGSC with the following;

- .1 Proof of current High Voltage Electrical Mechanic and/or High Voltage Linesman License's specializing in High voltage installations as per section 1.3 Qualifications.
- .2 Certification of level 1 thermographer as per section 1.3 Qualifications.
- .3 Proof of two (2) years High voltage Electrical Contracting experience.
- .4 Proof of liability insurance as per section 1.5 Liability Insurance
- .5 Proof of current registration with Work Safe NB as per section 1.11
- .6 Qualifications of other workers who will be performing work as per section 1.3.2 Qualifications.
- .7 Proof of being able to respond to emergencies within 4 hours as per section 1.16.8. (IE) Letter stating response plan and time/distance of travel to Base.

PART 1 - GENERAL

- 1.1 References .1 Canada Labour Code, Part 2, Canada Occupational Safety and Health Regulations.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
.1 Material Safety Data Sheets (MSDS).
- .3 Province of New Brunswick:
.1 Occupational Health and Safety Act, S.N.B. 1983.
- 1.2 Regulatory Requirements .1 Do Work in accordance with the safety measures of the National Building Code of Canada 2010, the Canada Labour Code Part 2, the New Brunswick Occupational Health and Safety Act, and WorkSafe NB, provided that in any case of conflict or discrepancy the more stringent requirements shall apply.
- 1.3 Responsibility .1 The Contractor is responsible for health and safety of all persons on site, safety of property on site and for protection of persons adjacent to site and environment to extent that they may be affected by conduct of Work.
- .2 The Contractor and all of the Contractor's employees are to comply with and enforce all safety requirements specified in the Contract Documents as well as all applicable federal, provincial and local statutes, regulations, and ordinances, and with site-specific Health and Safety Plan.
- .3 As outlined in the Canada Labour Code Part 2, the Contractor is responsible to provide a site-specific Health and Safety Plan that includes a Confined Space Entry Procedure in the event that work is deemed by the Engineer to be in a confined space. Work is not to begin until this Health and Safety Plan is submitted and approved by the Engineer.
- .4 CFB Gagetown Construction Engineering Branch employs a Lock Out/Tag Out Program to prevent work related injuries due to electrical or mechanical systems being energized while personnel are working in or around these
-

1.3 Responsibility (Cont'd) .4

(Cont'd)
systems. The Contractor must respect these locks and/or tags when encountered. Do not forcibly remove these locks and/or tags at any time. If the Contractor requires that these be removed to perform work, a request is to be made to the Engineer for such removal.

.5 As per the Canada Labour Code Part 2, it is the Contractor's responsibility to employ their own Lock Out/Tag Out program to ensure that equipment is not energized by other personnel while they are working in or around equipment.

.6 It is the Contractor's responsibility to ensure that all of their employees are provided all Personal Protective Equipment (PPE) necessary to perform all work. Hard hats, safety boots and safety glasses are to be worn at all times.

1.4 Unforeseen Hazards .1

Should any unforeseen or peculiar safety-related factor, hazard, or condition occur or become evident during performance of work, the Contractor must have procedures in place to facilitate Employee's Right to Refuse Work in accordance with Acts and Regulations of New Brunswick. The Contractor is to advise the Engineer verbally and in writing of any employee who exercises this right.

1.5 Correction of Non-Compliance .1

Immediately address health and safety non-compliance issues identified by authority having jurisdiction or by Engineer.

.2 Provide Engineer with written report of action taken to correct non-compliance of health and safety issues identified.

.3 Engineer may stop Work if non-compliance of health and safety regulations is not corrected.

1.6 Work Stoppage .1

Give precedence to safety and health of public and site personnel and protection of environment over cost and schedule considerations for Work.

PART 1 - GENERAL

- 1.1 Reporting Fires .1 Know location of nearest fire alarm box and telephone, including emergency phone number.
- .2 Report immediately all fire incidents to Fire Department as follows:
.1 activate nearest fire alarm box; or
.2 telephone 911.
- .3 When reporting fire by telephone, give location of fire, name or number of building and be prepared to verify the location.
- 1.2 Interior and Exterior Fire Protection and Alarm Systems .1 Fire protection and alarm system will not be:
.1 obstructed;
.2 shut-off; and
.3 left inactive at end of working day or shift without authorization from Fire Chief.
- .2 Fire hydrants, standpipes and hose systems will not be used for other than fire-fighting purposes unless authorized by Fire Chief.
- 1.3 Fire Extinguishers .1 Supply fire extinguishers, as scaled by Fire Chief, necessary to protect work in progress and contractor's physical plant on site.
- 1.4 Blockage of Roadways .1 Advise Fire Chief of any work that would impede fire apparatus response. This includes violation of minimum overhead clearance, as prescribed by Fire Chief, erecting of barricades and digging of trenches.
- 1.5 Smoking Precautions .1 Observe smoking regulations at all times.
- 1.6 Rubbish and Waste Materials .1 Rubbish and waste materials are to be kept to a minimum.
- .2 Burning of rubbish is prohibited.
-

- 1.6 Rubbish and Waste Materials (Cont'd)
- .3 Removal:
 - .1 Remove all rubbish from work site at end of work day or shift or as directed.
 - .4 Storage:
 - .1 Store oily waste in approved receptacles to ensure maximum cleanliness and safety.
 - .2 Deposit greasy or oily rags and materials subject to spontaneous combustion in approved receptacles and remove.
- 1.7 Flammable and Combustible Liquids
- .1 Handling, storage and use of flammable and combustible liquids are to be governed by the current National Fire Code of Canada.
 - .2 Flammable and combustible liquids such as gasoline, kerosene and naphtha will be kept for ready use in quantities not exceeding 45 litres provided they are stored in approved safety cans bearing Underwriters' Laboratory of Canada or Factory Mutual seal of approval. Storage of quantities of flammable and combustible liquids exceeding 45 litres for work purposes requires permission of Fire Chief.
 - .3 Transfer of flammable and combustible liquids is prohibited within buildings or jetties.
 - .4 Transfer of flammable and combustible liquids will not be carried out in vicinity of open flames or any type of heat-producing devices.
 - .5 Flammable liquids having a flash point below 38°C such as naphtha or gasoline will not be used as solvents or cleaning agents.
 - .6 Flammable and combustible waste liquids, for disposal, will be stored in approved containers located in a safe ventilated area. Quantities are to be kept to a minimum and Fire Department is to be notified when disposal is required.
- 1.8 Hazardous Substances
- .1 Work entailing use of toxic or hazardous materials, chemicals and/or explosives, or otherwise creating hazard to life, safety or health, will be in accordance with National Fire Code of Canada.

- 1.8 Hazardous Substances (Cont'd)
- .2 Obtain from Fire Chief a "Hot Work" permit for work involving welding, burning or use of blow torches and salamanders, in buildings or facilities.
 - .3 When Work is carried out in dangerous or hazardous areas involving use of heat, provide fire watchers equipped with sufficient fire extinguishers. Determination of dangerous or hazardous areas along with level of protection necessary for Fire Watch is at discretion of the Fire Chief. Contractors are responsible for providing fire watch service for work on a scale established and in conjunction with Fire Chief at pre-work conference.
 - .4 Where flammable liquids, such as lacquers or urethanes are to be used, proper ventilation will be assured and all sources of ignition are to be eliminated. Fire Chief is to be informed prior to and at cessation of such work.
- 1.9 Questions and/or Clarification
- .1 Direct any questions or clarification on Fire Safety in addition to above requirements to Fire Chief through the Engineer.
- 1.10 Fire Inspection
- .1 Site inspections by Fire Chief will be coordinated through Engineer.
 - .2 Allow Fire Chief unrestricted access to work site.
 - .3 Co-operate with Fire Chief during routine fire safety inspection of work site.
 - .4 Immediately remedy all unsafe fire situations observed by Fire Chief.

PART 1 - GENERAL

- 1.1 General .1 The Contractor will take all reasonable steps to ensure that they and their employees have complied with all pertinent legislation and have protected the environment.
- 1.2 Fires .1 Fires and burning of rubbish on site is not permitted.
- 1.3 Disposal of Wastes .1 Do not bury rubbish and waste materials on site unless approved by Engineer.
.2 Do not dispose of waste or volatile materials, such as mineral spirits, oil or paint thinner into waterways, storm or sanitary sewers.
.3 All potential hazardous wastes must be disposed of in the proper manner.
- 1.4 Spill Protection .1 The Contractor must have adequate clean up materials for any potential hazardous materials used in the completion of the work, ie: fuels, oils, lubricants, etc.
.2 In the event of a spill, the Contractor will immediately take corrective action to clean up the material.
.3 In the event of a spill over one (1) litre of a hazardous material, the Contractor will immediately inform the proper authorities at the CFB Gagetown Fire Department, telephone (506) 422-2000 extension 2106 and take necessary remedial action.
.4 The Contractor will inform the Engineer in writing of any spill, with details of any actions taken to remediate the spill and to prevent any reoccurrence.

PART 1 - GENERAL

- 1.1 General .1 This Section covers the particular testing criteria for the transformers located at CFB Gagetown.
- 1.2 Codes and Standards .1 Do complete testing in accordance with the the Standards listed in Section 00 21 13 - Part 1.11, except where specified otherwise.
- 1.3 Voltage Ratings .1 Operating voltages for the existing in service transformers is:
.1 Pad Mount transformers: 12.47 kV primary, 347/600 volts or 120/208 volts secondary.
.2 Pole mount transformers: 7.2 kV primary, 347 volts or 120/240 volts secondary.
- 1.4 Materials and Equipment .1 Provide materials and equipment in accordance with Section 00 21 13 - Instructions to Bidders.
.2 Equipment and material to be CSA certified. Where there is no alternative to supplying equipment which is not CSA certified, obtain special approval from the Engineer.
- 1.5 Co-ordination and Confirmation .1 Co-ordinate testing schedule with Engineer
Allow a minimum of ninety six (96) hours notice for scheduled power shut-downs.
Emergency power shut-downs are to be dealt with on an as needed basis.
-

PART 2 - TESTING

2.1 Testing
and Inspection

- .1 Pad mount transformers semi-annual inspection.
Note- The report will contain the below information;
 - .1 Visually check for fluid leaks in tanks and at bushings.
 - .2 Visually inspect for physical damages to the tank and fittings.
 - .3 Visually inspect high voltage bushings for cracks, chips and for deterioration.
 - .4 Visually check load break elbows and associated items for deterioration and fatigue.
 - .5 Check the integrity of secondary connections.
 - .6 Check the integrity of the grounding system.
 - .7 Check pressure relief valve, where applicable.
 - .8 Do load test on secondary conductors.
 - .9 Visually inspect pads and bollards.
 - .10 Check and verify location and name plate info (type, manufacturer, serial number, KVA, oil capacity, weight, % impedance, primary and secondary volts)
 - .11 Report findings for each transformer.

- .2 Pole mount transformers semi-annual inspection.
Note- The report will contain the below information;
 - .1 Visually check for fluid leaks in tanks and at bushings.
 - .2 Visually inspect for physical damages to the tank and bushings.
 - .3 Visually inspect high voltage bushings for cracks, chips and deterioration.
 - .4 Check integrity of primary connections.
 - .5 Check integrity of secondary connections.
 - .6 Check integrity of the grounding system.
 - .7 Check pressure relief valve, where applicable.
 - .8 Do load test on secondary conductors.
 - .9 Visually inspect pole condition.
 - .10 Check and verify name plate info (type, manufacturer, serial number, KVA, oil capacity, weight, % impedance, primary and secondary volts).
 - .11 Report findings for each transformer.

2.1 Testing
and Inspection
(Cont'd)

- .3 Infrared (IR) Inspection:
- .1 Conduct thermal infrared inspection on transformer and components for excessive heat levels to expose potential loose connections, load unbalance, faulty wiring and to roughly gauge the oil levels in the tanks.
 - .2 IR inspections are to be conducted in the month of July.

Note: the IR inspection is to be done only on the first year of the contract. No bid required for first/second option years.

Location	Manufacturer / Model	Serial Number	KVA	Sec Volts	Pri Volts	Type	Remarks
A-4	CARTE	20531-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
A-5	CARTE	20549-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
A-9	CARTE	20549-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
A-11	CARTE	20531-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
A-47	CARTE	3B042-001	1000	347/600	12.47 kV	PAD MOUNT	3 PHASE
A-48	CARTE	20534-002	225	120/208	12.47 kV	PAD MOUNT	3 PHASE
ROGERS TOWER	MOLONEY	379-231	50	120/240	7.2 kV	POLE	1 PHASE
ALIAANT TOWER FC	MOLONEY	A2724-637	15	120/240	7.2 kV	POLE	1 PHASE
ALIAANT TOWER PET	G E	1057034	37.5	120/240	7.2 kV	POLE	1 PHASE
AR-1	MOLONEY	A1743-272	75	120/240	7.2 kV	POLE	1 PHASE
AS1-1	CARTE	2A1870-001	25	120/240	7.2 kV	POLE	1 PHASE
AS1-1	CARTE	2A1870-002	25	120-240	7.2 kV	POLE	1 PHASE
AS1-1	CARTE	2A1870-003	25	120-240	7.2 kV	POLE	1 PHASE
AS1-2	CARTE	2A1869-001	10	120-240	7.2 kV	POLE	1 PHASE
AS1-2	CARTE	2A1869-002	10	120-240	7.2 kV	POLE	1 PHASE
AS1-2	CARTE	2A1869-003	10	120-240	7.2 kV	POLE	1 PHASE
AS1-2	CARTE	2A2070-001	25	4160/24	12.47 kV	PAD MOUNT	3 PHASE
AS1-4	MOLONEY	A1737-568	15	120/240	7.2 kV	POLE	1 PHASE
AV-1	WESTINGHOUSE	171E0228-	10	120-240	7.2 kV	POLE	1 PHASE
AV-1	G E	921506	100	120-240	7.2 kV	POLE	1 PHASE
AV-4	CARTE	U0742-001	15	120-240	7.2 kV	POLE	1 PHASE
B-1	CARTE	20531-002	150	120-208	12.47 kV	PAD MOUNT	3 PHASE
B-3 (POLE A8)	MOLONEY	A4095-2	15	120/240	7.2 kV	POLE	1 PHASE
B-6	CARTE	20531-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-6	CARTE	20532-001	150	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-7	CARTE	20532-002	150	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-9	CARTE	20538-001	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-10	CARTE	20534-004	225	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-10	CARTE	20537-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-12	PIONEER	G956201	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-14	COOPER	979007149	112.5	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-18	CARTE	20595-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-18	CARTE	20536-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-18 (STORAGE)	CARTE	20535-001	225	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-18 (STORAGE)	WESTINGHOUSE	87-03E1387-	15	120/240	7.2	POLE	1 PHASE
B-18 (STORAGE)	CARTE	2B321-001	750	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-18 (STORAGE)	CARTE	00539-3	50	347	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A2164-467	25	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A1739-342	50	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	LE10890	75	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A2165-471	50	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A2344-239	25	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	CARTE	00539-2	50	347	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A1739-343	50	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	571/126	25	120/240	7.2 kV	POLE	1 PHASE
B-18 (STORAGE)	MOLONEY	A4697-1	25	120/240	7.2 kV	POLE	1 PHASE
B-19	CARTE	7933-002	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-23	CARTE	20527-001	30	120/208	12.47 kV	PAD MOUNT	3 PHASE
B-341							
B-58	CARTE	10403-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
B-59	MOLONEY	A1743-518	75	120/240	7.2 kV	POLE	1 PHASE
B-69	MOLONEY	A3263-1114	25	120/240	7.2 kV	POLE	1 PHASE
BIO PAD	MOLONEY	A698-143	10	120/240	7.2 kV	POLE	1 PHASE
C-7	CARTE	18841-001	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
C-8	CARTE	20532-001	150	347/600	12.47 kV	PAD MOUNT	3 PHASE
C-9	PIONEER	6-9089-1	750	347/600	12.47 kV	PAD MOUNT	3 PHASE
CWES BUILDING	CARTE	12958-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
CHAMBERLAIN AVE CAMERA							
D-4	CARTE	20531-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-5	CARTE	20534-001	225	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-5	CARTE	20530-001	75	4160	12.47 kV	PAD MOUNT	3 PHASE
D-9	CARTE	20550-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-10	CARTE	18843-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
D-15	CARTE	20550-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-17	CARTE	7932-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-22	CARTE	20536-002	300	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-23	CARTE	5284-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-24	CAM TRAN CO	02C167550	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-25	CARTE	5283-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-27	CARTE	5284-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
D-55	CARTE	13626-001	150	347/600	12.47 kV	PAD MOUNT	3 PHASE

D-56	PIONEER	G12889-1	750	347/600	12.47 kV	PAD MOUNT	3 PHASE
D-57	CARTE	18483-001	1500	347/600	12.47 kV	PAD MOUNT	3 PHASE
D-58	COOPER	750010183	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
D-59	CARTE	20570-001	1000	347/600	12.47 kV	PAD MOUNT	3 PHASE
D-60			750	347/600	12.47 kV	PAD MOUNT	3 PHASE
EN-3	MOLONEY	ARP1287A-	15	120/240	7.2 kV	POLE	1 PHASE
EN-4	MOLONEY	ARP1287A-	15	120/240	7.2 kV	POLE	1 PHASE
F-1	CARTE	20550-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
F-2	CARTE	20550-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
F-6	CARTE	20549-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
F-12	CARTE	5235-001	300	347/600	12.47	PAD MOUNT	3 PHASE
F-18	CARTE	20534-003	225	120/208	12.47 kV	PAD MOUNT	3 PHASE
F-19	CARTE	23396-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
FFTA	MOLONEY	A3262-880	15	120/240	7.2 kV	POLE	1 PHASE
G-1	CARTE	7930-001	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
G-3	CARTE	7932-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
G-8							
GANONG ST. POLE 16	MOLONEY	A1737-569	15	120/240	7.2 kV	POLE	1 PHASE
GANONG ST. POLE 19	MOLONEY	A3263-228	25	120/240	7.2 kV	POLE	1 PHASE
GANONG ST. POLE 19	MOLONEY	A3263-241	25	120/240	7.2 kV	POLE	1 PHASE
GANONG ST. POLE 19	MOLONEY	A3263-243	25	120/240	7.2 kV	POLE	1 PHASE
GANONG ST. POLE 30	MOLONEY	468-155	10	120/240	7.2 kV	POLE	1 PHASE
GANONG ST. POLE 57	G E	672278	10	120/240	7.2 kV	POLE	1 PHASE
GANONG ST/ CHAMPLAIN							
H-1	CARTE	5284-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-3	CARTE	5283-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-7	CARTE	20551-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-8	CARTE	20533-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-10	CARTE	14846-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
H-12	CARTE	18842-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-14	CARTE	20552-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-16	CARTE	20552-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-17	CARTE	6787-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
H-19	CARTE	20551-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-20	CARTE	20551-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-21	CARTE	5283-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-23	CARTE	5283-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
H-33	CARTE	8335-001	1500	347/600	12.47	PAD MOUNT	3 PHASE
H-34	CARTE	11883-001	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
J-1	CARTE	20551-004	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
J-7	FEDERAL	C-7828-1	833	347/600	7.2 kV	FLOOR	1 PHASE
J-7	FEDERAL	C-7828-2	833	347/600	7.2 kV	FLOOR	1 PHASE
J-7	FEDERAL	C-7828-3	833	347/600	7.2 kV	FLOOR	1 PHASE
J-8/9	CARTE	1B080-001	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
J-10	CARTE	2B257-001	2000	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-1	REX MFG.	C24388	225	120/208	12.47 kV	CABINET	3 PHASE
K-4	CARTE	3B212-001	1000	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-6	CARTE		150	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-6	MOLONEY	6611026C	25	120/240	7.2 kV	POLE	1 PHASE
K-8			150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-10	CARTE	7933-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-13	CARTE	7932-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-14	CARTE	22035-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-15	CARTE	20538-002	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-16	CARTE	22035-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-17	CARTE	13437-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-18	CARTE	22114-001	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-19	CARTE	2214-002	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-20 SITE	MOLONEY	A4095-239	15	120/240	7.2 kV	POLE	1 PHASE
K-20 BULK	HAMMOND	DB00C45	112.5	347/600	12.47 kV	CABINET	3 PHASE
K-26	MOLONEY	A1555-132	15	120/240	7.2 kV	POLE	1 PHASE
K-38	MOLONEY	A2343-267	15	120/240	7.2 kV	POLE	1 PHASE
K-39	SIEMENS	63903-334	50	120/240	7.2 kV	POLE	1 PHASE
K-39	SIEMENS	63903-357	50	120/240	7.2 kV	POLE	1 PHASE
K-39	SIEMENS	63903-369	50	120/240	7.2 kV	POLE	1 PHASE
K-46	MOLONEY	A2005-150	15	120/240	7.2 kV	POLE	1 PHASE
K-60	CARTE	4B220-001	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
K-61	CARTE	20528-001	45	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-63	CARTE	20529-001	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-69	MOLONEY	A4101-7	25	347/600	7.2 kV	POLE	1 PHASE
K-69	MOLONEY	A4101-23	25	347/600	7.2 kV	POLE	1 PHASE

Annex A
L-G2-9900/1611
14 May 2013
CFB Gagetown Transformer Inventory

K-69	MOLONEY	A43268-64	25	347/600	7.2 kV	POLE	1 PHASE
K-71	MOLONEY	A4097-134	50	120/240	7.2 kV	POLE	1 PHASE
K-71	MOLONEY	A4097-409	50	120/240	7.2 kV	POLE	1 PHASE
K-71	MOLONEY	A3264-2012	50	120/240	7.2	POLE	1 PHASE
K-73	CARTE	22035-003	150	120/208	12.47 kV	PAD MOUNT	3 PHASE
K-75	MOLONEY	A1738-915	25	120/240	7.2 kV	POLE	1 PHASE
K-75	MOLONEY	A1738-916	25	120/240	7.2 kV	POLE	1 PHASE
K-75	MOLONEY	A1738-918	25	120/240	7.2 kV	POLE	1 PHASE
K-79	MOLONEY	A002-147	10	120/240	7.2 kV	POLE	1 PHASE
K-79	G E	2337	10	120/240	7.2 kV	POLE	1 PHASE
K-79	G E	858762	10	120/240	7.2 kV	POLE	1 PHASE
K-88	MOLONEY	A2725-57	25	120/240	7.2 kV	POLE	1 PHASE
K-88	MOLONEY	A2725-58	25	120/240	7.2 kV	POLE	1 PHASE
K-88	MOLONEY	A2725-61	25	120/240	7.2 kV	POLE	1 PHASE
K-92							
K-330	MOLONEY	A4457-10	15	120/240	7.2 kV	POLE	1 PHASE
L-3 WATER TOWER	MOLONEY	A1739-378	50	120/240	7.2 kV	POLE	1 PHASE
L-3 RETS 2	MOLONEY	A2513-16	50	120/240	7.2 kV	POLE	1 PHASE
L-3 RETS 2	MOLONEY	A2513-49	50	120/240	7.2 kV	POLE	1 PHASE
L-3 RETS 2	MOLONEY	A2513- 50	50	120/240	7.2 kV	POLE	1 PHASE
L-24	FEDERAL	G-8616	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
L-27	MOLONEY	A1743-322	75	120/240	7.2 kV	POLE	1 PHASE
L-27	MOLONEY	A1743-325	75	120/240	7.2 kV	POLE	1 PHASE
L-27	MOLONEY	A1743-327	75	120/240	7.2 kV	POLE	1 PHASE
L-32	TRANS CANADA	124B1000-	1000	347/600	12.47 kV	PAD MOUNT	3 PHASE
L-33	BROWN	98J586316	1000	347/600	12.47 kV	PAD MOUNT	3 PHASE
L-37 (Service was changed)	CARTE	411-001	75	120/208	12.47	PAD MOUNT	3 PHASE
L-38	SURPLEX	301-615	50	120/240	7.2 kV	POLE	1 PHASE
L-38	SURPLEX	301690-218	50	120/240	7.2 kV	POLE	1 PHASE
L-38	SURPLEX	17E0216-	10	120/240	7.2 kV	POLE	1 PHASE
L-100	MOLONEY	A1739 372	50	120/240	7.2 kV	POLE	1 PHASE
L-102	MOLONEY	20792-2	75	120/240	7.2 kV	POLE	1 PHASE
L-103	MOLONEY	A1739-376	50	120/240	7.2 kV	POLE	1 PHASE
L-108	MOLONEY	A1739-344	50	120/240	7.2 kV	POLE	1 PHASE
L-110	MOLONEY	A1739-371	50	120/240	7.2 kV	POLE	1 PHASE
L-111	MOLONEY	A1739-375	50	120/240	7.2 kV	POLE	1 PHASE
LV-9	MOLONEY	551-73	50	120/240	7.2 kV	POLE	1 PHASE
LV-9	MOLONEY	551-77	50	120/240	7.2 kV	POLE	1 PHASE
LV-9	MOLONEY	551-83	50	120/240	7.2 kV	POLE	1 PHASE
LW-3	MOLONEY	A2013-19	75	347/600	7.2 kV	POLE	1 PHASE
LW-3	MOLONEY	A1748-33	75	347/600	7.2 kV	POLE	1 PHASE
LW-3	MOLONEY	A4464-88	74	347/600	7.2 kV	POLE	1 PHASE
LW-4	MOLONEY	201497-65	50	120/240	7.2 kV	POLE	1 PHASE
LW-4	MOLONEY	201497-67	50	120/240	7.2 kV	POLE	1 PHASE
LW-4	MOLONEY	201497-72	50	120/240	7.2 kV	POLE	1 PHASE
M-2	CARTE	5952-001	750	347/600	12.47 kV	PAD MOUNT	3 PHASE
M-2 TRACK	MOLONEY	LC13275	15	120/240	7.2 kV	POLE	1 PHASE
M-5	PIONEER	C9844-1	167	347/600	7.2 kV	POLE	1 PHASE
M-5	PIONEER	C9844-2	167	347/600	7.2 kV	POLE	1 PHASE
M-5	PIONEER	C9844-3	167	347/600	7.2 kV	POLE	1 PHASE
M-6	MOLONEY	A3262-943	15	120/240	7.2 kV	POLE	1 PHASE
M-6	MOLONEY	A3262-977	15	120/240	7.2 kV	POLE	1 PHASE
M-6	MOLONEY	A3262-978	15	120/240	7.2 kV	POLE	1 PHASE
MA-22	CARTE	7B214-001	300	120/208	12.47 kV	PAD MOUNT	3 PHASE
MA-23	CARTE	7B213-002	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
MA-36	CARTE	511-011	15	120/240	7.2 kV	POLE	1 PHASE
MA-36	CARTE	ZB213-001	75	120/208	12.47 kV	PAD MOUNT	3 PHASE
MA-40	CARTE	21284-001	500	347/600	12.47 kV	PAD MOUNT	3 PHASE
MA-43	CARTE	3B360-001	300	347/600	12.47 kV	PAD MOUNT	3 PHASE
MR-1	MOLONEY	A2164-410	25	120/240	7.2 kV	POLE	1 PHASE
MR-2	PIONEER	G-10293-1	25	120/240	7.2 kV	POLE	1 PHASE
N-6	MOLONEY	468-143	15	120/240	7.2 kV	POLE	1 PHASE
N-38	MOLONEY	551-78	50	120/240	7.2 kV	POLE	1 PHASE
N-39	MOLONEY	551-39	50	120/240	7.2 kV	POLE	1 PHASE
N-45	MOLONEY	550-134	25	120/240	7.2 kV	POLE	1 PHASE
N-45	MOLONEY	550-141	25	120/240	7.2 kV	POLE	1 PHASE
N-45	MOLONEY	550-144	25	120/240	7.2 kV	POLE	1 PHASE
N-63	MOLONEY	551-54	50	120/240	7.2 kV	POLE	1 PHASE
N-68	WESTINGHOUSE	87-03E17-	50	120/240	7.2 kV	POLE	1 PHASE
N-75	MOLONEY	551-75	50	120/240	7.2 kV	POLE	1 PHASE
N-82	WESTINGHOUSE	87-03E17-	50	120/240	7.2 kV	POLE	1 PHASE
N-89	MOLONEY	551-51	50	120/240	7.2 kV	POLE	1 PHASE

Annex A
L-G2-9900/1611
14 May 2013
CFB Gagetown Transformer Inventory

N-104	CARTE	T1873-001	50	120/240	7.2 kV	POLE	1 PHASE
N-104	CARTE	T1873-002	50	120/240	7.2 kV	POLE	1 PHASE
N-104	CARTE	T1873-003	50	120/240	7.2 kV	POLE	1 PHASE
N-107	MOLONEY	551-89	50	120/240	7.2 kV	POLE	1 PHASE
N-116	MOLONEY	A2-166-19	75	120/240	7.2 kV	POLE	1 PHASE
N-118	MOLONEY	A2726-50	50	120/240	7.2 kV	POLE	1 PHASE
N-118	MOLONEY	A2726-51	50	120/240	7.2 kV	POLE	1 PHASE
N-118	MOLONEY	A2726-56	50	120/240	7.2 kV	POLE	1 PHASE
N-119	MOLONEY	A1218-15	100	120/240	7.2 kV	POLE	1 PHASE
N-120	MOLONEY	A121109-56	100	120/240	7.2 kV	POLE	1 PHASE
N-121	MOLONEY	ATL-1466-	100	120/240	7.2 kV	POLE	1 PHASE
N-123	G E	004-1280	25	120/240	7.2 kV	POLE	1 PHASE
N-124	MOLONEY	A2164-413	25	120/240	7.2 kV	POLE	1 PHASE
N-125	MOLONEY	A4458-3	50	120/240	7.2 kV	POLE	1 PHASE
N-125	MOLONEY	A4458-4	50	120/240	7.2 kV	POLE	1 PHASE
N-125	MOLONEY	A4458-8	50	120/240	7.2 kV	POLE	1 PHASE
N-329	MOLONEY	551-76	50	120/240	7.2 kV	POLE	1 PHASE
PC-19	MOLONEY	A3262-519	15	120/240	7.2 kV	POLE	1 PHASE
PC-29	MOLONEY	A1559-1-5	25	120/240	7.2 kV	POLE	1 PHASE
PC-33	G E	800-51291	37.5	120/240	7.2 kV	POLE	1 PHASE
PC-35	MOLONEY	A2725-266	25	120/240	7.2 kV	POLE	1 PHASE
PC-35	MOLONEY	ATL955-337	25	120/240	7.2 kV	POLE	1 PHASE
PC-35	CARTE	L0197-6	25	120/240	7.2 kV	POLE	1 PHASE
PC-42	G E	490850	10	120/240	7.2 kV	POLE	1 PHASE
PC-43	MOLONEY	381-19	75	120/240	7.2 kV	POLE	1 PHASE
PC-43	MOLONEY	381-25	75	120/240	7.2 kV	POLE	1 PHASE
PC-43	MOLONEY	381-29	75	120/240	7.2 kV	POLE	1 PHASE
PC-48	FIRENTI	2-156-775	50	347/600	7.2 kV	POLE	1 PHASE
PC-48	FIRENTI	2-156-777	50	347/600	7.2 kV	POLE	1 PHASE
PC-48	FIRENTI	2-156-777	50	347/600	7.2 kV	POLE	1 PHASE
PC-53	MOLONEY	APR1050-	25	120/240	7.2 kV	POLE	1 PHASE
PC-56	MOLONEY	A1738-1359	25	120/240	7.2 kV	POLE	1 PHASE
PC-58	MOLONEY	A1738-1352	25	120/240	7.2 kV	POLE	1 PHASE
PC-100	WESTINGHOUSE	C72R115	37.5	120/240	7.2 kV	POLE	1 PHASE
PC-101	MOLONEY	A2344-318	25	120/240	7.2 kV	POLE	1 PHASE
PC-104	MOLONEY	A2614-429	25	120/240	7.2 kV	POLE	1 PHASE
PC-105	WESTINGHOUSE	LL22262	25	120/240	7.2 kV	POLE	1 PHASE
PC-316	G E	800-61024	50	120/240	7.2 kV	POLE	1 PHASE
PC- HIGHWAY	MOLONEY	ARP1058-	15	120/240	7.2 kV	POLE	1 PHASE
PC-POL	WESTINGHOUSE	89-03E47-	50	347/600	7.2 kV	POLE	1 PHASE
PC-POL	WESTINGHOUSE	89-03F47-	50	347/600	7.2 kV	POLE	1 PHASE
PC-POL	MOLONEY	A1-523-42	50	347/600	7.2 kV	POLE	1 PHASE
PC-POL	MOLONEY	ATL1213-	25	120/240	7.2 kV	POLE	1 PHASE
RR-8	MOLONEY	383-506	25	120/240	7.2 kV	POLE	1 PHASE
RR-12	G E	6895-001	10	120/240	7.2 kV	POLE	1 PHASE
RR-14	CARTE	543001	50	120/240	7.2 kV	POLE	1 PHASE
RR-15	WESTINGHOUSE	87-03E1387-	15	120/240	7.2 kV	POLE	1 PHASE
RWR-1	MOLONEY	381-56	75	120/240	7.2 kV	POLE	1 PHASE
RWR-1	CARTE	6895-001	75	120/240	7.2 kV	POLE	1 PHASE
Repel Tower (Beside M2)							
STREET LITE-ALDER ST	WESTINGHOUSE	713097	10	120/240	7.2 kV	POLE	1 PHASE
STREET LITE-F ZONE	RELIANT	8712	15	120/240	7.2 kV	POLE	1 PHASE
SW-6	MOLONEY	A2033-1	15	120/240	7.2 kV	POLE	1 PHASE
SW-6	MOLONEY	A2033-2	15	120/240	7.2 kV	POLE	1 PHASE
SW-6	MOLONEY	A2033-3	15	120/240	7.2 kV	POLE	1 PHASE
SW-8	WESTINGHOUSE	LD59197	75	347/600	7.2 kV	POLE	1 PHASE
SW-8	MOLONEY	A2034-1	75	347/600	7.2 kV	POLE	1 PHASE
SW-8	MOLONEY	A2034-2	75	347/600	7.2 kV	POLE	1 PHASE
SW-8	MOLONEY	A2034-3	75	347/600	7.2 kV	POLE	1 PHASE
TA-1	MOLONEY	A1738-485	25	120/240	7.2 kV	POLE	1 PHASE
TA-10	MOLONEY	A1738-491	25	120/240	7.2 kV	POLE	1 PHASE
TB-11	WESTINGHOUSE	713437	10	120/240	7.2 kV	POLE	1 PHASE
TB-16	MOLONEY	A2724-93	15	120/240	7.2 kV	POLE	1 PHASE
TB-18	MOLONEY	A1737-496	15	120/240	7.2 kV	POLE	1 PHASE
TB-21	WESTINGHOUSE	17EOZ28-	10	120/240	7.2 kV	POLE	1 PHASE
TB-22	MOLONEY	A2005-279	15	120/240	7.2 kV	POLE	1 PHASE
VR-1	MOLONEY	A2164-408	25	120/240	7.2 kV	POLE	1 PHASE
VR-2	PIONEER	G10293-2	25	120/240	7.2 kV	POLE	1 PHASE
WALKING TRAIL	MOLONEY	A2343-277	15	120/240	7.2 kV	POLE	1 PHASE
WALKING TRAIL	G E	2845	10	120/240	7.2 kV	POLE	1 PHASE

Annex A
L-G2-9900/1611
14 May 2013

CFB Gagetown Transformer Inventory

WTP-4	MOLONEY	A2725-268	25	120/240	7.2 kV	POLE	1 PHASE
WTP-100	MOLONEY	A2725-271	25	120/240	7.2 kV	POLE	1 PHASE
PC HIGHWAY 7	WESTINGHOUSE	LC27-435	10	120/240	7.2 kV	POLE	1 PHASE

Annex B
 L-G2-9900/1611
 14-May-13

Detachment Moncton Transformer list

Location	Manufacturer/Model	Serial Number	KVA	Sec Volts	Pri Volts	Type	Remarks
MONCTON BLDG 47/48	CARTE	1B039-001	500	347/600	12.47 Kv	PAD MOUNT	3 PHASE
MONCTON BLDG 47/48	CARTE	2B179-001	150	120/208	12.47 Kv	PAD MOUNT	3 PHASE
MONCTON BLDG 1	MALONEY	A1920-3	50	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 1	MALONEY	A1920-1	50	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 1	MALONEY	A1920-2	50	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 2	MALONEY	866/52	75	600	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 2	MALONEY	866/48	75	600	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 2	MALONEY	866/38	75	600	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 42	WESTINGHOUSE	8903E4766-008	100	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 2 (BACKSIDE)	WESTINGHOUSE	8903E4766-001	100	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 60A	WESTINGHOUSE	89-03E-4762-019	75	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 60A	WESTINGHOUSE	89-03E-4762-024	75	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 60A	WESTINGHOUSE	89-03E-4762-022	75	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 60	CARTE	T0191-003	50	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 60	CARTE	T0191-001	50	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 52	RELIANT	KW8855-8	100	120/240	12.47 Kv	POLE	1 PHASE
MONCTON BLDG 70	FERRANTI PACKARD	110925	50	120/240	12.47 Kv	POLE	1 PHASE