

Part 1 General

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B16.1, Cast Iron Pipe Flanges and Flanged Fittings.
 - .2 ASME B16.3, Malleable Iron Threaded Fittings.
 - .3 ASME B16.5, Pipe Flanges and Flanged Fittings.
 - .4 ASME B16.9, Factory-Made Wrought Butt welding Fittings.
 - .5 ASME B18.2.1, Square and Hex Bolts and Screws (Inch Series).
 - .6 ASME B18.2.2, Square and Hex Nuts (Inch Series).
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A47/A47M, Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A53/A53M, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
 - .3 ASTM A536-[84(1999)e1], Standard Specification for Ductile Iron Castings.
 - .4 ASTM B61-[02], Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B62, Standard Specification for Composition Bronze or Ounce Metal Castings.
- .3 American Water Works Association (AWWA).
 - .1 AWWA C111, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .4 Manufacturer's Standardization of the Valve and Fittings Industry (MSS).
 - .1 MSS-SP-67, Butterfly Valves.
 - .2 MSS-SP-70, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71, Cast Iron Swing Check Valves Flanged and Threaded Ends.
 - .4 MSS-SP-80, Bronze Gate, Globe, Angle and Check Valves.
 - .5 MSS-SP-85, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 SUBMITTALS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Closeout Submittals.
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals and include following:

1.3 QUALITY ASSURANCE

- .1 Health and Safety.
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal.

1.5 MAINTENANCE

- .1 Extra Materials.
 - .1 Provide following spare parts:
 - .1 Valve seats: one for every ten valves, each size. Minimum one.
 - .2 Discs: one for every ten valves, each size. Minimum one.
 - .3 Stem packing: one for every ten valves, each size. Minimum one.
 - .4 Valve handles: two of each size.
 - .5 Gaskets for flanges: one for every ten flanges.

Part 2 Products

2.1 PIPE

- .1 Steel pipe: to ASTM A53/A53M, Grade B, as follows:
 - .1 To NPS6:

2.2 PIPE JOINTS

- .1 NPS2 and under: screwed fittings with PTFE tape or lead-free pipe dope.
- .2 Pipe thread: taper.

2.3 FITTINGS

- .1 Screwed fittings: malleable iron, to ASME B16.3, Class 150.
- .2 Unions: malleable iron, to ASTM A47/A47M and ASME B16.3.

2.4 VALVES

- .1 Connections:
 - .1 NPS2 and smaller: screwed ends.
- .2 Gate valves: to MSS-SP-70 Application: Isolating equipment, control valves, pipelines.
 - .1 NPS2 and under:
 - .1 Mechanical Rooms. Class 125, rising stem, split wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .3 Balancing, for TAB:
 - .1 Sizes: Calibrated balancing valves, as specified this section.
 - .2 NPS2 and under:
 - .1 Mechanical Rooms: Globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.

- .4 Drain valves: Gate, Class 125, non-rising stem, solid wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .5 Swing check valves: to MSS-SP-71.
 - .1 NPS2 and under:
 - .1 Class 125, swing, with composition disc, as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 NPS2 1/2 and over:
- .6 Silent check valves:
 - .1 NPS2 and under:
 - .1 As specified Section 23 05 23.01 - Valves - Bronze.
- .7 Ball valves:
 - .1 NPS2 and under: as specified Section 23 05 23.01 - Valves - Bronze.

Part 3 Execution

3.1 PIPING INSTALLATION

- .1 Install pipework in accordance with Section 23 05 01 - Installation of Pipe Work.

3.2 CLEANING, FLUSHING AND START-UP

- .1 In accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

3.3 TESTING

- .1 Test system in accordance with Section 21 05 01 - Common Work Results for Mechanical.

3.4 BALANCING

- .1 Balance water systems to within plus or minus 5% of design output.
- .2 Refer to Section 23 05 93 - Testing, Adjusting and Balancing for HVAC for applicable procedures.

END OF SECTION