

Part 1 General

1.1 REFERENCES

- .1 American National Standards Institute (ANSI)/American Welding Society (AWS)
 - .1 ANSI/AWS A5.8/A5.8M, Specification Filler Metals for Brazing and Bronze Welding.
- .2 American Society of Mechanical Engineers (ASME)
 - .1 ANSI/ASME B16.4, Gray-Iron Threaded Fittings.
 - .2 ANSI/ASME B16.15, Cast Bronze Threaded Fittings.
 - .3 ANSI B16.18, Cast Copper Alloy, Solder Joint Pressure Fittings.
 - .4 ANSI/ASME B16.22, Wrought Copper and Copper -Alloy Solder Joint Pressure Fittings.
- .3 American Society for Testing and Materials International (ASTM)
 - .1 ASTM B32, Standard Specification for Solder Metal.
 - .2 ASTM B61, Standard Specification for Steam or Valve Bronze Castings.
 - .3 ASTM B62, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .4 ASTM B88M, Standard Specification for Seamless Copper Water Tube Metric.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 Manufacturers Standardization Society (MSS)
 - .1 MSS SP67, Butterfly Valves.
 - .2 MSS SP70, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS SP80, Bronze Gate, Globe, Angle and Check Valves.
 - .4 MSS SP85, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Indicate on manufacturers catalogue literature the following: VALVES.
- .3 Quality assurance submittals: submit follow ing in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .2 Instructions: submit manufacturer's installation instructions.
- .4 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.3 QUALITY ASSURANCE

- .1 Regulatory Requirements: ensure Work is performed in compliance with CEPA, and applicable Provincial /Territorial regulations.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.4 MAINTENANCE

- .1 Extra Materials:
 - .1 Furnish following spare parts:
 - .1 Valve seats: one for every ten valves, each size. Minimum one.
 - .2 Discs: one for every ten valves, each size. Minimum one.
 - .3 Stem packing: one for every ten valves, each size. Minimum one.
 - .4 Valve handles: two of each size.
 - .5 Gaskets for flanges: one for every ten flanges.

1.5 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.

Part 2 Products

2.1 TUBING

- .1 Type A hard drawn copper tubing: to ASTM B88M.

2.2 FITTINGS

- .1 Cast bronze threaded fittings: to ANSI/ASME B16.15.
- .2 Wrought copper and copper alloy solder joint pressure fittings: to ANSI/ASME B16.22.
- .3 Cast iron threaded fittings: to ANSI/ASME B16.4.
- .4 Cast copper alloy solder joint pressure fittings: to ANSI B16.18.

2.3 FLANGES

- .1 Brass or bronze: threaded.
- .2 Cast iron: threaded.
- .3 Orifice flanges: slip-on, raised face, 2100 kPa.

2.4 JOINTS

- .1 Solder, tin-antimony, 95:5: to ASTM B32.
- .2 Silver solder BCUP: to ANSI/AWS A5.8.
- .3 Brazing: as indicated.

2.5 VALVES

- .1 Connections:
 - .1 NPS 2 and smaller: ends for soldering.
- .2 Gate Valves Application: isolating equipment, control valves, pipelines:
 - .1 NPS 2 and under:
 - .1 Mechanical Rooms: Class 125, rising stem wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .3 Globe valves: Application: throttling, flow control, emergency bypass:
 - .1 NPS 2 and under:
 - .1 Mechanical Rooms: with PTFE disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .4 Balancing, for TAB:
 - .1 Sizes: calibrated balancing valves, as specified.
 - .2 NPS 2 and under:
 - .1 Mechanical Rooms: globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.
- .5 Drain valves: gate, Class 125, non-rising stem, solid wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .6 Swing check valves:
 - .1 NPS 2 and under:
 - .1 Class 125, swing, with composition disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .7 Ball valves:
 - .1 NPS 2 and under: as specified Section 23 05 23.01 - Valves - Bronze.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PIPING INSTALLATION

- .1 Connect to equipment in accordance with manufacturer's instruction unless otherwise indicated.
- .2 Install concealed pipes close to building structure to keep furring space to minimum. Install to conserve headroom and space. Run exposed piping parallel to walls. Group piping where ever practical.
- .3 Slope piping in direction of drainage and for positive venting.
- .4 Use eccentric reducers at pipe size change installed to provide positive drainage or positive venting.
- .5 Provide clearance for installation of insulation and access for maintenance of equipment, valves and fittings.
- .6 Assemble piping using fittings manufactured to ANSI standards.

3.3 VALVE INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Install ball valves at branch take-offs and to isolate each piece of equipment, and as indicated.
- .3 Install globe valves for balancing and in by-pass around control valves as indicated.
- .4 Install swing check valves in horizontal lines on discharge of pumps and as indicated.

3.4 FLUSHING AND CLEANING

- .1 Flush and clean in presence of Departmental Representative.
- .2 Flush after pressure test for a minimum of 4h.
- .3 Fill with solution of water and non-foaming, phosphate-free detergent 3% solution by weight. Circulate for minimum of 8h.
- .4 Refill system with clean water. Circulate for at least 4h. Clean out strainer screens/baskets regularly. Then drain.
- .5 Refill system with clean water. Circulate for at least 2h. Clean out strainer screens/baskets regularly. Then drain.

- .6 Drainage to include drain valves, dirt pockets, strainers, low points in system.
- .7 Re-install strainer screens/baskets only after obtaining Departmental Representative's approval.

3.5 CIRCUIT BALANCING VALVES

- .1 Install flow measuring stations and flow balancing valves as indicated.
- .2 Remove handwheel after installation and TAB is complete.

3.6 FIELD QUALITY CONTROL

- .1 Testing:
 - .1 Test system in accordance with Section 21 05 01 - Common Work Results for Mechanical.
- .2 Balancing:
 - .1 Balance water systems to within plus or minus 5% of design output.

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION