

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results – Electrical.

1.2 REFERENCES

- .1 American National Standards Institute /Institute of Electrical and Electronics Engineers (ANSI/IEEE)
 - .1 ANSI/IEEE 837-02, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.
- .2 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-12, Canadian Electrical Code, Part 1 (22nd Edition), Safety Standard for Electrical Installations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect grounding equipment from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 EQUIPMENT

- .1 Ground Ball Stud:
 - 1. Nominal 25.4 mm diameter ball and 114 mm overall length
 - 2. Tin plated bronze alloy
 - 3. 400 amps continuous current rating
 - 4. Fault withstanding current: 43,000 amps for 15 cycles, 30,000 amps for 30 cycles

- .2 Grounding conductors: bare stranded copper, tinned, soft annealed, size as indicated, minimum #2/0 AWG.
- .3 Insulated grounding conductors: green, copper conductors, size as indicated, minimum #2/0 AWG.
- .4 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Compression connectors

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate are acceptable for grounding equipment installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including conductors, connectors, accessories.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Provide supports to secure ground wires properly
- .4 Protect grounding conductors from any possible injury.
- .5 Make connections to ground electrodes, using copper compression connectors to ANSI/IEEE 837.
- .6 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .7 Soldered joints not permitted.
- .8 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.
- .9 Bond metallic armoured cables and splice kits to ground.

3.3 MAINTENANCE HOLES

- .1 Connect support brackets of cables, structural steel and metal parts to ground by welding copper to steel.
- .2 Replace undersized ground wire with a minimum #2/0 AWG stranded copper conductor.
- .3 Confirm ground resistance meets or exceeds Canadian Electrical Code minimum requirements.

3.4 Ball Studs

- .1 Install ball studs permanently mounted on the bus of the switchgear “SG-1” as indicated on the drawings. Provide one ball stud on each phase bus and three studs on the ground bus to allow for de-energizing feeders to ground, when needed.

3.5 ELECTRODES

- .1 Electrodes are existing in each maintenance hole.
- .2 Use minimum size 2/0 AWG copper conductors for connections to electrodes.

3.6 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform ground resistance and continuity tests before energizing electrical system.

3.7 CLEANING

- .1 Progress Cleaning
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.
- .3 Waste Management: separate waste materials for recycling.
- .4 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION