



SUPPLY AND INSTALL NEW SERVICE GROUND CONDUCTOR (MINIMUM #6 AWG BARE COPPER) AND NEW GROUND RODS.

NEW OUTLET

EXISTING FPE STABLOK COMBINATION TYPE LOAD CENTRE SERVICE PANEL

EXISTING HEATING CONTROL PANEL

EXISTING WASHROOM LIGHTING CONTROL TIME CLOCK

NEW EXTERIOR LIGHTING CONTROL TIME CLOCK AND CONTROL PANEL. SEE DETAIL 1/E2

### ELECTRICAL SYMBOL LEGEND

- FLUORESCENT LUMINAIRE
- WALL MOUNTED LUMINAIRE (REFER TO LUMINAIRE SCHEDULE)
- PHOTOCELL
- SINGLE POLE SWITCH
- MOTION SENSOR SWITCH
- DUPLEX RECEPTACLE
- GROUND FAULT INTERRUPT - MOUNTED ABOVE COUNTER
- SURFACE MOUNTED PANEL
- MOTOR OUTLET
- MOTOR DISCONNECT
- MANUAL MOTOR STARTER
- HUMIDISTAT

# MECHANICAL????????



## MAIN FLOOR PLAN - ELECTRICAL

1:50

**DO NOT SCALE DRAWINGS**

Client	Project title	drawing title	approved by	PISSC Project Manager	project no.
PARKS CANADA	TUNNEL MOUNTAIN CAMPGROUND VILLAGE 1 BANFF NATIONAL PARK	ELECTRICAL FLOOR PLAN	J. GILBERT	J. WHITE	420301
	WASHROOM & SHOWER UPGRADE		designed by	PISSC, Architectural and Engineering Resources Manager	sheet
			J. GILBERT	Surinder J. Singh Brar, P. Eng.	E1
			drawn by	Date	REV.
			J. GILBERT	2007-02-31	OF 2