

PART 1 **GENERAL**

1.1 **GENERAL**

- .1 This Section covers items common to Sections of Division 26. This section supplements requirements of Division 1, Division 23 and Division 33.

1.2 **REFERENCES**

- .1 Canadian Standards Association (CSA)
 - .1 CSA C22.1-12, Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations.
 - .2 CAN3-C235, Preferred Voltage Levels for AC Systems, 0 to 50,000 V.

1.3 **CARE, OPERATION AND START-UP**

- .1 Instruct Departmental Representative and operating personnel in the operation, care and maintenance of systems, system equipment and components.
- .2 Operating instructions to include following:
 - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
 - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
 - .3 Safety precautions.
 - .4 Procedures to be followed in event of equipment failure.
 - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
- .3 Arrange and pay for services of manufacturer's factory service departmental representative to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
- .4 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with all aspects of its care and operation.

1.4 **DESIGN REQUIREMENTS**

- .1 Operating voltages: to CAN3-C235
- .2 Equipment and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard. Equipment to operate in extreme operating conditions established in above standard without damage to equipment.

1.5 SUBMITTALS

- .1 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure coordinated installation.
- .2 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
- .3 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
- .4 Quality Control: in accordance with Section 01 45 00 – Testing and Quality Control.
 - .1 Provide CSA certified equipment and material. Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction for approval before delivery to site.
 - .2 Submit test results of installed electrical systems and instrumentation.
 - .3 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
- .5 Manufacturer's Field Reports: submit to Departmental Representative within 7 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.

1.6 PERMITS, FEES AND INSPECTION

- .1 Submit to Electrical Inspection Division and Supply Authority necessary number of drawings and specifications for examination and approval prior to commencement of work.
- .2 Pay associated fees.
- .3 Departmental Representative will provide drawings and specifications required by Electrical Inspection Division and Supply Authority at no cost.
- .4 Notify Departmental Representative of changes required by Electrical Inspection Division prior to making changes.
- .5 Furnish Certificates of Acceptance from Electrical Inspection Division or authorities having jurisdiction on completion of work to Departmental Representative.

1.7 COORDINATION

- .1 Coordinate work with work of other divisions to avoid conflict.
- .2 Locate distribution systems, equipment, and materials to provide minimum interference and maximum usable space.

- .3 Locate all existing underground services and make all parties aware of their existence and location.
- .4 Where interference occurs, Departmental Representative must approve relocation of equipment and materials regardless of installation order.
- .5 Notwithstanding the review of shop drawings, this division may be required to relocate electrical equipment which interferes with the equipment of other trades, due to lack of coordination by this Division. The cost of this relocation shall be the responsibility of this Division. The Departmental Representative shall decide the extent of relocation required.

1.8 CUTTING AND PATCHING

- .1 This contractor is responsible for all cutting and patching associated with installation of electrical equipment.

1.9 PROTECTION

- .1 Protect exposed live equipment during construction for personnel safety.
- .2 Shield and mark all live parts “LIVE 240 VOLTS”, or with appropriate voltage in English.
- .3 Arrange for installation of temporary doors for rooms containing electrical distribution equipment. Keep these doors locked except when under direct supervision of electrician.

1.10 RECORD DRAWINGS

- .1 Obtain and pay for three sets of white prints. As the job progresses, mark these prints to accurately indicate installed work. Have the white prints available for inspection at the site at all times and present for scrutiny at each job meeting.
- .2 Show on the record drawings the installed inverts of all services entering and leaving the building. Dimension underground services at key points of every run in relation to the structure and building.
- .3 Submit record drawings within 30 days prior to start of commissioning.

1.11 INSPECTION OF WORK

- .1 The Departmental Representative will make periodic visits to the site during construction to ascertain reasonable conformity to plans and specifications but will not execute quality control. The Contractor shall be responsible for the execution of his work in conformity with the construction documents and with the requirements of the inspection authority.

1.12 SCHEDULING OF WORK

- .1 Work shall be scheduled in phases as per other divisions of the architectural specifications.
- .2 Become familiar with the phasing requirements for the work and comply with these conditions.
- .3 No additional monies will be paid for contractor's requirement to comply with work phasing conditions.

PART 2 PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- .1 Provide materials and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Equipment and material to be CSA certified. Where there is no alternative to supplying equipment which is not CSA certified, obtain special approval from Electrical Inspection Division.
- .3 Factory assemble control panels and component assemblies.

2.2 WARNING SIGNS

- .1 As specified and to meet requirements of Electrical Inspection Department and Departmental Representative.
- .2 Porcelain enamel decal signs, minimum size 175 x 250 mm.

2.3 WIRING TERMINATIONS

- .1 Lugs, terminals, screws used for termination of wiring to be suitable for either copper or aluminum conductors.

2.4 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .1 Nameplates: Lamicoid 3 mm thick plastic engraving sheet, black white face, black white core, mechanically attached with self tapping screws.
 - .2 Sizes as follows:

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters

NAMEPLATE SIZES

Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

.2 Labels:

.1 Embossed plastic labels with 6 mm high letters unless specified otherwise.

.3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.

.4 Allow for average of twenty-five (25) letters per nameplate and label.

.5 Identification to be English.

.6 Disconnects: as described.

.7 Receptacles: as indicated.

.8 Panels: voltage, phase, ampacity.

2.5 WIRING IDENTIFICATION

.1 Identify wiring with permanent indelible identifying markings, either numbered or coloured plastic tapes, on both ends of phase conductors of branch circuit wiring at devices, terminal blocks and at panel.

.2 Maintain phase sequence and colour coding throughout.

.3 Colour code: to CSA C22.1, Canadian Electrical Code.

.4 Use colour coded wires in communication cables, matched throughout system.

PART 3 EXECUTION

3.1 NAMEPLATES AND LABELS

.1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.2 LOCATION OF OUTLETS

.1 Locate outlets in accordance with Section 26 27 26 – Wiring Devices.

.2 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.

- .3 Locate light switches on latch side of doors.

3.3 MOUNTING HEIGHTS

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical at following heights unless indicated otherwise.
 - .1 Local switches: 1200 mm.
 - .2 Wall receptacles:
 - .1 General: 450 mm.
 - .3 Panelboards: as required by Code or as indicated.

3.4 COORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

3.5 FIELD QUALITY CONTROL

- .1 All electrical work to be carried out by qualified, licensed electricians or apprentices as per the conditions of the Provincial Act respecting manpower vocational training and qualification. Employees registered in a provincial apprentices program shall be permitted, under the direct supervision of a qualified licensed electrician, to perform specific tasks – the activities permitted shall be determined based on the level of training attained and the demonstration of ability to perform specific duties.
- .2 The work of this division to be carried out by a contractor who holds a valid Code 1 Electrical Contractor License as issued by the Province.
- .3 Conduct and pay for following tests:
 - .1 Power distribution system including phasing, voltage, grounding.
 - .2 Circuits originating from branch distribution panels.
 - .3 Lighting and its control.
 - .4 Heaters and associated control equipment.
 - .5 Systems: metering systems.
- .4 Furnish manufacturer's certificate or letter confirming that entire installation as it pertains to each system has been installed to manufacturer's instructions.
- .5 Insulation resistance testing.

- .1 Megger and record circuits, feeders and equipment up to 350 V with a 500 V instrument.
- .2 Check resistance to ground before energizing and record value.
- .6 Carry out tests in presence of Departmental Representative.
- .7 Provide instruments, meters, equipment and personnel required to conduct tests during and conclusion of project.

3.6 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.

END OF SECTION