

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 05 00 – Common Work Results – Electrical.
- .2 Section 26 05 34 – Conduits, Conduit Fastenings and Fittings.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA)
 - .1 CSA C22.1, Canadian Electrical Code, Part 1.

PART 2 PRODUCTS

2.1 OUTLET AND CONDUIT BOXES GENERAL

- .1 Size boxes in accordance with CSA C22.1.
- .2 102 mm square or larger outlet boxes as required for special devices.

2.2 CONDUIT BOXES

- .1 PVC boxes with factory hubs and mounting feet for surface wiring of switches and receptacles within electrical shed.
- .2 PVC boxes with factory hubs and mounting feet for receptacles at pedestals.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Support boxes independently of connecting conduits.
- .2 Provide correct size of openings in boxes for conduit connections. Reducing washers are not allowed.
- .3 Vacuum clean interior of outlet boxes before installation of wiring devices.
- .4 Identify systems for outlet boxes as required.

END OF SECTION