

**PART 1**      **GENERAL**

**1.1**            **SECTION INCLUDES**

- .1      Service equipment and installation.

**1.2**            **RELATED SECTIONS**

- .1      Section 26 05 28 - Grounding - Secondary.
- .2      Section 26 24 16.01 - Panelboards Breaker Type.
- .3      Section 26 28 23 - Disconnect Switches - Fused and Non-Fused.

**PART 2**      **PRODUCTS**

**2.1**            **EQUIPMENT**

- .1      Fused disconnect switch: in accordance with Section 26 28 23 - Disconnect Switches - Fused and Non-Fused, size as indicated, service entrance rated.
- .2      Panelboard breaker type: in accordance with Section 26 24 16.01 - Panelboards Breaker Type.
- .3      Cabinet type 'A' for utility revenue metering.
- .4      Utility meter socket.

**PART 3**      **EXECUTION**

**3.1**            **INSTALLATION**

- .1      Install service equipment.
- .2      Connect to incoming service.
- .3      Connect to outgoing load circuits.
- .4      Make grounding connections in accordance with Section 26 05 28 - Grounding – Secondary.
- .5      Make provision for power supply authority's metering.

**END OF SECTION**