

PART 1 **GENERAL**

1.1 **REFERENCES**

- .1 Canadian Standards Association (CSA)
 - .1 CAN/CSA C22.2 No. 18, Outlet Boxes, Conduit Boxes, and Fittings and Associated Hardware, a National Standard of Canada.
 - .2 CSA C22.2 No. 45, Rigid Metal Conduit.
 - .3 CSA C22.2 No. 211.2, Rigid PVC (Unplasticized) Conduit.

1.2 **SUBMITTALS**

- .1 Product data: submit manufacturer's printed product literature, specifications and datasheets.
 - .1 Submit cable manufacturing data.
- .2 Quality assurance submittals:
 - .1 Test reports: submit certified test reports.
 - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .3 Instructions: submit manufacturer's installation instructions.

PART 2 **PRODUCTS**

2.1 **CONDUITS**

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
- .2 Rigid PVC conduit: to CSA C22.2 No. 211.2.

2.2 **CONDUIT FASTENINGS**

- .1 One hole steel straps to secure surface conduits 50 mm and smaller. Two hole steel straps for conduits larger than 50 mm.

2.3 **CONDUIT FITTINGS**

- .1 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
- .2 Factory "ells" where 90°, 45 ° or 22.5 ° bends are required for 25 mm and larger conduits.
- .3 Ensure conduit bends other than factory “ells” are made with an approved bender. Making offsets and other bends by cutting and rejoining 90 degree bends are not permitted.

2.4 FISH CORD

- .1 Polypropylene.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install all conduit, conduit fittings and accessories in accordance with the latest edition of the Canadian Electrical Code in a manner that does not alter, change or violate any part of the installed system components or the CSA/UL certification of these components.
- .2 Use rigid PVC conduit underground.
- .3 Use rigid PVC conduit for exposed installations at pedestals.
- .4 Use rigid PVC conduit for wiring within electrical shed (exposed).
- .5 Use rigid PVC for concealed installation alongside face of wharf.
- .6 Minimum conduit size for lighting and power circuits: 21 mm.
- .7 Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .8 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .9 Install fish cord in empty conduits.
- .10 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.
- .11 Dry conduits out before installing wire.

3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.

3.4 CONDUITS UNDERGROUND

- .1 Slope conduits to provide drainage.

- .2 Waterproof joints (PVC excepted) with heavy coat of bituminous paint.

3.5 CLEANING

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 On Completion and verification of performance of installation, remove surplus materials, excess materials rubbish, tools and equipment.

END OF SECTION