

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving - PWGSC / Réception des soumissions -**  
**TPSGC**  
**11 Laurier St./11 rue Laurier**  
**Place du Portage, Phase III**  
**Core 0A1 / Noyau 0A1**  
**Gatineau, Québec K1A 0S5**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Construction Services Division/Division des services de  
construction  
11 Laurier St./11 Rue Laurier  
3C2, Place du Portage  
Phase III  
Gatineau, Québec K1A 0S5

<b>Title - Sujet</b> PANL ELEVATOR MODERNIZATION	
<b>Solicitation No. - N° de l'invitation</b> EP067-140879/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> 20140879	<b>Date</b> 2013-10-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-349-63512	
<b>File No. - N° de dossier</b> fg349.EP067-140879	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-10-23</b>	
<b>Time Zone</b> <b>Fuseau horaire</b> Eastern Daylight Saving Time EDT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> D'aoust, Jacques	<b>Buyer Id - Id de l'acheteur</b> fg349
<b>Telephone No. - N° de téléphone</b> (819) 956-0616 ( )	<b>FAX No. - N° de FAX</b> (819) 956-8335
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Library and Archives Canada 395 Wellington Street Ottawa, Ontario K1A 0N4	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

This amendment is being raised to make the following changes to the Invitation to Tender document: a) extension of the solicitation bid closing date, and b) to incorporate the Addendum number 01 to the solicitation document.

**a) Extension of the Solicitation Closing Date**

Note that the solicitation closing date for this project is hereby EXTENDED from October 18, 2013 at 2:00 p.m. to **October 23, 2013 at 2:00 p.m.**

**b) Addendum number 01**

This amendment is raised to incorporate the **Addendum number 01** to the solicitation document. This Addendum will form part of the resulting contract.

All other terms and conditions remain the same.

PROJECT NAME: 875 Heron Rd – Low Rise Elevator Modernization  
PROJECT NUMBER: R.052232.002  
DATE: October 15, 2013.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

## 1. SPECIFICATIONS

### 1. Section 01 00 10 General Instructions

- .1 **REMOVE** Items 1.3.2.1, 1.3.2.2, 1.3.2.3 Fire Safety Requirements in their entirety.
- .2 **MODIFY** Item 1.3.3.1.2 Fire Safety Requirements to read: *Completed welding permit.*
- .3 **MODIFY** Item 1.3.3.2 Fire Safety Requirements to read: *"Fire Watchers" shall be assigned when welding or cutting operations are carried out in areas where combustible materials within 15m may be ignited by conduction or radiation.*
- .4 **MODIFY** Item 1.3.3.4.1 Fire Safety Requirements to read: *Provide 'Watchman Service'; In general, watchman service is defined as an individual conversant with "Fire Emergency Procedures", performing fire picket duty within an unprotected and unoccupied (no workers) area once per hour.*
- .5 **ADD** Item 1.5 Site Separation: *The contractor shall agree to install proper site separation and identification in order to maintain "Time and Space" at all times throughout the life of the project. When Building Operations staff requires access to equipment in order to operate the building, proper coordination and communication must exist between all parties involved.*

### 2. Section 01 35 29 .06 Health and Safety Requirements

1. **REMOVE** Items 1.2.1, 1.2.2, 1.2.4 References in their entirety.
2. **MODIFY** Item 1.2.3 References to read: *"Occupational Health and Safety Act and Regulations for Construction Projects, R.S.O. 1990, c. o.1, current edition and O. Reg. 213/91, current edition".*
3. **MODIFY** Item 1.3.3 Submittals to read: *Submit 2 copies of Contractor's authorized representative's work site health and safety inspection reports to Departmental Representative Engineer and authority having jurisdiction.*

PROJECT NAME: 875 Heron Rd – Low Rise Elevator Modernization  
PROJECT NUMBER: R.052232.002  
DATE: October 15, 2013.

4. **MODIFY** Item 1.10 Responsibility to read: Be responsible *and assume the role of "Constructor" as described in the Ontario Occupational Health & Safety Act and Regulations for Construction Projects* for health and safety of persons on site, safety of property on site and for protection of persons adjacent to site and environment to extent that they may be affected by conduct of Work.
5. **REMOVE** Items 1.11.1, 1.11.2, 1.11.3, 1.11.4, 1.11.5 Compliance in their entirety.
6. **ADD** Item 1.11.1 Compliance to read: *Comply with the Ontario Occupational Health and Safety Act and Regulations for Construction Projects.*
3. Section 01 61 00 Common Product Requirements
  1. **ADD:** *Items 1.8*
    1. *Carry out Work using qualified licensed workers or apprentices in accordance with Provincial Act representing manpower vocational training and qualification*
    2. *Permit employees registered in Provincial apprenticeship program to perform specific tasks only if under direct supervision of qualified licensed workers.*
4. Section 14 20 06 Gearless Passenger Elevators
  1. **ADD** Item 2.2.9.6 Controller and Cabinet: *Provide fully non-proprietary control equipment to include the following as a minimum.*
    1. *All required diagnostics are 'on board'*
    2. *All programming and wiring diagrams required for long term maintenance are provided with the controller.*
    3. *The controller will not shut down or alter its functionality in anyway after a pre-determined increment of time or use.*
    4. *Any Elevator Contractor should be allowed to purchase parts, supplies, wiring diagrams, support, or training directly from the factory at the same cost level as the original manufacturer. A published price list shall be supplied with the controller.*
    5. *Parts including circuit boards should be available for direct purchase from the original manufacturer in numbers and not on a one-for-one "exchange only" basis.*

PROJECT NAME: 875 Heron Rd – Low Rise Elevator Modernization  
PROJECT NUMBER: R.052232.002  
DATE: October 15, 2013.

5. Section 14 20 03 Geared Freight Elevator

1. **ADD** Item 2.25.6 Controller and Cabinet: *Provide fully non-proprietary control equipment to include the following as a minimum.*
  1. *All required diagnostics are 'on board'*
  2. *All programming and wiring diagrams required for long term maintenance are provided with the controller.*
  3. *The controller will not shut down or alter its functionality in anyway after a pre-determined increment of time or use.*
  4. *Any Elevator Contractor should be allowed to purchase parts, supplies, wiring diagrams, support, or training directly from the factory at the same cost level as the original manufacturer. A published price list shall be supplied with the controller.*
  5. *Parts including circuit boards should be available for direct purchase from the original manufacturer in numbers and not on a one-for-one "exchange only" basis.*

END OF ADDENDUM no. 01