

The following changes are effective immediately and shall be incorporated into the Contract Documents.

**DRAWING**

**E2.4 ELECTRICAL ROOM 1629E LAYOUT**

1. Provide structural support for electrical panel EP-254 as shown on detail ESK-1. The structural support shall be built as per the requirements of section 26 05 49 Seismic Restraints.

END OF ADDENDUM NO.1