

PART 1 - GENERAL

- 1.1 SUBMITTALS
- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Shop drawings; submit drawings stamped and signed by professional engineer registered or licensed in Canada.
  - .3 Shop drawings to show:
    - .1 Mounting arrangements.
    - .2 Operating and maintenance clearances.
  - .4 Shop drawings and product data accompanied by:
    - .1 Detailed drawings of bases, supports, and anchor bolts.
    - .2 Acoustical sound power data, where applicable.
    - .3 Points of operation on performance curves.
    - .4 Manufacturer to certify current model production.
    - .5 Certification of compliance to applicable codes.
  - .5 In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
  - .6 Closeout Submittals:
    - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
    - .2 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
    - .3 Operation data to include:
      - .1 Control schematics for systems including environmental controls.
      - .2 Description of systems and their controls.
      - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
      - .4 Operation instruction for systems and component.
      - .5 Description of actions to be taken in event of equipment failure.

June 19, 2013

- 
- 1.1 SUBMITTALS .6 Closeout Submittals:(Cont'd)  
(Cont'd)
- .3 Operation data to include:(Cont'd)
- .6 Valves schedule and flow diagram.
  - .7 Colour coding chart.
- .4 Maintenance data to include:
- .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
  - .2 Data to include schedules of tasks, frequency, tools required and task time.
- .5 Performance data to include:
- .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
  - .2 Equipment performance verification test results.
  - .3 Special performance data as specified.
  - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
- .6 Approvals:
- .1 Submit 2 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
  - .2 Make changes as required and re-submit as directed by Departmental Representative.
- .7 Additional data:
- .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .8 Site records:
- .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
  - .2 Transfer information to reproducibles, revising reproducibles to show work as actually installed.
  - .3 Use different colour waterproof ink for each service.
-

- 1.1 SUBMITTALS (Cont'd) .6 Closeout Submittals:(Cont'd)
- .8 Site records:(Cont'd)
    - .4 Make available for reference purposes and inspection.
  - .9 As-built drawings:
    - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
    - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
    - .3 Submit to Departmental Representative for approval and make corrections as directed.
    - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
    - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
  - .10 Submit copies of as-built drawings for inclusion in final TAB report.
- 1.2 QUALITY ASSURANCE .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 28 - Health and Safety Requirements.
- 1.3 MAINTENANCE .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:
- .1 One set of packing for each pump.
  - .2 One casing joint gasket for each size pump.
  - .3 One head gasket set for each heat exchanger.
  - .4 One glass for each gauge glass.
  - .5 One filter cartridge or set of filter media for each filter or filter bank in addition to final operating set.
- .2 Provide one set of special tools required to service equipment as recommended by
-

- 1.3 MAINTENANCE .2 (Cont'd)  
(Cont'd)
- manufacturers and in accordance with Section 01 78 00 - Closeout Submittals.
- .3 Furnish one commercial quality grease gun, grease and adapters to suit different types of grease and grease fittings.

PART 2 - PRODUCTS Not Used

PART 3 - EXECUTION

- 3.1 CLEANING .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.

- 3.2 FIELD QUALITY CONTROL .1 Manufacturer's Field Services:
- .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
- .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
- .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

- 3.3 DEMONSTRATION .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .3 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
-

- 3.3 DEMONSTRATION .4 Instruction duration time requirements as  
(Cont'd) specified in appropriate sections.
- .5 Departmental Representative will record these  
demonstrations on video tape for future  
reference.
- 3.4 PROTECTION .1 Protect equipment and systems openings from  
dirt, dust, and other foreign materials with  
materials appropriate to system.

PART 1 - GENERAL

- 1.1 USE OF SYSTEMS .1 Use of new and or existing permanent heating and or ventilating systems for supplying temporary heat or ventilation is permitted permitted under the following conditions:
- .1 Entire system is complete, pressure tested, cleaned, flushed out.
  - .2 Specified water treatment system has been commissioned, water treatment is being continuously monitored.
  - .3 Building has been closed in, areas to be heated/ventilated are clean and will not thereafter be subjected to dust-producing processes.
  - .4 There is no possibility of damage.
  - .5 Supply ventilation systems are protected by 60% filters, inspected daily, changed every 2 weeks or more frequently as required.
  - .6 Return systems have approved filters over openings, inlets, outlets.
  - .7 Systems will be:
    - .1 Operated as per manufacturer's recommendations and instructions.
    - .2 Operated by Contractor.
    - .3 Monitored continuously by Contractor.
  - .8 Warranties and guarantees are not relaxed.
  - .9 Regular preventive and other manufacturers recommended maintenance routines are performed by Contractor at own expense and under supervision of Departmental Representative.
  - .10 Refurbish entire system before static completion; clean internally and externally, restore to "as-new" condition, replace filters in air systems.
- .2 Filters specified in this Section are over and above those specified in other Sections of this project.
- .3 Exhaust systems are not included in approvals for temporary heating ventilation.
-

PART 2 - PRODUCTS

2.1 NOT USED .1 Not Used.

PART 3 - EXECUTION

PART 1 - GENERAL

- 1.1 RELATED SECTIONS.1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- 1.2 REFERENCES .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
- .1 ASHRAE 90.1, Energy Code for Buildings Except Low-Rise Residential Buildings.
- .2 Electrical Equipment Manufacturers' Advisory Council (EEMAC)
- 1.3 SECTIONS INCLUDES .1 Electrical work to conform to Division 26 including the following:
- .1 Supplier and installer responsibility is indicated in Motor, Control and Equipment Schedule on electrical drawings and related mechanical responsibility is indicated on Mechanical Equipment Schedule on mechanical drawings.
- .2 Control wiring and conduit is specified in Division 26. Refer to Division 26 for quality of materials and workmanship.
- 1.4 SHOP DRAWINGS .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- 1.5 CLOSEOUT SUBMITTALS .1 Provide maintenance data for motors, drives and guards for incorporation into manual specified in Section 01 33 00 - Submittal Procedures.
-

1.6 WASTE  
MANAGEMENT AND  
DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.
- .3 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .4 Dispose of corrugated cardboard, polystyrene, plastic and packaging material in appropriate on-site bin for recycling in accordance with site waste management program.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Motors to be high efficiency, in accordance with the requirements of ASHRAE 90.1.

2.2 MOTORS

- .1 Provide motors for mechanical equipment as specified.
- .2 If delivery of specified motor will delay delivery or installation of equipment, install motor approved by Departmental Representative for temporary use. Final acceptance of equipment will not occur until specified motor is installed.
- .3 Motors under 373 W: speed as indicated, continuous duty, built-in overload protection, resilient mount, single phase, 120 V, unless otherwise specified or indicated.
- .4 Motors 373 W and larger: EEMAC Class B, squirrel cage induction, speed as indicated, continuous duty, drip proof, ball bearing, maximum temperature rise 40° C, 3 phase, 575 V, unless otherwise specified or indicated.

2.3 TEMPORARY MOTORS .1 If delivery of specified motor will delay completion or commissioning work, install motor approved by Departmental Representative for temporary use. Work will only be accepted when specified motor is installed.

2.4 BELT DRIVES .1 Fit reinforced belts in sheave matched to drive. Multiple belts to be matched sets.

.2 Use cast iron or steel sheaves secured to shafts with removable keys unless otherwise indicated.

.3 For motors under 7.5 kW 10 HP: standard adjustable pitch drive sheaves, having plus or minus 10% range. Use mid-position of range for specified r/min.

.4 For motors 7.5 kW and over: sheave with split tapered bushing and keyway having fixed pitch unless specifically required for item concerned. Provide sheave of correct size to suit balancing.

.5 Correct size of sheave determined during commissioning.

.6 Minimum drive rating: 1.5 times nameplate rating on motor. Keep overhung loads within manufacturer's design requirements on prime mover shafts.

.7 Motor slide rail adjustment plates to allow for centre line adjustment.

.8 Supply one set of spare belts for each set installed.

2.5 DRIVE GUARDS .1 Provide guards for unprotected drives.

.2 Guards for belt drives;

.1 Expanded metal screen welded to steel frame.

.2 Minimum 1.2 mm thick sheet metal tops and bottoms.

.3 38 mm dia holes on both shaft centres for insertion of tachometer.

---

- 2.5 DRIVE GUARDS .2 (Cont'd)  
(Cont'd) .4 Removable for servicing.
- .3 Provide means to permit lubrication and use of test instruments with guards in place.
- .4 Install belt guards to allow movement of motors for adjusting belt tension.
- .5 Guard for flexible coupling:  
.1 "U" shaped, minimum 1.6 mm thick galvanized mild steel.  
.2 Securely fasten in place.  
.3 Removable for servicing.
- .6 Unprotected fan inlets or outlets:  
.1 Wire or expanded metal screen, galvanized, 19 mm mesh.  
.2 Net free area of guard: not less than 80% of fan openings.  
.3 Securely fasten in place.  
.4 Removable for servicing.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Fasten securely in place.
- .2 Make removable for servicing, easily returned into, and positively in position.

PART 1 - GENERAL

- 1.1 SUMMARY .1 Section Includes:  
.1 Bronze - valves.
- .2 Related Sections:  
.1 Section 01 33 00 - Submittal Procedures.  
.2 Section 01 35 30 - Health and Safety Requirements.  
.3 Section 01 78 00 - Closeout Submittals.
- 1.2 REFERENCES .1 American National Standards Institute (ANSI)/  
American Society of Mechanical Engineers  
(ASME).  
.1 ANSI/ASME B1.20.1-1983(R2001), Pipe  
Threads, General Purpose (Inch).  
.2 ANSI/ASME B16.18-2001, Cast Copper Alloy  
Solder Joint Pressure Fittings.
- .2 American Society for Testing and Materials  
International, (ASTM).  
.1 ASTM A 276, Specification for Stainless  
Steel Bars and Shapes.  
.2 ASTM B 62, Specification for Composition  
Bronze or Ounce Metal Castings.  
.3 ASTM B 283, Specification for Copper and  
Copper Alloy Die Forgings (Hot-Pressed).  
.4 ASTM B 505/B 505M, Specification for  
Copper-Base Alloy Continuous Castings.
- .3 Manufacturers Standardization Society of the  
Valve and Fittings Industry, Inc. (MSS).  
.1 MSS-SP-25, Standard Marking System for  
Valves, Fittings, Flanges and Unions.  
.2 MSS-SP-80, Bronze Gate Globe, Angle and  
Check Valves.  
.3 MSS-SP-110, Ball Valves, Threaded,  
Socket-Welding, Solder Joint, Grooved and  
Flared Ends.
- 1.3 SUBMITTALS .1 Submittals in accordance with Section  
01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS - Material  
Safety Data Sheets.
-

- 1.3 SUBMITTALS      .2    Product Data:(Cont'd)  
    (Cont'd)
- .1    Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
  - .2    Submit data for valves specified in this section.
- .3    Closeout Submittals:
- .1    Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
- 1.4 QUALITY      .1    Health and Safety:  
ASSURANCE
- .1    Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.
- 1.5 MAINTENANCE    .1    Extra Materials:
- .2    Furnish following spare parts:
    - .1    Valve seats: one for every 10 valves each size, minimum 1.
    - .2    Discs: one for every 10 valves, each size. Minimum 1.
    - .3    Stem packing: one for every 10 valves, each size. Minimum 1.
    - .4    Valve handles: 2 of each size.
    - .5    Gaskets for flanges: one for every 10 flanged joints.

PART 2 - PRODUCTS

- 2.1 MATERIALS      .1    Valves:
- .1    Except for specialty valves, to be single manufacturer.
  - .2    All products to have CRN registration numbers.
- .2    End Connections:
- .1    Connection into adjacent piping/tubing:
    - .1    Steel pipe systems: Screwed ends to ANSI/ASME B1.20.1.
    - .2    Copper tube systems: Solder ends to ANSI/ASME B16.18.
-

2.1 MATERIALS  
(Cont'd)

- .3 Lockshield Keys:
  - .1 Where lockshield valves are specified, provide 10 keys of each size: malleable iron cadmium plated.
  
- .4 Gate Valves:
  - .1 Requirements common to gate valves, unless specified otherwise:
    - .1 Standard specification: MSS SP-80.
    - .2 Bonnet: union with hexagonal shoulders.
    - .3 Connections: screwed with hexagonal shoulders.
    - .4 Inspection and pressure testing: to MSS SP-80. Tests to be hydrostatic.
    - .5 Packing: non-asbestos.
    - .6 Handwheel: non-ferrous.
    - .7 Handwheel Nut: bronze to ASTM B 62.
  - .2 NPS 2 and under, non-rising stem, solid wedge disc, Class 125
    - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
    - .2 Operator: Handwheel.
  - .3 NPS 2 and under, non-rising stem, solid wedge disc, Class 150:
    - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
    - .2 Operator: Handwheel.
  - .4 NPS 2 and under, rising stem, split wedge disc, Class 125:
    - .1 Body: with long disc guides, screwed bonnet.
    - .2 Disc: split wedge, bronze to ASTM B 283, loosely secured to stem.
    - .3 Operator: Handwheel Lockshield.
  - .5 NPS 2 and under, rising stem, solid wedge disc, Class 125:
    - .1 Body: with long disc guides, screwed bonnet.
    - .2 Operator: Handwheel.
  - .6 NPS 2 and under, rising stem, solid wedge disc, Class 150:
    - .1 Body: with long disc guides, screwed union bonnet.
    - .2 Operator: Handwheel.
  
- .5 Globe Valves:
  - .1 Requirements common to globe valves, unless specified otherwise:
    - .1 Standard specification: MSS SP-80.
    - .2 Bonnet: union with hexagonal shoulders.

- 
- 2.1 MATERIALS (Cont'd)
- .5 Globe Valves:(Cont'd)
- .1 (Cont'd)
- .3 Connections: screwed with hexagonal shoulders.
- .4 Pressure testing: to MSS SP-80. Tests to be hydrostatic.
- .5 Stuffing box: threaded to bonnet with gland follower, packing nut, high grade non-asbestos packing.
- .6 Handwheel: non-ferrous.
- .7 Handwheel Nut: bronze to ASTM B 62.
- .2 NPS 2 and under, composition disc, Class 125:
- .1 Body and bonnet: screwed bonnet.
- .2 Disc and seat: renewable rotating PTFE disc composition to suit service conditions, regrindable bronze seat, loosely secured to bronze stem to ASTM B 505.
- .3 Operator: Handwheel.
- .3 NPS 2 and under, composition disc, Class 150:
- .1 Body and bonnet: union bonnet.
- .2 Disc and seat: renewable rotating PTFE disc in easily removable disc holder, regrindable bronze seat, loosely secured to bronze stem to ASTM B 505.
- .3 Operator: Handwheel.
- .4 NPS 2 and under, plug disc, Class 150, screwed ends:
- .1 Body and bonnet: union bonnet.
- .2 Disc and seat ring: tapered plug type with disc stem ring of AISI S420 stainless steel to ASTM A 276, loosely secured to stem.
- .3 Operator: Handwheel.
- .5 Angle valve, NPS 2 and under, composition disc, Class 150:
- .1 Body and bonnet: union bonnet.
- .2 Disc and seat: renewable rotating PTFE disc in slip-on easily removable disc holder having integral guides, regrindable bronze seat, loosely secured to stem.
- .3 Operator: Handwheel.
- .6 Check Valves:
- .1 Requirements common to check valves, unless specified otherwise:
- .1 Standard specification: MSS SP-80.
- .2 Connections: screwed with hexagonal shoulders.
-

2.1 MATERIALS  
(Cont'd)

- .6 Check Valves:(Cont'd)
  - .2 NPS 2 and under, swing type, bronze disc, Class 125:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
  - .3 NPS 2 and under, swing type, bronze disc:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
  - .4 NPS 2 and under, swing type, composition disc, Class 200:
    - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
    - .2 Disc: renewable rotating disc of number 6 composition to suit service conditions, bronze two-piece hinge disc construction.
  - .5 NPS 2 and under, horizontal lift type, composition disc, Class 150:
    - .1 Body: with integral seat, union bonnet ring with hex shoulders, cap.
    - .2 Disc: renewable PTFE rotating disc in disc holder having guides top and bottom, of bronze to ASTM B 62.
  - .6 NPS 2 and under, vertical lift type, bronze disc, Class 125:
    - .1 Disc: rotating disc having guides top and bottom, disc guides, retaining rings.
- .7 Silent Check Valves:
  - .1 NPS 2 and under:
    - .1 Body: cast high tensile bronze to ASTM B 62 with integral seat.
    - .2 Pressure rating: Class 125.
    - .3 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
    - .4 Disc and seat: renewable rotating disc.
    - .5 Stainless steel spring, heavy duty.
    - .6 Seat: regrindable.

June 19, 2013

- 2.1 MATERIALS .8 Ball Valves:  
(Cont'd)
- .1 NPS 2 and under:
    - .1 Body and cap: cast high tensile bronze to ASTM B 62.
    - .2 Pressure rating: Class 125, 860 kPa steam.
    - .3 Connections: Screwed ends to ANSI B1.20.1 and with hexagonal shoulders.
    - .4 Stem: tamperproof ball drive.
    - .5 Stem packing nut: external to body.
    - .6 Ball and seat: replaceable stainless steelhard chrome solid ball and teflon seats.
    - .7 Stem seal: TFE with external packing nut.
    - .8 Operator: removable lever handle.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Install rising stem valves in upright position with stem above horizontal.
  - .2 Remove internal parts before soldering.
  - .3 Install valves with unions at each piece of equipment arranged to allow servicing,

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 American Society of Mechanical Engineers (ASME)
    - .1 ASME B31.1, Power Piping.
  - .2 ASTM International
    - .1 ASTM A 125, Standard Specification for Steel Springs, Helical, Heat-Treated.
    - .2 ASTM A 307, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
    - .3 ASTM A 563, Standard Specification for Carbon and Alloy Steel Nuts.
  - .3 Canada Green Building Council (CaGBC)
    - .1 LEED Canada-NC Version 1.0, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum).
    - .2 LEED Canada-CI Version 1.0, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
  - .4 Factory Mutual (FM)
  - .5 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
    - .1 MSS SP 58, Pipe Hangers and Supports - Materials, Design and Manufacture.
    - .2 MSS SP 69, Pipe Hangers and Supports - Selection and Application.
    - .3 MSS SP 89, Pipe Hangers and Supports - Fabrication and Installation Practices.
  - .6 Underwriter's Laboratories of Canada (ULC)
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
-



PART 2 - PRODUCTS

2.1 SYSTEM  
DESCRIPTION

- .1 Design Requirements:
- .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
  - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP 58.
  - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
  - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
  - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP 58.

2.2 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with MSS SP 58. ANSI B31.1 and
- .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

2.3 PIPE HANGERS

- .1 Finishes:
- .1 Pipe hangers and supports: galvanized.
  - .2 Use hot dipped galvanizing process.
  - .3 Ensure steel hangers in contact with copper piping are epoxy coated.
- .2 Upper attachment structural: suspension from lower flange of I-Beam:
- .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
    - .1 Rod: 9 mm UL listed.
  - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining

- 
- 2.3 PIPE HANGERS (Cont'd)
- .2 Upper attachment structural:(Cont'd)
    - .2 (Cont'd)  
clip, tie rod, nuts and washers to MSS-SP 58 and MSS-SP 69.
  - .3 Upper attachment structural: suspension from upper flange of I-Beam:
    - .1 Cold piping NPS 2 maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip to MSS SP 69.
    - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut UL listed.
  - .4 Upper attachment to concrete:
    - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
    - .2 Concrete inserts: wedge shaped body with knockout protector plate to MSS SP69.
  - .5 Shop and field-fabricated assemblies.
  - .6 Hanger rods: threaded rod material to MSS SP 58:
    - .1 Ensure that hanger rods are subject to tensile loading only.
    - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
    - .3 Do not use 22 mm or 28 mm rod.
  - .7 Pipe attachments: material to MSS SP 58:
    - .1 Attachments for steel piping: carbon steel.
    - .2 Attachments for copper piping: copper plated black steel.
    - .3 Use insulation shields for hot pipework.
    - .4 Oversize pipe hangers and supports.
  - .8 Adjustable clevis: material to MSS SP 69, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.
  - .9 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP 69.
  - .10 U-bolts: carbon steel to MSS SP 69 with 2 nuts at each end to ASTM A 563.
    - .1 Finishes for steel pipework: galvanized.
-

- 2.3 PIPE HANGERS (Cont'd)
- .10 U-bolts:(Cont'd)
    - .2 Finishes for copper, glass, brass or aluminum pipework: galvanized, with formed portion plastic coated.
  - .11 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP 69.
- 2.4 RISER CLAMPS
- .1 Steel or cast iron pipe: galvanized carbon steel to MSS SP 58, type 42.
  - .2 Copper pipe: carbon steel copper plated to MSS SP 58, type 42.
  - .3 Bolts: to ASTM A 307.
  - .4 Nuts: to ASTM A 563.
- 2.5 INSULATION PROTECTION SHIELDS
- .1 Insulated cold piping:
    - .1 64 kg/m<sup>3</sup> density insulation plus insulation protection shield to: MSS SP 69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
  - .2 Insulated hot piping:
    - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP 69.
- 2.6 CONSTANT SUPPORT SPRING HANGERS
- .1 Springs: alloy steel to ASTM A 125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).
  - .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
  - .3 Provide upper and lower factory set travel stops.
-

- 2.6 CONSTANT SUPPORT SPRING HANGERS  
(Cont'd)
- .4 Provide load adjustment scale for field adjustments.
  - .5 Total travel to be actual travel + 20%. Difference between total travel and actual travel 25 mm minimum.
  - .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.
- 2.7 VARIABLE SUPPORT SPRING HANGERS
- .1 Vertical movement: 13 mm minimum, 50 mm maximum, use single spring pre-compressed variable spring hangers.
  - .2 Vertical movement greater than 50 mm: use double spring pre-compressed variable spring hanger with 2 springs in series in single casing.
  - .3 Variable spring hanger complete with factory calibrated travel stops. Provide certificate of calibration for each hanger.
  - .4 Steel alloy springs: to ASTM A 125, shot peened, magnetic particle inspected, with +/-5 % spring rate tolerance, tested for free height, spring rate, loaded height and provided with CMTR.
- 2.8 EQUIPMENT SUPPORTS
- .1 Fabricate equipment supports not provided by equipment manufacturer from structural grade steel.
- 2.9 EQUIPMENT ANCHOR BOLTS AND TEMPLATES
- .1 Provide templates to ensure accurate location of anchor bolts.
- 2.10 HOUSE-KEEPING PADS
- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 50 mm larger than equipment; chamfer pad edges.
-

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.
- 3.2 INSTALLATION .1 Install in accordance with:  
.1 Manufacturer's instructions and recommendations.  
.2 Vibration Control Devices:  
.1 Install on piping systems at pumps, boilers, chillers, cooling towers, and as indicated.  
.3 Clamps on riser piping:  
.1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.  
.2 Bolt-tightening torques to industry standards.  
.3 Steel pipes: install below coupling or shear lugs welded to pipe.  
.4 Cast iron pipes: install below joint.  
.4 Clevis plates:  
.1 Attach to concrete with 4 minimum concrete inserts, one at each corner.  
.5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.  
.6 Use approved constant support type hangers where:  
.1 Vertical movement of pipework is 13 mm or more,  
.2 Transfer of load to adjacent hangers or connected equipment is not permitted.  
.7 Use variable support spring hangers where:  
.1 Transfer of load to adjacent piping or to connected equipment is not critical.  
.2 Variation in supporting effect does not exceed 25 % of total load.

- 3.3 HANGER SPACING
- .1 Plumbing piping: to Canadian Plumbing Code.
  - .2 Fire protection: to applicable fire code.
  - .3 Gas and fuel oil piping: up to NPS 1/2: every 1.8 m.
  - .4 Copper piping: up to NPS 1/2: every 1.5 m.
  - .5 Flexible joint roll groove pipe: in accordance with table below for steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.
  - .6 Within 300 mm of each elbow.

Maximum Pipe Size : NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.4 m	1.8 m
1-1/2	3.0 m	2.4 m
2	3.0 m	2.4 m
2-1/2	3.7 m	3.0 m
3	3.7 m	3.0 m
3-1/2	3.7 m	3.3 m
4	3.7 m	3.6 m
5	4.3 m	
6	4.3 m	
8	4.3 m	
10	4.9 m	
12	4.9 m	

- .7 Pipework greater than NPS 12: to MSS SP 69.

3.4 HANGER  
INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

3.5 HORIZONTAL  
MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

3.6 FINAL  
ADJUSTMENT

- .1 Adjust hangers and supports:
  - .1 Ensure that rod is vertical under operating conditions.
  - .2 Equalize loads.
- .2 Adjustable clevis:
  - .1 Tighten hanger load nut securely to ensure proper hanger performance.
  - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
  - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
  - .1 Hammer jaw firmly against underside of beam.

3.7 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian General Standards Board (CGSB)  
.1 CAN/CGSB-1.60-97, Interior Alkyd Gloss Enamel.  
.2 CAN/CGSB-24.3-92, Identification of Piping Systems.
- .2 National Fire Protection Association (NFPA)  
.1 NFPA 13-2002, Standard for the Installation of Sprinkler Systems.  
.2 NFPA 14-2003, Standard for the Installation of Standpipe and Hose Systems.
- 1.2 SUBMITTALS .1 Product Data:
- .2 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Product data to include paint colour chips, other products specified in this section.
- .4 Samples:  
.1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.  
.2 Samples to include nameplates, labels, tags, lists of proposed legends.
- 1.3 QUALITY ASSURANCE .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Health and Safety:  
.1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.
- 1.4 DELIVERY, STORAGE, AND HANDLING .1 Packing, shipping, handling and unloading:  
.1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.  
.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
-

PART 2 - PRODUCTS

- 2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES
- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
  - .2 Lettering and numbers raised or recessed.
  - .3 Information to include, as appropriate:
    - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
    - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.
- 2.2 SYSTEM NAMEPLATES
- .1 Colours:
    - .1 Hazardous: red letters, white background.
    - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
  - .2 Construction:
    - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.
  - .3 Sizes:
    - .1 Conform to following table:

Size #	mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1		10 x 50	1	3
2		13 x 75	1	5
3		13 x 75	2	3
4		20 x 100	1	8
5		20 x 100	2	5
6		20 x 200	1	8
7		25 x 125	1	12
8		25 x 125	2	8
9		35 x 200	1	20
  - .2 Use maximum of 25 letters/numbers per line.
  - .4 Identification for PWGSC Preventive Maintenance Support System (PMSS):
    - .1 Use arrangement of Main identifier, Source identifier, Destination identifier.

- 2.2 SYSTEM NAMEPLATES (Cont'd)
- .4 (Cont'd)
    - .2 Equipment in Mechanical Room:
      - .1 Main identifier: size #9.
      - .2 Source and Destination identifiers: size #6.
      - .3 Terminal cabinets, control panels: size #5.
    - .3 Equipment elsewhere: sizes as appropriate.
- 2.3 EXISTING IDENTIFICATION SYSTEMS
- .1 Apply existing identification system to new work.
  - .2 Where existing identification system does not cover for new work, use identification system specified this section.
  - .3 Before starting work, obtain written approval of identification system from Departmental Representative.
- 2.4 PIPING SYSTEMS GOVERNED BY CODES
- .1 Identification:
    - .1 Natural gas: to CSA/CGA B149.1 authority having jurisdiction.
    - .2 Propane gas: to CSA/CGA B149.1 authority having jurisdiction.
    - .3 Sprinklers: to NFPA 13.
    - .4 Standpipe and hose systems: to NFPA 14.
- 2.5 IDENTIFICATION OF PIPING SYSTEMS
- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
  - .2 Pictograms:
    - .1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.
  - .3 Legend:
    - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
  - .4 Arrows showing direction of flow:
    - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
-

- 2.5 IDENTIFICATION OF PIPING SYSTEMS (Cont'd)
- .4 Arrows showing direction of flow:(Cont'd)
- .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
- .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
- .1 To full circumference of pipe or insulation.
- .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
- .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
- .2 Other pipes: pressure sensitive plastic-coated cloth vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.
- .7 Colours and Legends:
- .1 Where not listed, obtain direction from Departmental Representative.
- .2 Colours for legends, arrows: to following table:

<u>Background colour:</u>	<u>Legend, arrows:</u>
Yellow	BLACK
Green	WHITE
Red	WHITE

.3 Background colour marking and legends for piping systems:

Contents	Background colour marking	Legend
Raw water	Green	RAW WATER
City water	Green	CITY WATER
Treated water	Green	TREATED WATER
Domestic hot water supply	Green	DOM. HW SUPPLY
Dom. HWS recirculation	Green	DOM. HW CIRC
Domestic cold water supply	Green	DOM. CWS
Sanitary	Green	SAN
Plumbing vent	Green	SAN. VENT
Fire protection water	Red	FIRE PROT. WTR
Sprinklers	Red	SPRINKLERS

---

- 2.6 IDENTIFICATION DUCTWORK SYSTEMS .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.
- 2.7 VALVES, CONTROLLERS .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.
- 2.8 CONTROLS COMPONENTS IDENTIFICATION .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.
- 2.9 LANGUAGE .1 Identification in English and French.
- .2 Use one nameplate and label for each language both languages.

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.
- 3.2 TIMING .1 Provide identification only after painting specified Section 09 91 23 - Interior Painting has been completed.
-

- 3.3 INSTALLATION .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC PMSS.
- 3.4 NAMEPLATES .1 Locations:  
.1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:  
.1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:  
.1 Do not paint, insulate or cover.
- 3.5 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not
-



PART 1 - GENERAL

- 1.1 SUMMARY
- .1 TAB is used throughout this Section to describe the process, methods and requirements of testing, adjusting and balancing for HVAC.
  - .2 TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.
- 1.2 QUALIFICATIONS OF TAB PERSONNEL
- .1 Submit names of personnel to perform TAB to Departmental Representative within 90 days of award of contract.
  - .2 Provide documentation confirming qualifications, successful experience.
  - .3 TAB: performed in accordance with the requirements of standard under which TAB Firm's qualifications are approved:
    - .1 Associated Air Balance Council, (AABC) National Standards for Total System Balance, MN-1.
    - .2 National Environmental Balancing Bureau (NEBB) TABES, Procedural Standards for Testing, Adjusting, Balancing of Environmental Systems.
    - .3 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), HVAC TAB HVAC Systems - Testing, Adjusting and Balancing.
  - .4 Recommendations and suggested practices contained in the TAB Standard: mandatory.
  - .5 Use TAB Standard provisions, including checklists, and report forms to satisfy Contract requirements.
  - .6 Use TAB Standard for TAB, including qualifications for TAB Firm and Specialist and calibration of TAB instruments.
  - .7 Where instrument manufacturer calibration recommendations are more stringent than those listed in TAB Standard, use manufacturer's recommendations.
-

- 1.2 QUALIFICATIONS OF TAB PERSONNEL .8 TAB Standard quality assurance provisions such as performance guarantees form part of this contract.  
(Cont'd)
- .1 For systems or system components not covered in TAB Standard, use TAB procedures developed by TAB Specialist.
- .2 Where new procedures, and requirements, are applicable to Contract requirements have been published or adopted by body responsible for TAB Standard used (AABC, NEBB, or TABB), requirements and recommendations contained in these procedures and requirements are mandatory.
- 1.3 PURPOSE OF TAB .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads
- .2 Adjust and regulate equipment and systems to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.
- 1.4 EXCEPTIONS .1 TAB of systems and equipment regulated by codes, standards to satisfaction of authority having jurisdiction.
- 1.5 CO-ORDINATION .1 Schedule time required for TAB (including repairs, re-testing) into project construction and completion schedule to ensure completion before acceptance of project.
- .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.
-

- 1.6 PRE-TAB REVIEW .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing proposed procedures which vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.
- 1.7 START-UP .1 Follow start-up procedures as recommended by equipment manufacturer unless specified otherwise.
- .2 Follow special start-up procedures specified elsewhere in Division 23.
- 1.8 OPERATION OF SYSTEMS DURING TAB .1 Operate systems for length of time required for TAB and as required by Departmental Representative for verification of TAB reports.
- 1.9 START OF TAB .1 Notify Departmental Representative 7 days prior to start of TAB.
- .2 Start TAB when building is essentially completed, including:
- .3 Installation of ceilings, doors, windows, other construction affecting TAB.
- .4 Application of weatherstripping, sealing, and caulking.
- .5 Pressure, leakage, other tests specified elsewhere Division 23.
- .6 Provisions for TAB installed and operational.
- .7 Start-up, verification for proper, normal and safe operation of mechanical and associated
-

- 
- 1.9 START OF TAB .7 (Cont'd)  
(Cont'd)
- electrical and control systems affecting TAB including but not limited to:
- .1 Proper thermal overload protection in place for electrical equipment.
  - .2 Air systems:
    - .1 Filters in place, clean.
    - .2 Duct systems clean.
    - .3 Ducts, air shafts, ceiling plenums are airtight to within specified tolerances.
    - .4 Correct fan rotation.
    - .5 Fire, smoke, volume control dampers installed and open.
    - .6 Coil fins combed, clean.
    - .7 Access doors, installed, closed.
    - .8 Outlets installed, volume control dampers open.
  - .3 Liquid systems:
    - .1 Flushed, filled, vented.
    - .2 Correct pump rotation.
    - .3 Strainers in place, baskets clean.
    - .4 Isolating and balancing valves installed, open.
    - .5 Calibrated balancing valves installed, at factory settings.
    - .6 Chemical treatment systems complete, operational.
- 1.10 APPLICATION TOLERANCES .1 Do TAB to following tolerances of design values:
- .1 HVAC systems: plus 5%, minus 5%.
  - .2 Hydronic systems: plus or minus 10%.
- 1.11 ACCURACY TOLERANCES .1 Measured values accurate to within plus or minus 2% of actual values.
- 1.12 INSTRUMENTS .1 Prior to TAB, submit to Departmental Representative list of instruments used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.
-



- 1.17 SETTINGS .1 After TAB is completed to satisfaction of Departmental Representative, replace drive guards, close access doors, lock devices in set positions, ensure sensors are at required settings.
- .2 Permanently mark settings to allow restoration at any time during life of facility. Do not eradicate or cover markings.
- 1.18 COMPLETION OF TAB .1 TAB considered complete when final TAB Report received and approved by Departmental Representative.
- 1.19 AIR SYSTEMS .1 Standard: TAB to most stringent of this section or TAB standards of AABC, NEBB, SMACNA and ASHRAE.
- .2 Do TAB of systems, equipment, components, controls specified in Division 23.
- .3 Qualifications: personnel performing TAB current member in good standing of AABC or NEBB.
- .4 Quality assurance: perform TAB under direction of supervisor qualified to standards of AABC or NEBB.
- .5 Measurements: to include as appropriate for systems, equipment, components, controls: air velocity, static pressure, flow rate, pressure drop (or loss), temperatures (dry bulb, wet bulb, dewpoint), duct cross-sectional area, RPM, electrical power, voltage, noise, vibration.
- .6 Locations of equipment measurements: to include as appropriate:
- .1 Inlet and outlet of dampers, filter, coil, humidifier, fan, other equipment causing changes in conditions.
- .2 At controllers, controlled device.
- .7 Locations of systems measurements to include as appropriate: main ducts, main branch, sub-branch, run-out (or grille, register or diffuser).
-

- 1.20 OTHER TAB REQUIREMENTS .1 General requirements applicable to work specified this paragraph:  
.1 Qualifications of TAB personnel: as for air systems specified this section.  
.2 Quality assurance: as for air systems specified this section.
- .2 Building pressure conditions:  
.1 Adjust HVAC systems, equipment, controls to ensure specified pressure conditions at all times.

PART 2 - PRODUCTS

- 2.1 NOT USED .1 Not used.

PART 3 - EXECUTION

- 3.1 NOT USED .1 Not used.

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
  - .2 American Society for Testing and Materials International, (ASTM).
    - .1 ASTM A 480/A 480M, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
    - .2 ASTM A 635/A 635M, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
    - .3 ASTM A 653/A 653M, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
  - .3 Department of Justice Canada (Jus).
    - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
  - .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
    - .1 Material Safety Data Sheets (MSDS).
  - .5 National Fire Protection Association (NFPA).
    - .1 NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems.
    - .2 NFPA 90B, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.
    - .3 NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.
  - .6 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
    - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible.
    - .2 SMACNA HVAC Air Duct Leakage Test Manual.
    - .3 IAQ Guideline for Occupied Buildings Under Construction.
  - .7 Transport Canada (TC).
    - .1 Transportation of Dangerous Goods Act (TDGA).
-

1.2 SUBMITTALS .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.

1.3 QUALITY ASSURANCE .1 Certification of Ratings:

.1 Catalogue or published ratings shall be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.

.2 Health and Safety:

.1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.4 DELIVERY, STORAGE AND HANDLING .1 Protect on site stored or installed absorptive material from moisture damage.

PART 2 - PRODUCTS

2.1 SEAL CLASSIFICATION .1 Classification as follows:

Maximum Pressure Pa	SMACNA Seal Class
500	C
250	C
125	C
125	Unsealed

---

.2 Seal classification:

.1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.

.2 Class B: longitudinal seams, transverse joints and connections made airtight with sealant.

.3 Class C: transverse joints and connections made air tight with sealant. Longitudinal seams unsealed.

.4 Unsealed seams and joints.

- 2.2 SEALANT .1 Sealant: oil resistant, water borne, polymer type flame resistant duct sealant. Temperature range of minus 30 degrees C to plus 93 degrees C.  
.1.
- 2.3 TAPE .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.  
.1.
- 2.4 DUCT LEAKAGE .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.
- 2.5 FITTINGS .1 Fabrication: to SMACNA.
- .2 Radiused elbows.  
.1 Rectangular: standard radius Centreline radius: 1.5 times width of duct  
.2 Round: smooth radius. Centreline radius: 1.5 times diameter.
- .3 Mitred elbows, rectangular:  
.1 To 400 mm: with single thickness turning vanes.  
.2 Over 400 mm: with double thickness turning vanes.
- .4 Branches:  
.1 Rectangular main and branch: with 45 degrees entry on branch.  
.2 Round main and branch: enter main duct at 45 degrees.  
.3 Provide volume control damper in branch duct near connection to main duct.  
.4 Main duct branches: with splitter damper.
- .5 Transitions:  
.1 Diverging: 20 degrees maximum included angle.  
.2 Converging: 30 degrees maximum included angle.
- .6 Offsets:  
.1 As indicated.
-

- 2.5 FITTINGS (Cont'd)
- .7 Obstruction deflectors: maintain full cross-sectional area.
    - .1 Maximum included angles: as for transitions.
- 2.6 FIRE STOPPING
- .1 Retaining angles around duct, on both sides of fire separation in accordance with Section 07 84 00 - Firestopping.
  - .2 Fire stopping material and installation must not distort duct.
- 2.7 GALVANIZED STEEL
- .1 Lock forming quality: to ASTM A 653/A 653M, Z90 zinc coating.
  - .2 Thickness, fabrication and reinforcement: to SMACNA.
  - .3 Joints: to SMACNA.
- 2.8 HANGERS AND SUPPORTS
- .1 Hangers and Supports: in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
    - .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.
      - .1 Maximum size duct supported by strap hanger: 500.
    - .2 Hanger configuration: to ASHRAE and SMACNA.
    - .3 Hangers: galvanized steel angle with galvanized steel rods to following table:
 

Duct Size (mm)	Angle Size (mm)	Rod Size (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10
    - .4 Upper hanger attachments:
      - .1 For concrete: manufactured concrete inserts.
      - .2 For steel joist: manufactured joist clamp.

- 2.8 HANGERS AND .1 (Cont'd)  
 SUPPORTS .4 Upper hanger attachments:(Cont'd)  
 (Cont'd) .3 For steel beams: manufactured beam  
 clamps:

PART 3 - EXECUTION

- 3.1 GENERAL .1 Do work in accordance with ASHRAE and SMACNA.  
 .2 Do not break continuity of insulation vapour  
 barrier with hangers or rods.  
 .1 Insulate strap hangers 100 mm beyond  
 insulated duct Ensure diffuser is fully  
 seated.  
 .3 Support risers in accordance with ASHRAE and  
 SMACNA.  
 .4 Install breakaway joints in ductwork on sides  
 of fire separation.  
 .5 Install proprietary manufactured flanged duct  
 joints in accordance with manufacturer's  
 instructions.  
 .6 Manufacture duct in lengths and diameter to  
 accommodate installation of acoustic duct  
 lining.

- 3.2 HANGERS .1 Strap hangers: install in accordance with  
 SMACNA.  
 .2 Angle hangers: complete with locking nuts and  
 washers.  
 .3 Hanger spacing: in accordance with ASHRAE and  
 SMACNA as follows:

Duct Size	Spacing
(mm)	(mm)
to 1500	3000
1501 and over	2500

- 3.3 WATERTIGHT DUCT .1 Provide watertight duct for:  
 .1 Fresh air intake.  
 .2 As indicated.
-

- 3.3 WATERTIGHT DUCT .2 Form bottom of horizontal duct without  
(Cont'd) longitudinal seams.
- .1 Weld joints of bottom and side sheets.
  - .2 Seal other joints with duct sealer.
- .3 Fit base of riser with 150 mm deep drain sump and 32 mm drain connected, with deep seal trap discharging to open funnel drain.
- 3.4 SEALING AND TAPING .1 Apply sealant to outside of joint to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.
- 3.5 LEAKAGE TESTS .1 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .2 Do leakage tests in sections.
- .3 Make trial leakage tests as instructed to demonstrate workmanship.
- .4 Do not install additional ductwork until trial test has been passed.
- .5 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degrees elbows.
- .6 Complete test before performance insulation or concealment Work.

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
    - .1 Material Safety Data Sheets (MSDS).
  - .2 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
    - .1 SMACNA - HVAC Duct Construction Standards - Metal and Flexible, 95.
- 1.2 SUBMITTALS
- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Submit manufacturer's printed product literature, specifications and data sheet. Indicate the following:
      - .1 Flexible connections.
      - .2 Duct access doors.
      - .3 Turning vanes.
      - .4 Instrument test ports.
  - .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
    - .1 Certification of ratings: catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
  - .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
  - .5 Instructions: submit manufacturer's installation instructions.
  - .6 Manufacturer's Field Reports: manufacturer's field reports specified.
  - .7 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
-

1.3 QUALITY  
ASSURANCE

- .1 Health and Safety:
  - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Manufacture in accordance with SMACNA - HVAC Duct Construction Standards.

2.2 FLEXIBLE  
CONNECTIONS

- .1 Frame: galvanized sheet metal frame mm thick with fabric clenched by means of double locked seams.
- .2 Material:
  - .1 Fire resistant, self extinguishing, neoprene coated glass fabric, temperature rated at minus 40 degrees C to plus 90 degrees C, density of 1.3 kg/m<sup>2</sup>.

2.3 ACCESS DOORS IN  
DUCTS

- .1 Non-Insulated Ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame.
- .2 Insulated Ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame and 25 mm thick rigid glass fibre insulation.
- .3 Gaskets: neoprene.
- .4 Hardware:
  - .1 Up to 300 x 300 mm: two sash locks complete with safety chain.
  - .2 301 to 450 mm: four sash locks complete with safety chain.
  - .3 451 to 1000 mm: piano hinge and minimum two sash locks.
  - .4 Doors over 1000 mm: piano hinge and two handles operable from both sides.
  - .5 Hold open devices.
  - .6 300 x 300 mm glass viewing panels.

- 
- 2.4 TURNING VANES .1 Factory or shop fabricated double thickness with trailing edge, to recommendations of SMACNA and as indicated.
- 2.5 INSTRUMENT TEST .1 1.6 mm thick steel zinc plated after manufacture.
- .2 Cam lock handles with neoprene expansion plug and handle chain.
- .3 28 mm minimum inside diameter. Length to suit insulation thickness.
- .4 Neoprene mounting gasket.
- 2.6 SPIN-IN COLLARS .1 Conical galvanized sheet metal spin-in collars with lockable butterfly damper.
- .2 Sheet metal thickness to co-responding round duct standards.
- PART 3 - EXECUTION
- 3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.
- 3.2 INSTALLATION .1 Flexible Connections:
- .1 Install in following locations:
- .1 Inlets and outlets to supply air units and fans.
- .2 Inlets and outlets of exhaust and return air fans.
- .3 As indicated.
- .2 Length of connection: 100 mm.
- .3 Minimum distance between metal parts when system in operation: 75 mm.
- .4 Install in accordance with recommendations of SMACNA.
- .5 When fan is running:
- .1 Ducting on sides of flexible connection to be in alignment.
-

- 3.2 INSTALLATION .1 (Cont'd)
- (Cont'd) .5 When fan is running:(Cont'd)
- .2 Ensure slack material in flexible connection.
- .2 Access Doors and Viewing Panels:
- .1 Size:
- .1 600 x 600 mm for person size entry.
- .2 600 x 600 mm for servicing entry.
- .3 300 x 300 mm for viewing.
- .4 As indicated.
- .2 Locations:
- .1 Fire and smoke dampers.
- .2 Control dampers.
- .3 Devices requiring maintenance.
- .4 Required by code.
- .5 Reheat coils.
- .6 Elsewhere as indicated.
- .3 Instrument Test Ports:
- .1 General:
- .1 Install in accordance with recommendations of SMACNA and in accordance with manufacturer's instructions.
- .2 Locate to permit easy manipulation of instruments.
- .3 Install insulation port extensions as required.
- .4 Locations:
- .1 For traverse readings:
- .1 Ducted inlets to roof and wall exhausters.
- .2 Inlets and outlets of other fan systems.
- .3 Main and sub-main ducts.
- .4 And as indicated.
- .2 For temperature readings:
- .1 At outside air intakes.
- .2 In mixed air applications in locations as approved by Departmental Representative.
- .3 At inlet and outlet of coils.
- .4 Downstream of junctions of two converging air streams of different temperatures.
- .5 And as indicated.
- .4 Turning vanes:
- .1 Install in accordance with recommendations of SMACNA and as indicated.
-

3.3 FIELD QUALITY CONTROL .1 Manufacturer's Field Services:

.1 Have manufacturer of products, supplied under this Section, review Work involved in the handling, installation/application, protection and cleaning, of its products and submit written reports, in acceptable format, to verify compliance of Work with Contract.

.2 Manufacturer's Field Services: provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

.3 Schedule site visits, to review Work, at stages listed:

.1 After delivery and storage of products, and when preparatory Work, or other Work, on which the Work of this Section depends, is complete but before installation begins.

.2 Twice during progress of Work at 25% and 60% complete.

.3 Upon completion of the Work, after cleaning is carried out.

.4 Obtain reports, within 3 days of review, and submit, immediately, to Departmental Representative.

3.4 CLEANING .1 Perform cleaning operations as specified in Section and in accordance with manufacturer's recommendations.

.2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

- 1.1 REFERENCES .1 Air Conditioning and Mechanical Contractors (AMCA)
- .1 AMCA Publication 99, Standards Handbook.
  - .2 AMCA 300, Reverberant Room Method for Sound Testing of Fans.
  - .3 AMCA 301, Methods for Calculating Fan Sound Ratings from Laboratory Test Data.
- .2 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)
- .1 ANSI/AMCA 210, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating.
- .3 Canadian General Standards Board (CGSB)
- .1 CAN/CGSB 1.181, Ready-Mixed Organic Zinc-Rich Coating.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
- .1 Material Safety Data Sheets (MSDS).
- 1.2 SYSTEM DESCRIPTION .1 Performance Requirements:
- .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards in force.
  - .2 Capacity: flow rate, static pressure, W, efficiency, revolutions per minute, power, model, size, sound power data and as indicated on schedule.
  - .3 Fans: statically and dynamically balanced, constructed in conformity with AMCA 99.
  - .4 Sound ratings: comply with AMCA 301, tested to AMCA 300. Supply unit with AMCA certified sound rating seal.
  - .5 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210. Supply unit with AMCA certified rating seal, except for propeller fans smaller than 300 mm diameter.

- 1.3 SUBMITTALS .1 Product Data:
- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
    - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Shop Drawings:
    - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
      - .1 Shop Drawings: submit drawings stamped and signed by professional engineer registered or licensed in Canada.
  - .3 Provide :
    - .1 Fan performance curves showing point of operation, kW and efficiency.
    - .2 Sound rating data at point of operation.
  - .4 Indicate:
    - .1 Motors, sheaves, bearings, shaft details
    - .2 Minimum performance achievable with variable speed controllers.
  - .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
    - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
    - .2 Instructions: submit manufacturer's installation instructions.
      - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.
  - .6 Closeout Submittals:
    - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
-

1.4 QUALITY ASSURANCE .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.5 MAINTENANCE .1 Extra Materials:  
.1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.  
.1 Spare parts to include:  
.1 Matched sets of belts.  
.2 Furnish list of individual manufacturer's recommended spare parts for equipment, include:  
.1 Bearings and seals.  
.2 Addresses of suppliers.  
.3 List of specialized tools necessary for adjusting, repairing or replacing.

1.6 DELIVERY, STORAGE, AND HANDLING .1 Packing, shipping, handling and unloading:  
.1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.  
.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

PART 2 - PRODUCTS

2.1 FANS GENERAL .1 Motors:  
.1 Sizes as indicated.  
.2 Accessories and hardware: matched sets of V-belt drives, adjustable motor bases, belt guards, coupling guards fan inlet safety screens as indicated and as specified in Section 23 05 13 - Common Motor Requirements for HVAC Equipment.  
.3 Factory primed before assembly in colour standard to manufacturer.  
.4 Scroll casing drains: as indicated.

- 2.1 FANS GENERAL  
(Cont'd)
- .5 Bearing lubrication systems plus extension lubrication tubes where bearings are not easily accessible.
  - .6 Flexible connections: to Section 23 33 00 - Air Duct Accessories.
- 2.2 CENTRIFUGAL  
FANS
- .1 Fan wheels:
    - .1 Welded aluminum construction.
    - .2 Maximum operating speed of centrifugal fans not more than 50 % of first critical speed.
    - .3 Air foil, forward curved, backward inclined blades, as indicated.
  - .2 Bearings: heavy duty split pillow-block flange mounted grease lubricated ball or roller self aligning type with oil retaining, dust excluding seals and a certified minimum rated life of 100,000 hours.
  - .3 Housings:
    - .1 Volute with inlet cones: fabricated steel for wheels 300 mm or greater, aluminum, for smaller wheels, braced, and with welded supports.
    - .2 For horizontally and vertically split housings provide flanges on each section for bolting together, with gaskets of non-oxidizing non-flammable material.
    - .3 Provide latched airtight access doors with handles.
- 2.3 CABINET FANS-  
GENERAL PURPOSE
- .1 Fan characteristics and construction: as centrifugal fans.
  - .2 Cabinet hung single or multiple wheel with DWDI centrifugal fans in factory fabricated casing complete with vibration isolators and seismic control measures, motor, V-belt drive and guard.
  - .3 Fabricate casing of zinc coated or phosphate treated steel of reinforced and braced for rigidity. Provide removable panels for access to interior. Paint uncoated, steel parts with corrosion resistant paint to CAN/CGSB 1.181. Finish inside and out, over prime coat, with
-

- 2.3 CABINET FANS-  
GENERAL PURPOSE  
(Cont'd) .3 (Cont'd)  
rust resistant enamel. Internally line cabinet  
with 50 mm thick rigid acoustic insulation,  
pinned and cemented, complete with metal  
nosings on exposed edges.
- PART 3 - EXECUTION
- 3.1 MANUFACTURER'S  
INSTRUCTIONS .1 Compliance: comply with manufacturer's  
written recommendations or specifications,  
including product technical bulletins,  
handling, storage and installation  
instructions, and datasheet.
- 3.2 FAN  
INSTALLATION .1 Install fans as indicated, complete with  
flexible electrical leads and flexible  
connections in accordance with Section  
23 33 00 - Air Duct Accessories.
- .2 Provide sheaves and belts required for final  
air balance.
- .3 Bearings and extension tubes to be easily  
accessible.
- .4 Access doors and access panels to be easily  
accessible.
- 3.3 ANCHOR BOLTS  
AND TEMPLATES .1 Size anchor bolts to withstand seismic  
acceleration and velocity forces as specified.
- 3.4 CLEANING .1 Proceed in accordance with Section 01 74 11 -  
Cleaning.
- .2 Upon completion and verification of  
performance of installation, remove surplus  
materials, excess materials, rubbish, tools  
and equipment.